



**ODISHA POWER TRANSMISSION CORPORATION LIMITED
OFFICE OF THE SENIOR GENERAL MANAGER
CENTRAL PROCUREMENT CELL
JANAPATH, BHUBANESWAR-751022**

**TEL NO- 0674-2541801 FAX NO: 0674-2542964
TENDER SPECIFICATION NO
SGM-CPC-TENDER-CIRCUIT BREAKERS-42/2016-17
FOR
PROCUREMENT OF 420 KV SF₆ CIRCUIT BREAKERS**

Request for online tender documents – From dt- 03-12-2016 (13.00 hrs) to dt- 02.01.2017 (13.00 hrs)

Last date of submission of online tender - dt- 03.01.2017 (13.00 hrs)

Date of opening of Tender 03.01.2017 (15.00 hrs)



ODISHA POWER TRANSMISSION CORPORATION LTD.
REGD. OFFICE: JANPATH, BHUBANESWAR – 751 022,
ODISHA

E-TENDER NOTICE NO.CPC- 42 / 2016-17

For and on behalf of ODISHA POWER TRANSMISSION CORPORATION LTD, Sr.G.M. (CPC) invites Tenders from reputed manufacturers in two part bidding system for supply of **420 KV CIRCUIT BREAKERS**. The interested bidders would be required to enroll themselves on the tender portal www.tenderwizard.com/OPTCL. Complete set of bidding documents are available at www.tenderwizard.com/OPTCL from 03-12-2016 (13.00 Hrs) up to 02-01-2017 (13.00 Hrs).Interested manufacturers may visit OPTCL's official web site <http://www.optcl.co.in> and www.tenderwizard.com/OPTCL for detail specification.

N.B:- All subsequent addendums/corrigendum to the tender shall be hosted in the OPTCL's official web site <http://www.optcl.co.in> and www.tenderwizard.com/OPTCL only.

SENIOR GENERAL MANAGER (CPC)



NOTICE INVITING TENDER

ODISHA POWER TRANSMISSION CORPORATION LTD.,
REGD. OFFICE: JANPATH, BHUBANESWAR – 751022,
ODISHA, INDIA.

e-TENDER NOTICE NO.CPC- 42/2016-17

For and on behalf of the ODISHA POWER TRANSMISSION CORPORATION LTD, the undersigned invites bids under two-part bidding system in e- tendering mode only as per the following details.

Sl. No	Tender Specification No.	Description of equipments/ materials	Qty In Nos.	Earnest Money Deposit (In Rs.)	Cost of Tender Spec. document (in Rs.)	Tender Processing fee	Last date of receipt & opening of tender
1.	Sr. GM-CPC-Tender-C.B - 42/2016-17	420 KV SF₆ Circuit Breakers	8	2, 51, 618/-	10,000/- + 500/- (VAT) Rs 10, 500/-	Rs.5, 000/- +Service Tax @15 % i.e. Rs 5,750/-	Up to 02.01.2017 (13.00 Hrs.) & on 03.01.2017 at 15.00 Hrs.

The bidders can view the tender documents from website free of cost.

The bidders who want to submit bid shall have to pay Rs. 10,500/- (Rupees Ten thousand five hundred only non-refundable including VAT @ 5%) towards the tender cost, in the form of Demand draft/Cash only, drawn in favour of the D.D.O Headquarters, OPTCL Bhubaneswar.

The bidders shall have to submit non-refundable amount of Rs.5, 750/- (Rupees Five thousand seven hundred fifty) only including Service Tax @ 15.0 %) towards the tender processing fee to K.S.E.D.C.Ltd, in e-payment mode. The e-payment of above amount is to be made to enable the bidder to down load the bid proposal sheets & bid document in electronic mode.

The demand draft/pay order for tender cost , processing fee are to be submitted along with the EMD at the office of the undersigned on or before the last date & time of submission of tender.

The bidder shall deposit the tender cost, tender processing fee & EMD BG prior to last date & time for submission of bid as notified in tender notice. Local micro & small enterprisers (MSEs) **(In the state of Odisha)** registered with respective DICs, Khadi, Village, Cottage & Handicrafts Industries, OSIC and NSIC can participate without payment of the cost of tender specification. They have to submit notarized hard copy of valid registration as local MSE as above on or before the last date & time of submission of tender.

The prospective bidders are advised to register their user ID, Password, company ID from website www.tenderwizard.com/OPTCL by clicking on hyper link “Register Me”.

Any clarifications regarding the scope of work and technical features of the tender can be had from the undersigned during office hours.

Minimum qualification criteria of bidders: AS STIPULATED IN SECTION-II, (G.T.C.C) OF THE TENDER SPECIFICATION.

**SENIOR GENERAL MANAGER,
CENTRAL PROCUREMENT CELL**



TELEPHONE NO: 0674 – 2541801

FAX NO.: 0674 – 2542964

**ODISHA POWER TRANSMISSION CORPORATION LTD.
CENTRAL PROCUREMENT CELL**

JANAPATH, BHUBANESWAR – 751022

TENDER SPECIFICATION NO-SR.G.M-CPC-TENDER-420 KV SF₆ CIRCUIT BREAKERS -42/2016-17

CONTAINING

PART – I

SECTION – I : INSTRUCTION TO BIDDERS

**SECTION – II: GENERAL TERMS AND CONDITIONS OF CONTRACT (G.T.C.C.)
(COMMERCIAL)**

SECTION – III : LIST OF ANNEXURES (COMMERCIAL)

SECTION – IV : TECHNICAL SPECIFICATION

PART – II PRICE BID.

PART – I
TABLE OF CONTENTS
SECTION – I.
INSTRUCTIONS TO BIDDERS

<u>Clause.</u>	<u>Title.</u>	<u>Page.</u>
1.	Submission of Bids.	7 & 8
2.	Division of Specification.	8
3.	Bidders shall be in two parts.	8
4.	Opening of Bids	8 & 9
5.	Purchaser's right regarding alteration in	9
6.	Procedure and opening time of tenders.	9
7.	Bidder's liberty to deviate from specification.	9
8.	Eligibility for submission of bids.	9
9.	Purchaser's right to accept/reject bids.	9
10.	Mode of submission of tenders.	9
11.	Earnest money deposit.	9 & 10
12.	Validity of the bids.	10
13.	Price.	10
14.	Revision of Tender Price by Bidders.	10
15.	Bidders to be fully conversant with the clauses of the Specification	11
16.	Documents to accompany Bids.	11
17.	Documents/Papers to Accompany PART – II Bid	11
18.	Conditional Offer.	11
19.	General.	11 & 12
20.	Expenses in respect of OPTCL's representative for witnessing the inspection & testing of the offered Equipment/materials at the inspection & testing site.	12 & 13
21.	Litigation/Arbitration	13

SECTION – II.

GENERAL TERMS AND CONDITIONS OF CONTRACT [G.T.C.C.]

<u>Clause.</u>	<u>Title.</u>	<u>Page.</u>
1.	Scope of the contract.	15
2.	Definition of terms.	15
3.	Manner of execution.	15
4.	Inspection and testing.	16
5.	Training facilities.	16
6.	Rejection of materials.	17
7.	Experience of bidders.	17
8.	Language and measures.	17
9.	Deviation from Specification.	17
10.	Right to reject/accept any tender.	18
11,	Supplier to inform himself fully.	18
12.	Patent rights etc.	18
13.	Delivery.	18
14.	Despatch Instructions.	18
15.	Supplier's Default Liability.	18-19
16	Force Majeure.	19
17.	Extension of Time.	19
18.	Guarantee Period.	19
19.	Bank Guarantee towards Security Deposit, Payment and Performance	20
20.	Import License.	20
21.	Terms of Payment.	20
22.	Penalty for Delay in Completion of Contract.	21
23.	Insurance.	21
24.	Payment Due from the Supplier.	21
25.	Sales Tax clearance, Balance Sheet and P/L Account	21
26.	Certificate of exemption from E.D/Sales Tax.	21
27.	Supplier's Responsibility.	21
28.	Validity.	22
29.	Evaluation.	22-23
30.	Minimum qualification criteria of Bidders.	22
31.	Jurisdiction of High Court of Orissa.	23
32.	Correspondences.	23
33.	Official Address of the Parties to the Contract.	23
34.	Outright rejection of Tenders.	23-24
35.	Documents to be treated as confidential.	24
36.	Scheme/Projects.	24

COMMERCIAL SPECIFICATION

PART – I

SECTION-I

INSTRUCTIONS TO BIDDERS

1. Submission of Bids: -

The bidder shall submit the bid in Electronic Mode only i.e. www.tenderwizard.com/OPTCL. The bidder must ensure that the bids are received in the specified website of the OPTCL by the date and time indicated in the Tender notice. Bids submitted by telex/telegram will not be accepted. No request from any bidder to the OPTCL to collect the Bids in physical form will be entertained by the OPTCL.

The OPTCL reserves the right to reject any bid, which is not deposited according to the instruction, stipulated above. The participants to the tender should be registered under ODISHA Sales Tax, Act, VAT Act / Central sales Tax Act.

1. For all the users it is mandatory to procure the Digital Signatures.
2. Contractors / Vendors / Bidders / Suppliers are requested to follow the below steps for Registration:
 - a. Click “Register”, fill the online registration form.
 - b. Pay the amount of Rs. 2300/- through **e-payment mode only**.
 - c. Send the acknowledgment copy for verification.
 - d. As soon as the verification is being done the e-tender user id will be enabled.
3. After viewing Tender Notification, if bidder intends to participate in tender, he has to use his e-tendering User Id and Password which has been received after registration and acquisition of DSCs (Digital Signature Certificates).
4. If any Bidder wants to participate in the tender he will have to follow the instructions given below:
 - a. Insert the PKI (which consist of your Digital Signature Certificate) in your System.
(Note: Make sure that necessary software of PKI be installed in your system).
 - b. Click / Double Click to open the Microsoft Internet Explorer (This icon will be located on the Desktop of the computer).
 - c. Go to Start > Programs > Internet Explorer.
 - d. Type www.tenderwizard.com/OPTCL in the address bar, to access the Login Screen.
 - e. Enter e-tender User Id and Password, click on “Go”.
 - f. Click on “Click here to login” for selecting the Digital Signature Certificate.
 - g. Select the Certificate and enter DSC Password.
 - h. Re-enter the e-Procurement User Id Password
5. To make a request for Tender Document Bidders will have to follow below mentioned steps.
 - Click “Un Applied” to view / apply for new tenders.
 - Click on Request icon for online request.
6. After making the request Bidders will receive the Tender Documents which can be checked and downloaded by following the below steps:
 - Click to view the tender documents which are received by the user.
 - Tender document screen appears.
 - Click “Click here to download” to download the documents.
7. After completing all the formalities Bidders will have to submit the tender and they must take care of following instructions.
 - Prior to submission, verify whether all the required documents have been attached and uploaded to the particular tender or not.
 - Note down / take a print of bid control number once it displayed on the screen

8. Tender Opening event can be viewed online.
9. Competitors bid sheets are available in the website for all.
10. **For any e-tendering assistant contact help desk number mentioned below.**
 - Bangalore – 080- 40482000.The participants to the tender should be registered under ODISHA Sales Tax, Act, VAT Act/Central sales Tax Act.

2. Division of Specification

The Specification is mainly divided into two parts viz. Part-I and Part-II.

Part- I Consists of

- (i) Section-I : Instructions to Bidders.
- (ii) Section-II : General conditions of supply (commercial)
- (iii) Section-III : Schedules and forms etc.
- (iv) Section-IV : Technical Specification.

Part-II Consists of

Schedule of prices as per Annexure-V

3. Tenders shall be in Two Parts:-

The Bidders are required to submit the tenders in two parts Part-I (techno- commercial) and Part- II (Price Bid).

4. Opening of Bids:-

(a) The part-I shall be opened on the date and time fixed by the OPTCL. Bids will be opened in Electronic mode in presence of the Bidders or their authorized representatives [limited to one person only] on the due date of opening of tender. After scrutiny of the technical particulars and other commercial terms, clarifications, if required, shall be sought for from the bidders. The Bidders shall be allowed 15 days' time for such activity.

(b) On receipt of technical clarification the bids shall be reviewed/evaluated and those not in conformity with the technical Specification/qualifying experience, shall be rejected. If any of the technical proposals requires modification to make them comparable, discussion will be held with the participating bidders.

All the responsive bidders shall be given opportunity to submit the revised technical and revised price proposals as a follow up to the clarification on the technical proposals. The qualified bidders shall be given opportunity to submit revised price proposals within 15 days from the date of such discussion or within time frame mutually agreed, whichever is earlier.

(c) When the revised price proposals are received, only the revised technical and price proposals will be considered for bid evaluation. The price bids [Part-II] of such of the Bidders, whose tenders have been found to be technically and commercially acceptable, including those supplementary revised price bids, submitted subsequently, shall be opened in the presence of the bidder's representative on a date and time which will be intimated to all technically and commercially acceptable Bidders.

(d) The bidders are required to furnish sufficient information to the Purchaser to establish their qualification/capability to manufacture and/or supply the materials/perform the work. Such information shall include details of bidder's experience, its financial, managerial and technical capabilities.

(e) The bidders are also required to furnish details of availability of appropriate technical staff and capability to perform after sales service where applicable. The above information shall be considered during the first stage of scrutiny and evaluation of bids and any bid which does not satisfactorily meet these requirements, shall not be considered for price bid evaluation.

(f) The price bids of the technically and otherwise acceptable bids shall only be evaluated as per the norms applicable in terms of this Specification.

5. Purchaser's Right Regarding Alteration of Quantities Tendered:-

The Purchaser may alter the quantities of materials/equipment at the time of placing orders. Initially the Purchaser may place order for lesser quantity with full freedom to place extension orders for further quantity under similar terms and conditions of the original orders. Order may also be split among more than one Bidder for any particular item if considered necessary in the interest of the Purchaser.

6. Procedure & Opening Time of Tenders:-

Tenders will be opened in the office of the Sr. General Manager (CPC) on the specified date and time in present of such of the Bidders or their authorized representatives (limited to one person only) in case of each bidders who may desire to be present, at the time of opening the bids.

7. Bidder's Liberty to Deviate from Specification:-

The Bidder may deviate from the Specification while quoting if in his opinion such deviation is in the line with the manufacturer's standard practice and conducive to a better and more economical offer. All such deviations should however be clearly indicated giving full justifications for such deviation. (Read with Clause-9, Section-II of the Specification).

8. Eligibility for Submission of Bids:-

Only those manufacturers who have deposited the cost of tender specification are eligible to participate in the tender. They should upload the scanned copy of the D.D/ money receipt as a proof of such payment. The local Micro & Small Enterprises (MSEs) **(In the state of Odisha)** register with respective DICs, Khadi, Village, Cottage & Handicraft Industries, OSIC and NSIC **(Registered in Odisha)** can participate without payment of the cost of tender specification.

9. Purchaser's Right to Accept/Reject Bids:-

The purchaser reserves the right to reject any or all the tenders without assigning any reasons what so ever if it is in the interest of OPTCL under the existing circumstances. (Read with Clause-10, Section-II of the Specification).

10. Mode of Submission of Bids:-

(A) Bidders shall be submitted in electronic mode only. (www.tenderwizard.com/OPTCL)

(B)Telegraphic or FAX tenders shall not be accepted under any circumstances.

11. Earnest Money Deposit:-

(i) Earnest Money Deposit of value specified in the notice inviting tenders against each lot/ bid is to be submitted on or before the last date and time of submission of tender. Tenders without the required E.M.D. or without documentary proof for exemption from furnishing E.M.D. as indicated at Annexure-VIII will be rejected outright. The local Micro & Small Enterprises (MSEs) **(In the state of ODISHA)** register with respective DICs, Khadi, Village, Cottage & Handicraft Industries, OSIC and NSIC can participate by submitting EMD deposit 50 % of the amount indicated in the notice inviting tender.

The earnest money deposit shall be furnished in one of the following forms subject to the conditions mentioned below:

(a)Cash: Payable to Drawing & Disbursing Officer, OPTCL (Hrs. Office, Bhubaneswar-751022.

(b) Bank Draft: To be drawn in favour of the Drawing & Disbursing Officer, OPTCL (Hqrs. Office), Bhubaneswar-751022.

(c) Bank Guarantee from any nationalized/scheduled Bank strictly as per enclosed proforma vide Annexure-VI to be executed on non-judicial stamp paper of appropriate value to be accompanied by the confirmation letter of the issuing Bank.

Note:

(i) The validity of the E.M.D. Bank Guarantee shall be 240 days from the date of opening of tender, failing which the tender will be liable for rejection.

ii) No interest shall be paid on the Earnest Money Deposit. Up to Rs.25, 000/- (Rupees twenty-five thousand) only the Earnest Money Deposit may be made either in cash or Bank Draft. Above

Rs.25, 000/- (Rupees Twenty Five Thousand only) the Earnest Money Deposit shall be furnished in shape of EMD Bank Guarantee, as per proforma attached.

iii) No adjustment towards Earnest Money Deposit shall be permitted against any outstanding amount with the OPTCL.

iv) The chart showing particulars of E.M.D. to be furnished by Bidders of different categories is placed at Annexure-VIII.

v) In the case of un-successful Bidder the Earnest Money will be refunded immediately after the tender is decided. In the case of successful Bidders, EMD will be refunded only after furnishing of security money referred to at Clause-19 of section –II. Suits if any, arising out of this Clause shall be filed in a Court of law to which the jurisdiction of high court of Odisha extends.

vi) Earnest Money will be forfeited if the Bidders fail to accept the letter of intent and /or purchase orders issued in his favour.

vii) Tenders not accompanied by Earnest Money/documentary proof of Exemption of E.M.D. shall be summarily rejected.

12. Validity of the Bids:-

The tenders should be kept valid for a period of 180 days from the date of opening of the tender as notified in the tender notice failing which the tenders will be rejected.

13. PRICE:-

i) Bidders are requested to quote-‘FIRM’ Price. No deviation from FIRM PRICE will be entertained irrespective of deviation clause No.7 of this part of the specification.

14. Revision of Tender Price By Bidders:-

a) After opening of tenders and within the validity period, no reduction or Enhancement in price will be entertained. If there is any change in price, the tender shall stand rejected and E.M.D. deposited shall be forfeited. In case of bidders who are exempted from depositing E.M.D. and who revise their price within the validity period, the bids for similar items against subsequent tender call notice of OPTCL, may not be considered.

b) After opening of price bid if the validity period is not sufficient to place purchase order, the Bidders may be asked by the purchaser to extend the validity period of the bid under the same terms and condition as per the original tender.

However, the tender are free to change any or all conditions including price except delivery period of their bids at their own risk, if they are asked by the purchaser to extend the validity period of the bid prior to opening of price bid.

15. Bidders to be fully Conversant with the Clauses of the specification:-

Bidders are expected to be fully conversant with the meaning of all the Clauses of the Specification before submitting their tenders. In case of doubt regarding the meaning of any Clause the Bidders may seek clarification in writing from the Sr. General Manager (CPC) OPTCL. This however, does not entitle the Bidders to ask for time beyond due date fixed for receipt of tender.

16. Documents to Accompany Bids:-

Bidders are required to upload the Scanned/.pdf copy of the following document as vender generic document and also upload the .xls bid documents as mentioned below:-

Part-I (Vender Generic Document)

	Document Details	File Name
1	Declaration Form duly filled in and signed. (As per Annexure –I)	Attachment1.pdf
2	(a) Earnest Money(As per Annexure-VI) or Documents in support of exemption from Earnest Money Deposit if any (b)Tender cost (c)Tender Processing fee.	Attachment2.pdf
3	Technical Specification conforming to the Purchaser’s Specification along with drawings and literature.	Attachment3.pdf
4	Photostat copies of latest type test certificate of materials/ equipment offered. (Type tests should have been conducted within 5 years prior to the dated tender opening and not earlier).	Attachment4.pdf
5	List of orders executed for similar items during preceding four years indicating the customer’s name & P.O. copies.	Attachment5.pdf
6	Data on past experience as per Clause-7 of Section –II of the Specification.	Attachment6.pdf
7	Sales Tax clearance certificates for the previous year.	Attachment7.pdf
8	Audited Balance Sheet & Profit Loss Accounts for the previous three years.	Attachment8.pdf
9	Schedule of quantity and delivery in the prescribed proforma vide Annexure-III.	Attachment9.pdf
10	Abstract of price components as per Annexure-IV	Attachment10.pdf
11	Any other required document as per tender specification	Attachment11.pdf
12	The notarized hard copy & soft copy of valid registration as local MSE (In the state of Odisha) (if any) on or before the last date & time of submission of tender.	
13	Any attachment having size more than 5Mb is to be divided into parts like Attachment1partI, Attachment1partII etc.	

Part-I (Techno-commercial Bid Sheet)

1	All the.xls sheets are to be down loaded and filled in completely and uploaded without any modification to the file name.	.xls sheet name /file name is not to be modified
---	---	--

- 17. Documents/Papers to Accompany Part –II Bid:-**
Part –II of the tender shall consist of the following.

Part-II (Price Bid Sheet).

1	All the .xls sheets are to be down loaded and filled in completely and uploaded without any modification to the file name.	.xls sheet name /file name is not to be modified
---	--	--

- 18. Conditional Offer:-**
Conditional offer shall not be accepted.

19. General:-

- (i) Over writing shall be avoided
- (ii) Erasures and other changes shall bear the dated initial of the person signing the tender.
- (iii) In the event of discrepancy or arithmetical error in the schedule of price, the decision of the Purchaser shall be final and binding on the Bidders.
- (iv) For evaluation the price mentioned in words shall be taken if there is any difference in figure and words in the price bid.
- (v) Notice inviting tender shall form part of this Specification.
- (vi) The price bids of the technically and otherwise acceptable bids shall only be evaluated.
- (vii) It should be distinctly understood that the part-II of the bid shall contain only details/documents relating to price, as outlined in clause-17 mentioned herein above. Inclusion of any of the documents/information etc. shall render the bid liable for rejection.
- (viii) The Bidders must submit the EMD amount, cost of tender document (Form Fee) and Tender processing fee in a sealed cover envelope super-scribing the tender specification number, Tender Notice No & Date opening of tender clearly on the cover envelope. The said envelope is to be submitted in the office of the purchaser on or before the last date and time of submission of Bids.

20 Expenses in respect of OPTCL's representative for witnessing the inspection & testing of the offered equipment/materials at the inspection and testing site:-

The expenses under the following heads, in respect of OPTCL's representative for witnessing the inspection & testing of the offered equipment/materials at the inspection and testing site, shall be borne by the contractor / supplier.

a) Hotel Accommodation:

- I. Single room accommodation in 4 star hotels for the OPTCL inspecting officer of the rank of Assistant General Manager (Grade E-6) and above.
- II. Single room accommodation in 3 star hotels for the OPTCL inspecting officer of the rank below Assistant General Manager (Grade E-6).

N.B.: It is the responsibility of the contractor to arrange the hotel accommodation matching with their inspection and testing schedule, so that the inspecting officer can check-in the hotel one day prior to the date of inspection and check out after the completion of the inspection, subject to availability of the return travel ticket. In case of extended duration of inspection or non-availability of the return travel ticket, Contractor/supplier/manufacturer shall arrange for the extended stay of the inspecting officer in the Hotel accordingly. In case there is no hotel with prescribed standard in and around the place of inspection, the contractor/supplier/manufacturer shall suggest alternative suitable arrangement at the time of offer for inspection, which is subjected to acceptability of OPTCL inspecting officer.

b) Journey of the inspecting officer:

- (i) To and fro travel expenditure from the Head Quarters of the inspecting officer to the place of inspection/testing shall be borne by the contractor/supplier/manufacturer. Journey from the Head Quarters of the inspecting officer to the nearest Air Port by train (1st/IIInd A.C) & A/C Taxi then by Air to the place of inspection/testing or to the nearest place of inspection/testing and then by train (1st/IIInd A.C) & A/C taxi to the place of inspection/testing shall be arranged by the contractor/supplier/manufacturer.
- (ii) For train journey, inspecting officer of the rank Assistant General Manager and above shall be provided with 1st class AC ticket and inspecting officer below the rank of Assistant General Manager shall be provided with 2nd class AC ticket.

(iii) The Air-ticket / train-ticket booking/cancellation is the responsibility of the contractor / supplier.

(iv) Moreover, if during the journey there is an unavoidable necessity for intermediate travel by road/ waterway/sea-route, the contractor/supplier shall provide suitable conveyance to the inspecting officer for travel this stretch of journey or bear the cost towards this. Any such possibilities shall be duly intimated to OPTCL at the time of their offer for inspection.

c) Local Conveyance:

At the place of the inspection/testing, for local journey of the inspecting officer between Hotel and inspection/testing site and or any other places, Air-conditioned four wheeler vehicle in good condition shall be provided by the contractor/supplier/manufacturer.

d) Following points are also to be considered:

(i) All the above expenses shall be deemed to be included in the bidder's quoted price for that supply item. Bidder shall not be eligible to raise any extra claim in this regard.

(ii) Contractor/supplier/manufacturer may assume that only in 40% of the inspection and testing offer cases, OPTCL inspecting officer, not below the rank of Assistant General Manager will witness the inspection and testing.

(ii) In case of inspection and testing of some critical equipment/materials like Power transformers, OPTCL may depute more than one inspecting officer.

(iii) Contractor/supplier/manufacturer shall judiciously plan the inspection/testing schedule and place of inspection/testing, so that optimum number of inspection/testing and minimum time shall be required to cover all the equipment/materials of the relevant contract package.

(iv) It shall be the responsibility of the Contractor/Supplier to organize the above tour related matters of OPTCL inspecting officer including the matters related to overseas inspection/testing, if any.

21. Litigation/Arbitration

(i)- Bidder has to furnish detailed information on any litigation or arbitration arising out of contracts completed or under execution by it over the last five years. A consistent history of litigation by or against the bidder may result in rejection of bid.

(ii) The bidder should not have any pending litigation or arbitration with OPTCL with regard to any project or related activity. The bidder should certify/declare the same in unequivocal terms by way of an affidavit duly sworn before a magistrate. Bid furnished by the bidder shall not be eligible for consideration if it is not accompanied by the affidavit. Further, the bid/LOA/LOI shall liable for outright rejection/cancellation at any stage if any information contrary to the affidavit/declaration is detected.

PART-I

SECTION-II

GENERAL TERMS AND CONDITIONS OF CONTRACT [GTCC]

1.0 Scope of the contract:-

The scope of the contract shall be to design, manufacture, supply of equipments as per the specification at the consignee's site, and rendering services in accordance with the enclosed technical specification and bill of quantity.

2.0 Definition of terms:-

For the purpose of this specification and General Terms and Conditions of contract [GTCC], the following words shall have the meanings hereby indicated, except where otherwise described or defined.

2.1 "The Purchaser" shall mean the Senior General Manager [Central Procurement Cell] for and on behalf of ODISHA POWER TRANSMISSION CORPORATION LTD., Bhubaneswar.

2.2 "The Engineer" shall mean the Engineer appointed by the Purchaser for the Purpose of this contract.

2.3 "Purchaser's Representative" shall mean any person or persons or consulting firm appointed and remunerated by the Purchaser to supervise, inspect, test and examine workmanship and materials of the equipment to be supplied.

2.4 "The supplier" shall mean the bidder whose bid has been accepted by the purchaser and shall include the bidder's executives, administrators, successors and permitted assignees.

2.5 "Equipment" shall mean and include all machinery, apparatus, materials, and articles to be provided under the contract by the suppliers.

2.6 "Contract Price" shall mean the sum named in or calculated the bid.

2.7 "General Condition" shall mean these General Terms and Conditions of Contract.

2.8 "The Specification" shall mean both the technical as well as commercial parts of the specification annexed to or issued with GTCC and shall include the schedules and drawings, attached thereto as well as all samples and pattern, if any.

2.9 "Month" shall mean "Calendar month".

2.10 "Writing" shall include any manuscript, type written, printed or other statement reproduction in any visible form and whether under seal or under hand.

2.11 "FOR Destination costs" shall mean the cost of equipment and material at the consignee's store/site. The cost is inclusive of Excise duty, Sales tax and other local taxes, packing, forwarding and insurance and freight charges.

2.12 The term "Contract document" shall mean and include GTCC, specifications, schedules, drawings, form of tender, Notice Inviting Tender, covering letter, schedule of prices or the final General Conditions, any special conditions, applicable to the particular contract.

2.13 Terms and conditions not herein defined shall have the same meaning as are assigned to them in the Indian Contract Act, failing that in the Odisha General Clauses Act.

3. Manner of execution:-

All equipments supplied under the contract shall be manufactured in the manner, set out in the Specification or where not set out, to the reasonable satisfaction of the Purchaser's representative.

4. Inspection and Testing:-

[i] The purchaser's representative shall be entitled at all reasonable times during manufacture to inspect, examine and test at the supplier's premises, the materials and workmanship of all equipments/materials to be supplied under this contract and if part of the said equipment/material is being manufactured in other premises, the supplier shall obtain for the purchaser's representative permission to inspect, examine and test as if the equipment/material were being manufactured in the contractor's premises. Such inspection, examination and testing shall not relieve the supplier from his obligations under the contract.

[ii] The Supplier shall give to the purchaser adequate time/notice (at least clear 15 days for inside the state suppliers and 20 days for outside the state suppliers) in writing for inspection of materials indicating the place at which the equipment/material is ready for testing and inspection and shall also furnish the shop Routine Test Certificate, Calibration certificates of Testing instruments, calibrated in Govt. approved laboratory with authenticity letter of that laboratory along with the offer for inspection. A packing list along with the offer, indicating the quantity which can be delivered in full truck load/Mini truck load to facilitate issue of dispatch instruction shall also be furnished.

[iii] Where the contract provides for test at the Premises of the supplier or any of his sub-vendors, the supplier shall provide such assistance, labour, materials, electricity, fuel and instruments, as may be required or as may be reasonably demanded by the Purchaser's representative to carry out such tests efficiently. The supplier is required to produce shop routine test Certificate, calibration certificates of Testing Instruments before offering their materials/equipment for inspection & testing. The test house/laboratory where tests are to be carried out must be approved by the Govt. A letter pertaining to Govt. approved laboratory must be furnished to the purchaser along with the offer for inspection.

[iv] After completion of the tests, the Purchaser's representative shall forward the test results to the Purchaser. If the test results conform to the specific standard and specification, the Purchaser shall approve the test results and communicate the same to the supplier in writing. The supplier shall provide at least five copies of the test certificates to the Purchaser.

[v] The Purchaser has the right to have the tests carried out at his own cost by an independent agency whenever there is dispute regarding the quality of supply.

[vi] If the firm fails to present the offered items for inspection/testing as per their inspection call due to any reason(s) during the visit of inspecting officer at the testing site, the firm shall have to bear all expenses towards repetition of inspection and testing of the total offered quantity or part thereof.

[vii] For PHASE-II delivery inspection call is to be offered by the bidder after 01.04.2017

5. Training facilities:-

The supplier shall provide all possible facilities for training of Purchaser's Technical personnel, when deputed by the Purchaser for acquiring firsthand knowledge in assembly of the equipment, its erection, commissioning and for its proper operation and maintenance in service, wherein it is thought necessary by the purchaser.

6. Rejection of Materials:-

In the event any of the equipments/material supplied by the manufacturer is found defective due to faulty design, bad workmanship, bad materials used or otherwise not in conformity with the requirements of the Specification, the Purchaser shall either reject the equipment/material or ask the supplier in writing to rectify or replace the defective equipment/material free of cost to the purchaser. The Supplier on receipt of such notification shall either rectify or replace the defective equipment/material free of cost to the purchaser within 15 days from the date of issue of such notification by the purchaser. If the supplier fails to do so, the Purchaser may:-

[a] At its option replace or rectify such defective equipments/materials and recover the extra costs so involved from the supplier plus fifteen percent and/or.

[b] Terminate the contract for balance work/supplies, with enforcement of penalty Clause as per contract for the un-delivered goods and with forfeiture of Performance Guarantee/ Composite Bank guarantee.

[c] Acquire the defective equipment/materials at reduced price, considered equitable under the circumstances.

7. Experience of Bidders:-

The bidders should furnish information regarding experience particularly on the following points:

[i] Name of the manufacturer:

[ii] Standing of the firm and experience in manufacture of equipment/material quoted:

[iii] Description of equipment/material similar to that quoted, supplied and installed during the last three years with the name(s) of the Organizations to whom supplies were made wherein, at least one (1) certificate shall be from a state/central P.S.U.

[iv] Details as to where installed etc.

[v] Testing facilities at manufacturer's works.

[vi] If the manufacturer is having collaboration with another firm [s], details regarding the same.

[vii] A list of purchase orders of identical material/equipments offered as per technical specification executed during the last two years along with user's certificate. User's certificate shall be legible and must indicate user's name, address, designation, place of use, and satisfactory performance of the equipment/materials for at least two years from the date of commissioning. Wherein at least one (1) certificate shall be from a State/Central or P.S.U. Bids will not be considered if the past manufacturing experience is found to be un-satisfactory or is of less than 3 (three) years on the date of opening of the bid and bids not accompanying user's certificate will be rejected.

8. Language and measures:-

All documents pertaining to the contract including specifications, schedule, notices, correspondence, operating and maintenance instructions, drawings or any other writing shall be written in English language. The metric system of measurement shall be used exclusively in this contract.

9. Deviation from specification:-

It is in the interest of the Bidders to study the specification, specified in the tender schedule thoroughly before tendering so that, if any deviations are made by the Bidders,(both commercial and Technical), the same are prominently brought out on a separate sheet under heading "Deviations Commercial" and "Deviations Technical".

A list of deviations shall be enclosed with the tender. Unless deviations in scope, technical and commercial stipulations are specifically mentioned in the list of deviations, it shall be presumed that the Bidders has accepted all the conditions, stipulated in the tender specification, notwithstanding any exemptions mentioned therein.

10. Right to reject/accept any tender:-

The purchaser reserves the right either to reject or to accept any or all tenders if the situation so warrants in the interest of the purchaser. Orders may also be split up between different Bidders on individual merits of the Bidders. The purchaser has exclusive right to alter the quantities of materials/ equipment at the time of placing final purchase order. After placing of the order, the purchaser may defer the delivery of the materials. It may be clearly understood by the Bidders that the purchaser need not assign any reason for any of the above action [s]

11. Supplier to inform himself fully:-

The supplier shall examine the instructions to Bidders, general conditions of contract, specification and the schedules of quantity and delivery to satisfy him as to all terms and conditions and circumstances affecting the contract price. He shall quote price [s] according to his own views on these matters and understand that no additional allowances except as otherwise provided there in will be admissible. The purchaser shall not be responsible for any misunderstanding or incorrect information, obtained by the supplier other than the information given to the supplier in writing by the purchaser.

12. Patent rights Etc.:-

The supplier shall indemnify the Purchaser against all claims, actions, suits and proceedings for the infringement of any patent design or copy right protected either in the country of origin or in India by the use of any equipment supplied by the manufacturer. Such indemnity shall also cover any use of the equipment, other than for the purpose indicated by or reasonably to be inferred from the specification.

13. Delivery:-

[a] Time being the essence of the contract; the equipment shall be supplied within the delivery period, specified in the contract. The Purchaser, however, reserves the right to reschedule the delivery and change the destination if required. The delivery period shall be reckoned from the date of placing the Letter of Intent/Purchase order, as may be specified in LOI/Purchase order.

[b] The desired delivery period shall be as indicated at Appendix-II (Quantity & Delivery Schedule) of Section-IV (Technical Specification).

14. Dispatch instructions:-

[I] The equipment/ materials should be securely packed and dispatched directly to the specified site at the supplier's risk by Road Transport only.

[II] Loading & unloading of Ordered Materials:-

It will be the sole responsibility of the supplier for loading and unloading of materials both at the factory site and at the destination site/store.

The Purchaser shall have no responsibility on this account.

15. Supplier's Default Liability:-

[i] The Purchaser may, upon written notice of default to the supplier, terminate the contract in circumstances detailed hereunder.

[a] If in the judgment of the Purchaser, the supplier fails to make delivery of equipment/material within the time specified in the contract or within the period for which if extension has been granted by the Purchaser in writing in response to written request of the supplier.

[b] If in the judgment of the Purchaser, the supplier fails to comply with any of the provisions of this contract.

[ii] In the event, Purchaser terminates the contract in whole or in part as provided in Clause-15 (I) of this section, the Purchaser reserves the right to purchase upon such terms and in such a manner as he may deem appropriate in relation to the equipment/material similar to that terminated and the supplier will be liable to the Purchaser for any additional costs for such similar equipment/material and/or for penalty for delay as defined in clause-22 of this section until such reasonable time as may be required for the final supply of equipment.

[iii] In the event the Purchaser does not terminate the contract as provided in clause 15(I) of this Section, supplier shall be liable to the Purchaser for penalty for delay as set out in Clause-22 of this section until the equipment is accepted. This shall be based only on written request of the supplier and written willingness of the Purchaser.

16. Force Majeure:-

The supplier shall not be liable for any penalty for delay or for failure to perform the contract for reasons of force majeure such as acts of god, acts of the public enemy, acts of Govt., Fires, floods, epidemics, Quarantine restrictions, strikes, Freight Embargo and provided that the supplier shall within Ten (10) days from the beginning of delay on such account notify the purchaser in writing of the cause of delay. The purchaser shall verify the facts and grant such extension, if facts justify.

17. Extension of time:-

If the delivery of equipment/material is delayed due to reasons beyond the control of the supplier, the supplier shall without delay give notice to the purchaser in writing of his claim for an extension of time. The purchaser on receipt of such notice may or may not agree to extend the contract delivery date as may be reasonable but without prejudice to other terms and conditions of the contract.

18. GUARANTEE PERIOD:-

[i] The stores covered by this specification should be guaranteed for satisfactory operation and against defects in design, materials and workmanship for a period of at least 18 [eighteen] months from the last date of delivery or 12 [twelve] months from the date of commissioning whichever is earlier. The above guarantee certificate shall be furnished in triplicate to the purchaser for his approval. Any defect noticed during this period should be rectified by the supplier free of cost to the purchaser provided such defects are due to faulty design, bad workmanship or bad materials used, within one month upon written notice from the purchaser failing which provision of **clause 22 (ii)** shall apply.

[ii] Equipment/material failed or found defective during the guarantee period shall have to be guaranteed after repair/replacement for a further period of 12 months from the date of commissioning or 18 months from the date of receipt at the store/site after such repair/replacement whichever is earlier. The Bank Guarantee is to be extended accordingly. Date of delivery as used in this clause shall mean the date on which the materials are received in OPTCL'S stores/site in full & good condition which are released for Despatch by the purchaser after due inspection.

19. B.G. towards security deposit, 100% payment and performance guarantee:-

[i] For manufacturers situated Inside & outside the state of Odisha.

A Composite Bank Guarantee as per the Proforma enclosed at Annexure-VII of the specification for 10% [ten percent] of the total FORD cost of the purchase order, shall be furnished from any nationalized/scheduled bank having a place of business at Bhubaneswar, to the office of Sr. General Manager [Central Procurement Cell] OPTCL within 15 days from the date of issue of the purchase order. In case of successful bidder who is a local Micro and Small Enterprise (MSEs) (**In the state of Odisha**) registered with respective DICs, Khadi, Village, Cottage & Handicrafts Industries, OSIC and NSIC 5% (five percent)), shall be furnished from any nationalized/scheduled bank having a place of business at Bhubaneswar, to the office of Sr. General Manager [Central Procurement Cell] OPTCL within 15 days from the date of issue of the purchase order,. The BG shall be executed on non-judicial stamp paper worth of Rs.29.00 [Rupees twenty nine] only or as per the prevalent rules, valid for a period of 20 months from the last date of stipulated delivery period, for scrutiny and acceptance, failing which the supply order will be liable for cancellation without any further written notices. The BG should be accompanied by a confirmation letter from the concerned bank and should have provision for encashment at Bhubaneswar, before the Bank Guarantee is accepted and all concerned intimated. The B.G should be revalidated as and when intimated to you to cover the entire guarantee period.

[ii] No interest is payable on any kind of Bank Guarantee.

[iii] In case of non-fulfillment of contractual obligation, as required in the detailed purchase order/Specification, the composite Bank guarantee shall be forfeited.

[iv] B.G is to be furnished on the total quantity for both PHASE-I & PHASE-II delivery.

20. Import License:-

In case imported materials are offered, no assistance will be given for release of Foreign Exchange. The firm should arrange to import materials from their own quota. Equipment of indigenous origin will be preferred.

21. (A) Terms of Payment.

(i) 100% value of each consignment with 100% Excise duty, Entry Tax, if any, and sales tax in full as applicable along with freight & Insurance charges will be paid on receipt of materials in good condition at stores/desired site and verification thereof, subject to furnishing and approval of Composite Bank Guarantee at the rate of 10% (Ten percent) of the cost of supplied materials, as stipulated under clause-19 of this specification & on prior approval of guarantee certificate & Test certificate by the Purchaser.

Any imposition of new tax or revision of tax shall be paid/ reimbursed at the time of dispatch, scheduled or actual whichever is lower (i.e. if delivery is within schedule period, tax variation is applicable, and if delivery is made beyond schedule date, any additional financial implication due to statutory variation in tax shall be to bidder's account).

(ii) Payment of Freight & Insurance charges and Entry Tax:-

Freight & Insurance Charges & Entry Tax if any, incorporated in the Purchase contract shall be paid after receipt of materials at stores/desired site in good condition and on production of authenticated documentary evidence, otherwise no Freight, Insurance charges & entry taxes shall be payable.

[B] The supplier shall furnish Composite Bank Guarantee of appropriate amount to OPTCL covering 10% of F.O.R. Destination cost of the purchase order well in advance (within 15 days from the date of issue of the purchase order) before despatch of materials.

22. Penalty for Delay in Completion of Contract:-

(I) If the Supplier fails to deliver the materials/equipments within the delivery schedule, specified in the contract including delivery time extension, if any, granted thereto, the Purchaser shall recover from the Supplier, penalty for a sum of half percent (0.5 percent) of the Ex-works price of the un-delivered equipment for each calendar week of delay or part thereof. For this purpose, the date of receipted challan shall be reckoned as the date of delivery. The total amount of penalty shall not exceed five percent (5%) of the ex-works price of the unit or units so delayed. Equipment will be deemed to have been delivered only when all its components and accessories as per technical Specification are also delivered. If certain components & accessories are not delivered in time, the equipment will be considered delayed until such time as the missing parts are delivered.

(II) If the Supplier fails to rectify /replace the equipment/material within 30 days from the date of intimation of the defect, so noticed by the purchaser within the guarantee period then the penalty for sum of one half of the one percent (0.5%) of the total Purchase order amount for each calendar week of delay shall be recovered by the purchaser within the guarantee period. For this purpose, penalty date will start from the 30th Day from the date of issue of letter on defectiveness of equipment/material, so supplied, by the purchaser. The total amount of penalty in this case shall not exceed 10% (TEN PERCENT) of the purchase order amount. The purchase order amount shall mean ex-works price + freight & insurance and all taxes & duties. If the defects so intimated will not be rectified by the supplier within the guarantee period, then whole of the B.G. will be forfeited by the purchaser, without any intimation to the Supplier.

23. Insurance:-

The Supplier shall undertake insurance of stores covered by this Specification unless otherwise stated. The responsibility of delivery of the stores at destination in good condition rests with the Supplier. Any claim with the Insurance Company or transport agency arising due to loss or damage in transit has to be settled by the supplier. The Supplier shall undertake free replacement of materials damaged or lost, which will be reported by the consignee within 30 days of receipt of the materials at destination without waiting for the settlement of their claims with the carriers and underwriters.

24. Payment Due from the Supplier: All costs and damages, for which the supplier is liable to the purchaser, will be deducted by the purchaser from any money, due to the supplier, under any of the contract (s), executed with OPTCL.

25. Sales Tax clearance certificate and Balance sheet and profit & Loss Account:-

(i) Sales Tax clearance certificate for the previous year shall be enclosed with the tender.

(ii) Audited Balance Sheet and Profit & Loss Account of the bidder for the previous three years shall be enclosed to assess the financial soundness of the bidder(s).

26. Certificate of Exemption from Excise Duty/Sales tax:-

Offers with exemption from Excise duty including sales tax shall be accompanied with authenticated proof of such exemption. Authenticated proof for this clause shall mean attested Photostat copy of exemption certificate. Any claim towards Excise duty/ Sales Tax shall be paid on actual basis subject to production of authenticated documentary evidence.

27. Supplier's Responsibility:-

Notwithstanding anything mentioned in the Specification or subsequent approval or acceptance by the Purchaser, the ultimate responsibility for design, manufacture, materials used and satisfactory performance shall rest with the Bidders. The Supplier(s) shall be responsible for any discrepancy noticed in the documents, submitted by them along with the bid(s).

28. Validity:-

Prices and conditions contained in the offer should be kept valid for a minimum period of 180 days from the date of opening of the tender, failing which the tender shall be rejected.

29. EVALUATION:-

- (I) Evaluation of bids will be on the basis of the FOR DESTINATION PRICE (By Road Transport) including Excise Duty, sales Tax & other levies as may be applicable. The FORD PRICE shall consist of the following components
- a) Ex-works price.
 - b) Packing & Forwarding charges.
 - c) Freight.
 - d) Insurance.
 - e) Excise Duty.
 - f) Sales Tax.
 - g) Other levies.
 - h) Mandatory spares, if any for maintenance of equipment. (At the discretion of the purchaser)
 - i) Test charges, if any.
 - j) Supervision of erection, testing and commissioning charges, if any.
 - k) Any other items, as deemed proper for evaluation by the purchaser.
 - l) Loading factors will be taken in to account during evaluation if the prices of some of the items, not quoted.

(II) Weightage shall be given to the Following factors in the Evaluation & Comparison of Bids:-

In comparing bids and in making awards, the Purchaser will consider other factors such as compliance with Specification, minimum qualification criteria as per clause-30, outright rejection of tenders clause-34 of this tender, relative quality, adaptability of Supplies or services, experience, financial soundness, record of integrity in dealings, performance of materials/equipments earlier supplied, ability to furnish repairs and maintenance services, the time of delivery, capability to perform including available facilities such as adequate shops, plants, equipment and technical Organization.

(III) The local MSE (In the state of Odisha) bidders shall be required to furnish their willingness to match their bid price with that of the lowest evaluated bidder without any price preference and in case they agree, they shall be eligible to get up to 30% of the tendered quantity to be distributed suitably among the willing MSE bidders failing which the said 30% of the tendered quantity be awarded to the lowest evaluated bidder.

30. Minimum Qualification Criteria of Bidders:-

All the prospective bidders are requested to note that their bids for tendered equipment can only be considered for evaluation if:

- i) The bidder should have manufacture and supply experience of above rated or higher capacity equipments for a minimum period of 3 (three) years as on the date of opening of the tender
- ii) At least 50% of the tendered quantity of above rated or higher capacity equipment should have been supplied within the above-stipulated period.
- iii) The above rated or higher capacity equipment should have at least 3 (three) years successful performance from the date of commissioning. At least one of the performance certificates shall be submitted from Govt. of India/State Govt. (s) or their undertakings.
- iv) The bidder should have conducted type tests on the tendered equipments in Government approved laboratory within five years from the date of opening of the tender.

31. Jurisdiction of the High Court of Odisha:-

Suits, if any, arising out of this contract shall be filed by either Party in a court of Law to which the jurisdiction of High court of Odisha extends.

32. Correspondences:-

- i) Any notice to the supplier under the terms of the contract shall be served by Registered Post or by hand at the Supplier's Principal Place of Business.
- ii) Any notice to the Purchaser shall be served at the Purchaser's Principal Office in the same manner.

33. Official Address of the Parties to the Contract:-

The address of the parties to the contract shall be specified:-

[i] Purchaser: Senior General Manager (Procurement)(CPC) OPTCL
Bhubaneswar-751022 (Odisha)
Telephone No. 0674 -2541801
FAX No. 0674 -2542964

[iii] Supplier: Address
Telephone No
Fax No.

34. Outright Rejection of Tenders:-

Tenders shall be outrightly rejected if the followings are not complied with.

- [i]** The Bidders shall submit the bid in electronic mode only and shall submit the cost of tender document and Tender processing fee on or before the last date & time of submission of tender. In case of local Micro & Small Enterprises (MSEs) **(In the state of Odisha)** registered with respective DICs, Khadi, Village, Cottage & Handicraft Industries, OSIC and NSIC participating in the tender have to submit notarized hard copy of valid registration as local MSE as above on or before the last date & time of submission of tender.
- [ii]** The Bidders shall submit the bid in electronic mode only
- [iii]** The Tender shall not be submitted telegraphically or by FAX.
- [iv]** The prescribed EMD shall be submitted on or before the date and time of submission of technical bid.
- [v]** The Tender shall be kept valid for a minimum period of 180 days from the date of opening of tender.
- [vi]** The Tender shall be submitted in two parts as specified.
- [vii]** The Tenders shall be accompanied by a list of major supplies affected prior to the date of submission of tender. Data of at least 3 (three) years shall be furnished.
- [viii]** The Bidders shall upload the scanned copy of latest type test certificates (for the tests, carried out on the tendered equipments, being offered). Such type tests should have been conducted within last five years from the date of opening of this tender in a Government approved laboratory/CPRI in presence of any Government Organization's representative(s).
- [ix]** The schedule of prices should be filled up fully to indicate the break-up of the prices including taxes and duties. Incomplete submission of this schedule will make the tender liable for rejection. Vide Clause-4(ii) of Part-II.
- [x]** The Bidders should quote 'FIRM' price only and the price should be kept valid for a minimum period of 180 days from the date of opening of the tender.

- [xi] The Bidders shall upload the scanned copy legibly written user's certificate to prove the satisfactory operation of the offered equipments/materials for a minimum period of 2 (two) years from the date of commissioning/use as per the tender specification. User's certificate shall include the detailed address of the user with Equipment/Material, Name and type as per this specification, number of years of satisfactory use/operation & date of issue of this user's certificate with official seal written in English only & clearly visible must be furnished. At least one of the user's certificates shall be from state or Central Govt. or their Undertakings.
- [xii] Guaranteed Technical particulars & Abstract of terms and Conditions should be filled in completely.
- [xiii] The bidder should not have any pending litigation or arbitration with OPTCL with regard to any project or related activity. The bidder should certify/declare the same in unequivocal terms by way of an **affidavit** duly sworn before a **Magistrate**. Bid furnished by the bidder shall **not be eligible** for consideration, if it is not accompanied by the affidavit. Further the bid/LOA/LOI shall be liable for **outright rejection/cancellation** at any stage if any information contrary to the affidavit/declaration is **detected**.

35. Documents to be treated as confidential:-

The supplier shall treat the details of the specification and other tender documents as private and confidential and these shall not be reproduced without written authorization from the Purchaser.

36. Scheme/Projects:-

The materials/equipment covered in this specification shall come under "O&M" works.

SECTION – III

LIST OF ANNEXURES

[I TO XIII]

The following schedules and proforma are annexed to this specification and contained in Section-III as referred to in the relevant clauses.

1	Declaration form	ANNEXURE-I
2	Abstract of terms and conditions to accompany Section-II of Part-I	ANNEXURE-II
3	Schedule of Quantity and Delivery	ANNEXURE-III
4	Abstract of price component [to accompany Part-II of this specification]	ANNEXURE-IV
5	Schedule of prices to accompany Part-II	ANNEXURE-V
6	Bank Guarantee form for earnest money deposit	ANNEXURE-VI
7	Composite Bank Guarantee form for security deposit, payment and performance	ANNEXURE-VII
8.	Chart showing particulars of E.M.D.	ANNEXURE – VIII
9.	Data on Experience.	ANNEXURE – IX
10.	Schedule of spare parts.	ANNEXURE-X
11.	Schedule of Installations.	ANNEXURE-XI
12.	Schedule of deviations.	ANNEXURE-XII
13	Litigation/Arbitration	ANNEXURE-XIII

ANNEXURE – I

DECLARATION FORM

To

The Sr. General Manager (CPC)
OPTCL Head Qrs. BBSR, 751022

Sub: - Tender Specification No-_____

Sir,

1. Having examined the above specification together with terms & conditions referred to therein * I/We the undersigned hereby offer to supply the materials/equipments covered therein complete in all respects as per the specification and General conditions, at the rates, entered in the attached contract schedule of prices in the Tender.

2. * I/We hereby undertake to have the materials/equipments delivered within the time specified in the Tender.

3. * I/We hereby guarantee the technical particulars given in the Tender supported with necessary reports from concerned authorities.

4. * I/We certify to have submitted the bid electronically by remitting *cash/money order/D.D./ remitting the cost of tender, herewith and this has been acknowledged by your letter/ money receipt No. _____ Dated,

5. In the event of Tender, being decided in *my/our favour, * I/We agree to furnish the Composite B.G. in the manner, acceptable to ORISSA POWER TRANSMISSION CORPORATION LTD., and for the sum as applicable to *me/us as per clause-19 of section-II of this specification within 15 days of issue of letter of intent/purchase order failing which *I/We clearly understand that the said letter of Intent/Purchase order will be liable to be withdrawn by the purchaser, and the EMD deposited by us shall be forfeited by OPTCL.

Signed this _____ day of _____ 2016

Yours faithfully

Signature of the Tenderer with seal of the company

[This form should be dully filled up by the tenderer and uploaded at the time of submission of tender.]

* (Strikeout whichever is not applicable)

ANNEXURE-II

(To be filled up by the tenderer as indicated in the excel sheet)

ABSTRACT OF GENERAL TERMS AND CONDITIONS OF CONTRACT [COMMERCIAL] TO ACCOMPANY PART-I

(To be filled up by the tenderer as indicated in the excel sheet)

ANNEXURE-III

SCHEDULE OF QUANTITY AND DELIVERY

TO ACCOMPANY PART-I

(To be filled up by the tenderer as indicated in the excel sheet)

ANNEXURE-IV

TO ACCOMPANY PART-I

(To be filled up by the tenderer as indicated in the excel sheet)

ANNEXURE-V

TO ACCOMPANY PART-II

(To be filled up by the tenderer as indicated in the excel sheet)

1. The tenderer should fill up the schedule properly and in full in excel file in e-tender mode. The tender will be rejected, if the schedule of price is submitted in incomplete form. No post tender correspondence will be entertained on break-up of prices. Also, the supplier should agree for delivery at sub-station site.
2. In case, where F&I components are not specifically indicated in this schedule, 5% of the ex-works price shall be taken towards F&I components for the purpose of comparison of price.
3. The Tenderer shall certify in the price bid that MODVAT benefit, if any, has been fully passed on to the purchaser while quoting the tender price.
4. Conditional offers will not be acceptable.
5. The bidder is to clearly indicate the period up to which the tax holidays are available to them.
6. Price bid in any other format will not be acceptable and the offer will be rejected
7. Test charges (Routine/type) if any, mandatory spares, if any, maintenance equipment charges, if any, as per Technical Specification, supervisory charges, if any, (in case of equipments by taking 30 Man days) shall be indicated separately, row-wise.
8. All the above charges will be taken into account, during bid price evaluation.

ANNEXURE-VI

PROFORMA FOR BANK GUARANTEE FORM FOR EARNEST MONEY DEPOSIT

Ref _____ Date _____ Bank Guarantee No: _____
1 In accordance with invitation to Bid No. _____ Dated _____ of ODISHA POWER TRANSMISSION CORPORATION LTD. [OPTCL][herein after referred to as the OPTCL for the purchase of _____ Messers _____ Address _____

_____ wish/wished to participate in the said tender and as a Bank Guarantee for the sum of Rs. _____ [Rupees _____]

Valid for a period of 240 days [Two hundred forty days] is required to be submitted by the Tenderer. We _____ the _____

_____ [Indicate the Name of the Bank]
[Hereinafter referred to as 'the Bank'] at the request of M/S _____

[Herein after referred to as supplier (s)] do hereby unequivocally and unconditionally guarantee and undertake to pay during the above said period, on written request by the Sr. General Manager [Procurement] ODISHA POWER TRANSMISSION CORPORATION LTD. _____

[Indicate designation of the purchaser]
an amount not exceeding Rs. _____ to the OPTCL, without any reservation. The guarantee would remain valid up to 4.00 PM of _____ [date] and if any further extension to this is required, the same will be extended on receiving instructions from the _____ on whose behalf this guarantee has been issued.

2. We the _____ do hereby, further undertake [Indicate the name of the bank] to pay the amounts due and payable under this guarantee without any demur, merely on a demand from the OPTCL stating that the amount claimed is due by way of loss or damage caused to or would be caused to or suffered by the OPTCL by reason of any breach by the said supplier [s] of any of the terms or conditions or failure to perform the said Bid . Any such demand made on the Bank shall be conclusive as regards the amount due and payable by the Bank under this guarantee. However, our liability under this guarantee shall be restricted to an amount not exceeding Rs. _____

3. We undertake to pay the OPTCL any money so demanded not withstanding any dispute or disputes so raised by the contractor [s] in any suit or proceeding instituted/pending before any Court or Tribunal relating thereto, our liability under this present being absolute and unequivocal. The payment so made by us under this bond shall be a valid discharge of our liability for payment there under and the supplier(s) shall have no claim against us for making such payment.

4. We, the _____ further agree that the guarantee [Indicate the Name of the Bank] herein contained shall remain in full force and effect during the aforesaid period of 240 days [two hundred forty days] and it shall continue to be so enforceable till all the dues of the OPTCL under or by virtue of the said Bid have been fully paid and its claims satisfied or discharged or till Managing Director, ODISHA POWER TRANSMISSION CORPORATION LTD. certifies that the terms

and conditions of the said Bid have been fully and properly carried out by the said Supplier [s] and accordingly discharges this guarantee. Unless a demand or claim under this guarantee is made on us in writing on or before the _____ we shall be discharged from all liability under this guarantee thereafter.

5. We, the _____ further agree with the OPTCL that

[Indicate the name of the Bank]

the OPTCL shall have the fullest liberty without our consent and without affecting in any manner our obligations hereunder to vary any of the terms and conditions of the said Bid or to extend time of performance by the said Supplier [s] from time to time or to postpone for any time or from time to time any of the powers exercisable by the OPTCL against the said supplier [s] and to forbear or enforce any of the terms and conditions relating to the said bid

and we shall not be relieved from our liability by reason of any such variation, postponement or extension being granted to the said Supplier [s] or for any forbearance act or omission on the part of the OPTCL or any indulgence by the OPTCL to the said Supplier[s] or by any such matter or thing whatsoever which under the law relating to sureties would, but for this provision, have effect of so relieving us.

6. This guarantee will not be discharged due to the change in the name, style and constitution of the Bank or the supplier [s].

7. We, _____ lastly undertake not to revoke this

[Indicate the name of the Bank]

Guarantee during its currency except with the previous consent of the OPTCL in writing.

8. We the _____ Bank further agree that this guarantee shall also be invocable at our place of business at -----Branch of Bhubaneswar (**indicate the name & code of the branch**) in the state of ODISHA.

Notwithstanding anything contained herein.

1) Our liability under this bank guarantee shall not exceed Rs.----- (Rupees-----).

2) The bank guarantee shall be valid up to dt.-----

3) We are liable to pay the guaranteed amount or any part thereof under this bank guarantee only & only if you serve upon us at -----branch at Bhubaneswar a written claim or demand on or before dt.-----.

Dated _____ Day of _____

For _____

[indicate the name & code of the branch]

Witness ((Signature, names & address)

1.

2.

ANNEXURE-VII

PROFORMA FOR COMPOSITE BANK GUARANTEE FOR SECURITY DEPOSIT PAYMENT AND PERFORMANCE

This Guarantee Bond is executed this _____ day of _____ 20-- by us the _____ Bank at _____ P.O. _____ P.S. _____ District _____ State _____

1. WHEREAS the ODISHA POWER TRANSMISSION CORPORATION LTD., a body corporate constituted under the Electricity Act, 2003 [hereinafter called "the OPTCL" which shall include its successors and assigns has placed orders No. _____ Date _____ [hereinafter called "The Agreement"] on M/s. _____ [hereinafter called "The Supplier"] which shall include its successors & assigns for supply of materials.

AND WHERE AS the supplier has agreed to supply materials to the OPTCL in terms of the said agreement AND

WHEREAS the OPTCL has agreed [1] to exempt the supplier from making payment of Security [2] to release 100% payment of the cost of materials as per the said agreement and [3] to exempt from performance guarantee on furnishing by the Supplier to the OPTCL, a Composite bank Guarantee of the value of 10 % [ten percent] of the contract price of the said agreement.

NOW THEREFORE, in consideration of the OPTCL having agreed [1] to exempt the Supplier from making payment of Security [2] releasing 100% payment to the Supplier and [3] to exempt from furnishing performance guarantee in terms of the said agreement as aforesaid, we, the _____ [Bank][hereinafter referred to as 'the Bank'] do hereby undertake to pay to the OPTCL an amount not exceeding Rs. _____ [Rupees _____] against any loss or damage caused to or suffered by or would be caused to or suffered by the OPTCL by reason of any breach by the said Supplier [s] of any of the terms or conditions contained, in the said agreement.

2. We the (_____ Bank) do hereby undertake to pay the amounts due and payable under this guarantee without any demur, merely on demand from the OPTCL stating that the amount claimed is due by way of loss or damage caused to or suffered by the OPTCL by reason of any breach by the said Supplier [s] of any of the terms or conditions, contained in the said agreement or by reason of the supplier's failure to perform the said agreement. Any such demand made on the bank shall be conclusive as regards the amount due and payable by the Bank under this guarantee. However, our liability under this guarantee shall be restricted to an amount not exceeding Rs. _____ [Rupees _____]
3. We the _____ Bank} also undertake to pay to the OPTCL any money so demanded notwithstanding any dispute or disputes raised by the supplier [s] in any suit or proceeding instituted/pending before any Court or Tribunal relating thereto our liability under this present being absolute and unequivocal.

The payment so made by us under this bond shall be a valid discharge of our liability for payment there under and the Supplier [s] shall have no claim against us for making such payment.

- 4 We, (_____ Bank) further agree that the guarantee herein contained shall remain in full force and effect during the period that would be taken for the performance of the said agreement and that it shall continue to do so enforceable till all the dues of the OPTCL under or by virtue of the said agreement have been fully paid and its claims satisfied or discharged or till Managing Director, ODISHA POWER TRANSMISSION CORPORATION LTD. certifies that the terms and conditions of the said agreement have been fully and properly carried out by the said Supplier [s] and accordingly discharges this Guarantee.

Unless a demand or claim under this guarantee is made on us in writing on or before the [Date _____], we shall be discharged from all liability under this guarantee thereafter.

5. We,(_____ Bank) further agree that the OPTCL shall have the fullest liberty without our consent and without affecting in any manner our obligations hereunder to vary any of the terms and conditions of the said agreement or to extend time of performance by the said Supplier [s] and we shall not be relieved from our liability by reason of any such variations or extension being granted to the said supplier [s] or for any forbearance, act or omission on the part of the OPTCL or any indulgence by the OPTCL to the said Supplier [s] or by any such matter or thing whatsoever which under the law relating to sureties would but these provisions have effect of so relieving us.

6. This guarantee will not be discharged due to the change in the name, style and constitution of the Bank and supplier [s].

7. We, [_____ Bank] lastly undertake not to revoke this guarantee during its currency except with the previous consent of the OPTCL in writing.

8. We the _____ Bank further agree that this guarantee shall also be invocable at our place of business at ----- Branch of Bhubaneswar (**indicate the name & code of the branch**) in the state of ODISHA.

Notwithstanding anything contained herein.

- 1) Our liability under this bank guarantee shall not exceed Rs.----- (Rupees-----).
- 2) The bank guarantee shall be valid up to dt.-----
- 3) We are liable to pay the guaranteed amount or any part thereof under this bank guarantee only & only if you serve upon us at -----branch at Bhubaneswar (Indicate the name of branch) a written claim or demand on or before dt.-----.

Dated _____ Day of _____

For _____
[indicate the name & code of the branch]

Witness ((Signature, names & address)

1.

2.

ANNEXURE-VIII

CHART SHOWING PARTICULARS OF EARNEST MONEY DEPOSIT FURNISHABLE BY TENDERERS

1.	Central and State Government Undertakings	Exempted
2.	All other inside & outside state units.	The amount of EMD as specified in the specification /Tender Notice in shape of bank guarantee /DD.

NB: - REFUND OF E.M.D.

- [a] In case of unsuccessful tenderers, the EMD will be refunded immediately after the tender is decided. In case of successful tenderer, this will be refunded only after furnishing of Composite Bank Guarantee referred to in clause No.19 of Section-II of this specification. Suits, if any, arising out of EMD shall be filed in a court of law to which the jurisdiction of High Court of ODISHA extends.
- [b] Earnest Money will be forfeited if the tenderer fails to accept the letter of intent/purchase order, issued in his favour or revises the bid price[s] within the validity period of Bid.

ANNEXURE-IX

DATA ON EXPERIENCE

- [a] Name of the manufacturer.
- [b] Standing of the firm as manufacturer of equipment quoted.
- [c] Description of equipment similar to that quoted [supplied and installed during the last two years with the name of the organizations to whom supply was made].
- [d] Details as to where installed etc.
- [e] Testing facilities at manufacturer's works.
- [f] If the manufacturer is having collaboration with another firm, details regarding the same and present status.
- [g] A list of purchase orders, executed during last three years.
- [h] A list of similar equipments of specified rating, voltage class, short circuit rating, Designed, manufactured, tested and commissioned which are in successful operation for at least two years from the date of commissioning with legible user's certificate. User's full complete postal address/fax/phone must be indicated. (Refer clause No.7 of the Part-I, Section-II of the specification).

Place:

Date:

Signature of tenderer
Name, Designation, Seal

ANNEXURE-X

SCHEDULE OF SPARE PARTS FOR FIVE YEARS OF NORMAL OPERATION & MAINTENANCE

SL. No	Particulars	Quantity	Unit delivery rate	Total price

Place:

Date:

Signature of Tenderer
Name, Designation, Seal

ANNEXURE-XI

SCHEDULE OF INSTALLATIONS

Rated MVA	Rated Voltage	Place of installation and complete postal address	Year of commissioning

Place: -

Date

Signature of Tenderer:
Name, Designation, Seal

ANNEXURE-XII

DEVIATION SCHEDULE.

Tenderer shall enter below particulars of his alternative proposal for deviation from the specification, if any.

TO ACCOMPANY PART-I

(To be filled up by the tenderer as indicated in the excel sheet)

A) Technical deviations

TO ACCOMPANY PART-I

(To be filled up by the tenderer as indicated in the excel sheet)

(B) Commercial deviations.

TO ACCOMPANY PART-I

(To be filled up by the tenderer as indicated in the excel sheet)

ANNEXURE – XIII

LITIGATION HISTORY

Name of the Bidder:

Bidder should provide information on any history of litigation or arbitration resulting from contracts executed in the last five years or currently under execution.

Year.	Award for or against bidder	Name of client, cause of litigation and matter in dispute	Disputed amount (current value in Rs.)

Place: -

Date

Signature of Tenderer:

Name, Designation, Seal

PART – II

PRICE BID

1. PRICE:

- (i) Bidders are required to quote their price(s) for goods offered indicating they are 'FIRM'
- (ii) The prices quoted shall be FOR Destination only at the consignee's site/store inclusive of packing, forwarding, Freight & Insurance. In addition, the break-up of FOR Destination price shall be given as per schedule of Prices in Annexure-V of Section – III. The Bidders has to certify in the price bid that MODVAT benefit if any, has been fully passed on to the Purchaser, while quoting the tender prices.

2. INSURANCE:

Insurance of materials/equipments, covered by the Specification should normally be done by the Suppliers with their own Insurance Company unless otherwise stated. The responsibility of delivery of the materials/equipments at destination stores/site in good condition rests with the Supplier. Any claim with the Insurance Company or Transport agency arising due to loss or damage in transit has to be settled by the Supplier. The Supplier shall undertake free replacement of equipments/materials damaged or lost which will be reported by the Consignee within 30 days of receipt of the equipments/materials at Destination without awaiting for the settlement of their claims with the carriers and underwriters.

3. CERTIFICATE FOR EXEMPTION FROM EXCISE DUTY/SALES TAX:

Offers with exemption from excise Duty/ Sales tax shall be accompanied with authenticated proof of such exemption. Authenticated proof for this clause shall mean Photostat copy of exemption certificates, attested by Gazetted Officers of State or Central Government.

4. PROPER FILLING UP OF THE PRICE SCHEDULE:

- (i) In case where Freight & Insurance charges are not furnished, 5% of the Ex-works price shall be considered as the freight & Insurance charges.
- (ii) The Bidders should fill up the price schedule (Annexure-V of Section-III) properly and in full. The tender may be rejected if the schedule of price is submitted in incomplete form as per clause-34 (ix) of Section-II of the Specification.

5. NATURE OF PRICE INDICATED IN SPECIFICATION SHALL BE FINAL.

The nature of price indicated in the Clause-13, Section – I of PART –I of the Specification shall be final and binding.

SECTION –IV

TECHNICAL SPECIFICATION FOR 420, KV SF₆ CIRCUIT BREAKER

1.0 SCOPE:

1.1 This specification provides for the design, manufacture, inspection and testing before dispatch, packing and delivery F.O.R. (destination) By Road transport only and supervision of erection, testing and commissioning, of outdoor SF₆ circuit breakers along with structures, all the accessories and auxiliary equipment and mandatory spares, described herein, required for their satisfactory operation in various substations of the state.

1.2 The circuit breaker shall conform in all respects to high standards of engineering, design, workmanship and latest revisions of relevant standards at the time of offer and purchaser shall have the power to reject any work or material, which, in his judgement, is not in full accordance therewith.

STANDARDS

1.3 Except as modified in this specification, the circuit breakers shall conform to the latest revisions with amendments thereof, of following standards.

SL. NO.	STANDARD	TITLE
1.	IEC-62271-100	High Voltage Alternating Current Circuit-Breaker
2.	IS-12729:2004/ IEC-60694	Common Specification for High Voltage Control gear & Switchgear standard
3.	IS-14658/IEC-1633	H.V Alternating Current Ckt Breaker-Guide for Short Ckt & Switching Test Procedures for metal enclosed & dead tank Circuit Breaker
4.	IS-14674:1999/ IEC-1166:1993	H.V Alternating Current Ckt Breaker-Guide for Seismic qualification of HV A.C Circuit Breaker
5.	IEC-56 / IS-13118	Specification for alternating current circuit breakers
6.	IS-325	Specification for three phase induction motors
7.	IS-375	Marking and arrangement for switchgear bus-bar, main connections and auxiliary wirings.
9.	IS-802 (Part-1)	Code of practice for use of structural steel in overhead trans. Line towers.
10.	IS-2099	High voltage porcelain bushings.
11.	IS-2147	Degree of protection provided for enclosures for low voltage switchgear and control gear.
12.	IS-2629	Recommended practice for hot dip galvanizing of iron and steel.
13.	IS-4379	Identification of the contents of Industrial Gas Cylinders.
14.	IS-7311	Seamless high carbon steel cylinders for permanent and high pressure liquefied gases.

1.4 Equipment meeting with the requirements of any other authoritative standards, which ensures equal or better quality than the standard mentioned above shall also be acceptable. If the equipment offered by the Bidder conforms to other standards, salient points of difference between the standards adopted and the specific standards shall be clearly brought out in relevant schedule. Two copies of such standards with authentic English Translations shall be furnished along with the offer.

1.5 The standards mentioned above are available from:

Reference/ Abbreviation	Name and address from which the standards are available
IS	Bureau of Indian Standards, Nanak Bhawan, 9-Bahadur Shah Zafar Marg, New Delhi-110 001INDIA
IEC	International Electrotechnical Commission, Bureau Central De la Commission, Electro Technique International 1,Rue De Verembe, Geneva, Switzerland

2.0 AUXILIARY POWER SUPPLY

Auxiliary electrical equipment shall be suitable for operation on the following supply system.

(a)	Power Devices like drive Motors of rating 1 KW and above.	415 V, 3 phase 4 wire 50Hz, neutral grounded AC supply.
(b)	Lighting, space heaters and Fractional KW motors.	240 V, single phase, 50 Hz neutral grounded AC supply.
(c)	Alarm, control and Protective devices.	220 V DC, 2 wire

Each of the foregoing supplies shall be made available by the Purchaser at the terminal point for each circuit breaker for operation of accessories and auxiliary equipment. Supplier's scope include supply of interconnecting cables, terminal boxes etc. The above supply voltage may vary as below and all devices shall be suitable for continuous operation over entire range of voltages.

- i) AC supply: voltage $\pm 10\%$ frequency $\pm 5\%$
- i) DC supply : - 15% to + 10%

3.0 PRINCIPAL PARAMETERS

The breakers shall conform to the specific technical requirements specified hereunder:

Sl. No.	Item	Requirements
1.	Rated voltage (KV rms) frequency (Hz)	420 KV, 50HZ
2.	Continuous current rating (A) rms	3150
3.	Type	Outdoor SF ₆
4.	Mounting	Hot dip galvanized lattice steel support structure to be supplied by the Bidder
5.	Number of Poles	3
6.	Type of Operation	Individually Operated single poles.

7.	Phase to phase spacing in the switchyard i.e. inter pole spacing for breaker (mm)		7000
8.	Required ground clearance from the lowest live terminal (mm):		
	i.	If both the terminals are not in the same horizontal plane	7000
	ii.	If both the terminals are in the same horizontal plane	7000
9.	Height of concrete plinth (to be provided by the Owner) mm.		300
10.	Minimum height of the lowest part of the support insulator from ground level (mm)		2550/3500
11.	Operating Mechanism		FOR 420 KV /SPRING-SPRING/
12.	Auto reclosing duty		Single Phase
13.	Rated operating duty cycle		0-0.3 sec-co-3 min-co
14.	First pole to clear factor		1.3(As per IEC-62271-100)
15.	Type of tripping		Trip free
16.	Max. closing time(ms)		60
17.	Max. BREAK TIME (ms)		50/40
18.	1.2/50 microsecond impulse withstand voltage: (dry)		
	i.	To earth (kvp)	1550
	ii.	Across the open contacts with impulse on one terminal and power frequency voltage on opposite terminal (kvp/kv rms)	1550
19.	1 minute power frequency withstand voltage (kv-rms) (wet)		610
20.	Max. radio interference voltage (micro volts) at 1.1 times maximum phase voltage		1000
21.	Min. corona extinction voltage (kv rms)		320
22.	Rated breaking current capacity:		
	i.	Line charging at rated voltage at 90 deg. Leading power factor (A) rms	600
	ii.	Small inductive current (A) rms	-----0.5 to 10----- ----without switching o/v exceeding 2.3 p.u.
	iii.	Short circuit current	
		a) AC component (kA)	50
		b) % DC component	40%/as per IEC62271-100
23.	Rated short circuit making current capacity (kA)		125
24.	Permissible limit of temperature rise		As per Clause 5.29
25.	Max. acceptable difference in the instant of closing/opening of contacts		
	i)	Within a pole (ms)	2.5
	ii)	Between poles (ms)	3.3 for opening & 5 for closing
26.	Min. creepage distance of support insulator(mm)		10500
27.	Short time current carrying capability for one second (kA)		50
28.	Rating of auxiliary contacts		----10A at 220 V D.C.----
29.	Breaking capacity of auxiliary contact		2 A DC with the circuit time constant not less than 20 ms
30.	Noise level at base and up to 50 meters		----140 dB (max.)-----
31.	Seismic acceleration		-----0.3 g -----

Note:-Purchaser may accept the phase to phase, or phase to earth spacing of the breakers & structure heights basing on the firm's type test reports or he may ask the firm to manufacture the breakers as per the dimensions indicated in this specification.

4.0 GENERAL TECHNICAL REQUIREMENTS

4.1 Circuit breaker offered shall be sulphur hexafluoride (SF₆) type only.

4.2 Any part of the breaker, especially the removable ones, shall be freely interchangeable without the necessity of any modification at site.

4.3 Circuit breaker shall comprise of three identical single pole units. If the circuit breaker not meant for single pole re-closure, these units shall be linked together electrically. Complete circuit breaker with all the necessary items for successful operation shall be supplied, including but not limited to the following:

4.3.1 Breaker assemblies with bases, support structure for circuit breaker as well as for control cabinet, Ladder, central control cabinet and foundation bolts for main structure as well as control cabinet and central control cabinet (except concrete foundations), terminals and operating mechanisms.

4.3.2 Compressed SF₆ gas, spring operated systems complete including piping, fittings, valves and controls and etc.

4.3.3 One central control cabinet for each breaker and one control box for each pole with all the required electrical devices mounted therein and the necessary terminal blocks for termination of inter pole wiring. The necessary inter pole cabling at site shall be done by the Purchaser based on the schematic, wiring diagram and termination schedule to be supplied by the Supplier.

4.3.4 Instruments, pressure gauges and other devices like gas density monitor, temp. monitor & etc. for SF₆ gas pressure supervision.

4.3.5 All necessary parts to provide a complete and operable circuit breaker installation such as main equipment, terminal, control parts, connectors and other devices, whether specifically called for herein or not.

4.4 The circuit breaker shall be designed for high speed single and three poles reclosing with and operating sequence and timing as specified in clause 4.0 "Principal Parameters".

4.5 The support structure of circuit breaker as well as that of control cabinet shall be hot dip galvanized. The minimum weight of zinc coating shall be 610 gm. / sq. m and minimum thickness of coating shall be 86 microns for all items thicker than 5 mm.

4.6 Circuit breaker shall be suitable for hot line washing.

4.7 All breakers shall be supplied with terminal connectors. The exact requirement of terminal connectors would be intimated to the supplier during the course of detailed engineering (during drawing approval).

4.8 Terminal pads shall have silver plating of at least 50 microns thickness.

4.9 CONTACTS

4.9.1 All making and breaking contacts shall be sealed free from atmospheric effects. Contacts shall be designed to have adequate thermal and current carrying capacity for the duty specified and to have a life expectancy so that frequent replacements due to excessive burning will not be necessary. Provision shall be made for rapid dissipation of heat generated by the arc on opening.

4.9.2 Main contacts shall be first to open and the last to close so that there will be little contact burning and wear. If arcing contacts are used they shall be first to close and the last to open. Tips of arcing contacts and main contacts shall be silver plated or made of superior material like graphite.

4.9.3 Any device provided for voltage grading to damp oscillations or to prevent restrike prior to the complete interruption of the circuit or to limit over voltages on closing shall have a life expectancy comparable to that of the breaker as a whole.

4.9.4 Breakers shall be so designed that when operated within their specified rating, the temperature of each part will be limited to values consistent with a long life or the material used. The temperature shall not exceed that indicated in IEC-56 under specified ambient conditions.

4.9.5 Contacts shall be kept permanently under pressure of SF₆ gas. The gap between the open contacts shall be such that it can withstand at least the rated phase to ground voltage continuously at zero gauge pressure of SF₆ gas due to its leakage.

4.9.6 If multi break interrupters are used these shall be so designed and augmented that a uniform voltage distribution is developed across them. Calculations/test reports in support of the same shall be furnished along with the bid. The thermal and voltage withstands of the grading elements shall be adequate for the service conditions and duty specified.

5.10 PORCELAIN HOUSING

5.10.1 The porcelain housing shall be of single piece construction without any joint or coupling. It shall be made of homogeneous, vitreous porcelain of high mechanical and dielectric strength. Glazing of porcelain shall be uniform brown or dark brown colour with a smooth surface arranged to shed away rain water or condensed water particles (fog). The type and profile of the porcelain insulator sheds shall be in accordance with IEC-815 joints as per IEC-233.

5.11 ADDITIONAL REQUIREMENTS :

a) The circuit breakers shall be single pressure type, the design and construction of the circuit breaker shall be such that there is minimum possibility of gas leakage and entry of moisture. There should not be any condensation of SF₆ gas on the internal insulating surface of the circuit breaker.

b) All gasket surfaces shall be smooth, straight and reinforced, if necessary to minimize distortion and to make a tight seal, the operating rod connecting the operating mechanism to the arc chamber (SF₆ media) shall have adequate seals, Double –O–ring seals and test holes for leakage test of the internal seal shall be provided on each static joint.

c) In the interrupter assembly there shall be an absorbing product box to eliminate SF₆ decomposition products and moisture. The material used in the construction of the circuit breakers shall be fully compatible with SF₆ gas.

d) Each pole shall form an enclosure filled with SF₆ gas independent of two other poles. The SF₆ density of each pole shall be monitored and regulated by individual pressure switches.

e) The SF₆ gas density monitor shall be adequately temperature compensated. The density monitor shall meet the following requirements:

- i) It shall be possible to dismantle the density monitor for checking/replacement without draining the SF₆ gas by using suitable interlocked non-return couplings.
- ii) It shall damp the pressure pulsation while filling the gas in service so that the flickering of the pressure switch contacts does not take place.
- iii) A pressure indicator (pressure gauge) shall also be supplied.
- f) Means for pressure relief shall be provided in the gas chamber of circuit breaker to avoid the damages or distortion during occurrence of abnormal pressure increase or shock waves generated by internal electric fault occurs. The position of vents, diaphragms and pressure relief devices shall be so arranged as the minimize danger to the operators in the event of gas or vapour escaping under pressure.
- g) Facility shall also be provided to reduce the gas pressure within the breaker to a value not exceeding 8 mili bars within 4 hours or less. Each circuit breaker shall be capable of withstanding this degree of vacuum without distortion or failure of any part.
- h) Sufficient SF₆ gas shall be provided to fill all the circuit breakers installed. **In addition to this 20% of the total gas requirement shall be supplied in separate cylinders as spare requirement.**
- i) Provisions shall be made for attaching an operation analyzer after installation at site to record contact travel, speed and making measurement of operation timings, pre insertion timing of closing resistor, synchronization of contacts in one pole.

5.12 SULPHUR HEXAFLUORIDE GAS (SF₆ GAS) :

- a) The SF₆ gas shall comply with IEC-376, 376A and 376B and be suitable in all respects for use in the switchgear under the worst operating conditions.
- b) The high pressure cylinders in which the SF₆ gas is shipped and stored at site shall comply with requirements of the following standards and regulations:
IS: 4379- Identification of the contents of industrial gas cylinders.
IS: 7311 Seamless high carbon steel cylinders for permanent and high pressure liquefiable gases
The cylinders shall also meet Indian Boiler regulations.
- c) Test: SF₆ gas shall be tested for purity, dew point, break down voltage, water contents as per IEC-376, 376A and 376B and test certificates shall be furnished to owner indicating all the tests as per IEC-376 for each lot of SF₆ gas.

5.13 PREINSERTION RESISTOR (PIR)

~~DELETED~~

5.14 DUTY REQUIREMENTS

5.14.1 The circuit breaker shall be totally restrike free under all duty conditions. Opening resistors shall not be used.

5.14.2 The circuit breaker shall meet the duty requirements for any type of fault or fault location, for line charging and dropping when used on an effectively grounded system and perform make and break operations as per stipulated duty cycles satisfactorily. It shall withstand the maximum expected dynamic loads (including the seismic) to which the circuit breaker may be subjected during its 45 years' service life.

5.14.3 The circuit breaker shall be capable of:

- i) Interrupting the steady and transient magnetizing current corresponding to 420 KV class transformers of 100 MVA & 160 MVA ratings.
- ii) Interrupting line charging current as given in clause 4.0, "Principal Parameters" of this specification with a temporary overvoltage as high as 1.5 p.u without restrikes.
- iii) Clearing short line faults (Kilometric faults) with source impedance behind the bus equivalent to symmetrical fault current specified.
- iv) Breaking inductive currents of 0.5 to 10 A without switching overvoltage exceeding 2.3 p.u
- v) Breaking 25% of the rated fault current at twice rated voltage under phase opposition condition.

5.14.4 The critical current, which gives the longest arc duration at lockout pressure of extinguishing medium and the arc duration, shall be indicated.

5.14.5 The breaker shall satisfactorily withstand the high stresses imposed on them during fault clearing, load rejection and re-energisation of lines with trapped charges. The breaker shall ALSO WITHSTAND THE VOLTAGE SPECIFIED IN CLAUSE 4.0 “principal Parameters” of this specification.

5.15 TOTAL BREAK TIME

5.15.1 The “Total Break Time” as specified in clause 4.0, “Principal Parameters” of this section shall not be exceeded under any of the following duties:

- i) Test duties 1, 2, 3, 4, 5 (with TRV as per IEC-62271-100)/as per related IS.
- ii) Short line fault L90, L75 (with TRV as per IEC-62271-100) /as per related IS.

5.15.2 The Bidder may please note that there is only one specified break time of the breaker which shall not be exceeded under any duty conditions specified such as with the combined variation of the trip coil voltage, (70-110%) spring-spring operation and arc extinguishing medium pressure etc. while furnishing the proof for the total break time of complete circuit breaker, the Bidder may specifically bring out the effect of non-simultaneity between contacts within a pole or between poles and show how it is covered in the guaranteed total break time.

5.15.3 **The values guaranteed shall be supported with the type test reports.**

5.16 OPERATING MECHANISM AND ASSOCIATED EQUIPMENTS

5.16.1 The circuit breaker shall be designed for electrical local as well as remote control. In addition there shall be provision for local mechanical control (emergency trip).

5.16.2 SPRING OPERATED MECHANISM:

The operating mechanism for 420 KV class breakers shall be of spring -**spring type only** operated by electrical control. The mechanism shall be adequately designed for the specified tripping and re closing duty. The entire operating mechanism control circuitry etc. as required shall be housed in an outdoor type, with **Aluminum alloy enclosure (minimum 3mm thickness)**. This enclosure shall conform to the degree of protection IP-55 of IS- 2147. The enclosure shall be invariably mounted on a separate concrete plinth.

5.16.3 All working parts in the mechanism shall be of corrosion resistant material. All bearings which require greasing shall be equipped with pressure grease fittings.

5.16.4 The design of the operating mechanism shall be such that it shall be practically maintenance free. The guaranteed years of maintenance free operation, the number of full load and full rated short circuit current breaking/operation without requiring any maintenance or overhauling, shall be clearly stated in the bid. As far as possible the need for lubricating the operating mechanism shall be kept to the minimum and eliminated altogether if possible.

5.16.5 The operating mechanism shall be non-pumping (and trip free) electrically and mechanically under every method of closing. There shall be no rebounds in the mechanism and it shall not require any critical adjustments at site. Operation of the power operated closing device, when the circuit breaker is already closed, shall not cause damage to the circuit breaker or endanger the operator, provision shall be made for attaching an operation analyzer to facilitate testing of breaker at site.

5.16.6 A mechanical indicator shall be provided to show open and close position of the breaker. It shall be located in a position where it will be visible to a man standing on the ground level with

the mechanism housing closed. An operation counter shall also be provided in the central control cabinet.

5.16.7 The supplier shall furnish detailed operation and maintenance manual of the mechanism along with the operation manual for the circuit breaker.

5.16.8 **The Breaker shall have spare auxiliary switches for Owners use (i.e. for Interlocking, indication, contacts to main and back up relay etc.) A minimum of 20 N/O (52a) & 20 N/C (52b) spare auxiliary switch contacts should be provided.**

5.17 **CONTROL**

5.17.1 The close and trip circuits shall be designed to permit use of momentary contact switches and push buttons.

5.17.2 Each breaker pole shall be provided with two (2) independent tripping circuits, valves and coils each connected to a different set of protective relays.

5.17.3 The breaker shall normally be operated by remote electrical control. Electrical tripping shall be performed by shunt trip coils. However, provisions shall be made for local electrical control. For this purpose a local/remote selector switches and close and trip push buttons shall be provided in the breaker central control cabinet. Remote located push buttons and indicating lamps shall be provided by purchaser.

5.17.4 The trip coils shall be suitable for trip circuit supervision. The trip circuit supervision relay would be provided by the purchaser. Necessary terminals shall be provided in the central control cabinet of the circuit breaker by the supplier.

5.17.5 Closing coil shall operate correctly at all values of voltage between 85% and 110% of the rated voltage. Shunt trip shall operate correctly under all operating conditions of the circuit breaker up to the rated breaking capacity of the circuit breaker and at all values of supply voltage between 70% and 110% of rated voltage. However, even at 50% of rated voltage, the breaker shall be able to perform all its duties. If additional elements are introduced in the trip coil circuit their successful operation and reliability for similar applications on outdoor circuit breakers shall be clearly brought out in the additional information schedules. In the absence of adequate details the offer is likely to be rejected.

5.17.6 Suitable relay for monitoring of DC supply voltage to the control cabinet shall be provided. The pressure switches used for interlock purposes shall have adequate contact ratings to be directly used in the closing and tripping circuits. In case the contacts are not adequately rated and multiplying relays are used then the interlock for closing/opening operation of breaker shall be with No logic of the relay i.e. if the DC supply to the interlock circuit fails then operation lockout shall take place.

5.17.7 For all types of operating mechanism a local manual closing device which can be easily operated by one man standing on the ground shall also be provided for maintenance purposes and direction of motion of handle shall be clearly marked.

5.17.8 The auxiliary switch of the breaker shall be preferably positively driven by the breaker operating rod and where due to construction features, same is not possible a plug in device shall be provided to simulate the opening and closing operations of circuit breaker for the purpose of testing control circuits.

5.18 **MOTOR COMPRESSED SPRING CHARGING MECHANISM**

Spring operated mechanism shall be complete with motor, **opening spring, closing spring** and all other necessary accessories to make the mechanism a complete unit. Breaker operation shall be independent of motor which shall be used solely for the purpose of charging the closing spring.

Motor rating shall be such that it requires only 15 seconds for fully charging the closing spring. Closing operation shall compress the opening spring and keep ready for tripping. The mechanism shall be provided with means for charging the spring by hand. This operation shall be carried out with the doors of the cubicle open. During the process no electrical or mechanical operation of the mechanism shall endanger the operator or damage the equipment. A mechanical indicating device shall be provided to indicate the state of the charge spring and shall be visible with the door of the cubicle closed. An alarm shall be provided for spring failing to be charged within a pre-set time after circuit breaker closing. The spring mechanism shall be fitted with a local manual release, preferably by a push button to avoid inadvertent operation. Means shall be provided for discharging the spring when the circuit breaker is in the open position without circuit breaker attempting to close.

Opening spring and closing spring with limit switches for automotive charging and other necessary accessories to make the mechanism a complete operating unit shall also be provided. As long as power is available to the motor, a continuous sequence of the closing and opening operations shall be possible. The motor shall have adequate thermal rating for this duty.

After failure of power supply to the motor one close open operation shall be possible with the energy contained in the operating mechanism.

Breaker operations shall be independent of the motor which shall be used solely for compressing the closing spring. Facility for manual charging of the closing spring shall also be provided. The motor rating shall be such that it requires not more than 30 seconds for full charging of the closing spring.

Closing action of the breaker shall compress the opening spring ready for tripping.

When closing spring are discharged after closing a breaker, closing spring shall automatically charge for the next operation and an indication of this shall be provided in the local and remote control cabinet.

The spring operating mechanism shall have adequate energy stored in the operating spring to close and latch the circuit breaker against the rated making current also to provide the required energy for the tripping mechanism in case the tripping energy is derived from the operating mechanism.

Provision shall be made to prevent a closing operation of the breaker when the spring is in the partial charged condition. Mechanical interlocking shall be provided in the operating mechanism to prevent discharging of closing spring when the breaker is already in the closed position.

5.18.1 OPERATED MECHANISM FOR 400 KV BREAKERS.

The operating mechanism for 420 KV circuit breakers shall also be spring operated mechanism. (Closing spring and opening also spring).

5.19 OPERATING MECHANISM HOUSING

The operating mechanism housing/control cabinet shall conform to the requirement specified in clause 5.29. The entire operating mechanism and control mechanism control circuitry & etc. as required, shall be housed in an outdoor type, made out of **Aluminum alloy sheet of 3mm thickness** enclosure. This enclosure shall conform to the degree of protection IP-55 of IS- 2147.

5.20 INTERLOCKS

It is proposed to electrically interlock the circuit breaker with purchaser's associated air break isolating switches in accordance with switch yard safety interlocking scheme. The details of the scheme will be furnished to the supplier. All accessories required on breaker side for satisfactory operation of the scheme shall be deemed to be included in the scope of supply of this specification.

5.21 SUPPORT STRUCTURE

The supplier shall indicate the price of support structure along with the foundation bolts required separately in the bid proposal sheets and these shall be considered in evaluation. Purchaser reserves the right to procure these from the supplier or through separate contract. However, in case the equipment offered have integral support structure or the specialties of the breaker are such that support structures have to be provided by the supplier, the prices of these support structure shall be included in the price of the equipment and same shall be indicated clearly in the bid proposal sheet. The support structure shall meet the following requirements:

- 1) The minimum vertical clearance from any energized metal part to the bottom of the circuit breaker (structure) base, where it rests on the foundation pad, shall **be minimum 8 meters for 400 KV**
- 2) The minimum vertical distance from the bottom of the lowest porcelain part of the bushings, porcelain enclosures or supporting insulators to the bottom of the circuit breaker base, where it rests on the foundation pad shall be **2.55 meters for all voltages.**
- 3) The minimum clearance between the live parts and earth shall be **3.5 meters for 400 KV.**

5.22 FITTINGS AND ACCESSORIES

5.22.1 Following is a partial list of some of the major fittings and accessories to be furnished by supplier in the central control cabinet. Number and exact locations of these parts shall be indicated in the bid.

- a) Central control cabinet in accordance with clause no. 5.29 complete with
 - i) Cable glands.
 - ii) Local/remote changeover switch.
 - iii) Operation counter.
 - iv) SF₆ pressure gauges.
 - v) Control switches to cut off control power supply.
 - vi) Fuses as required.
 - vii) The number of terminals provided shall be adequate enough to wire out all contacts and control circuits plus 24 terminals spare for owner's use.

All the terminal blocks to be used in the operating mechanism and control cubicle should be of stud type of Poly-amide/Melamine material of make like Elmex (OAT-6 for non-disconnecting type and OAT 6T for disconnecting type) / Connect well (Equivalent).

- b) Anti-pumping relay.
- c) Rating and diagram plate in accordance with IEC / IS incorporating year of manufacture.

5.23 PAINTING, GALVANISING AND CLIMATE PROOFING

5.23.1 All interiors and exteriors of tanks and other metal parts shall be thoroughly cleaned to remove all rust, scales, corrosion, greases or other adhering foreign matter and the surfaces treated by phosphating (e.g. seven tank phosphating sequences). All steel surfaces in contact with insulating oil, as far as accessible, shall be painted with not less than two coats of heat resistant, oil insoluble, insulating paint.

5.23.2 All metal surfaces exposed to atmosphere shall be given, in addition to the treatment described in clause 5.23 two primer coats of zinc chromate and two coats of epoxy paint with epoxy base thinner. All metal parts not accessible for painting shall be made of corrosion resisting material. All machine finished or bright surfaces shall be coated with a suitable preventive compound and suitably wrapped or otherwise protected. All paints shall be carefully selected to withstand tropical heat and extremes of weather within the limits specified. The paint shall not scale off or wrinkle or be removed by abrasion due to normal handling. All external paintings shall be as per shade no. 697 of IS: 5.

5.23.3 Paint inside the metallic housing shall be of anti-condensation type and the paint on outside surfaces shall be suitable for outdoor installation.

5.23.4 All components shall be given adequate treatment of climate proofing as per IS:3202 so as to withstand corrosive and service conditions.

5.24 GALVANISING

All ferrous parts including all sizes of nuts, bolts, support channels, structures, etc. as also the mechanism housing shall be hot dip galvanized conforming to latest version of IS: 2629. Spring washers shall be electro galvanized.

5.25 EARTHING

The operating mechanism housing, control cabinets, dead tanks, support structure etc. shall be provided with two separate earthing terminals suitable for bolted connection to 50X8 mm mild steel flat to be provided by the Purchaser for connection to station earth mat.

5.26 NAME AND RATING PLATES:

Circuit breaker and its operating device shall be provided with a rating plate or plates marked with but not limited to following data:

- a) Manufacturer's name or trade mark.
 - b) Serial Number or type designation making it possible to get all the relevant information from the manufacturer.
 - c) Year of manufacture.
 - d) Rated voltage.
 - e) Rated insulation level.
 - f) Rated frequency.
 - g) Rated normal current.
 - h) Rated short circuit breaking current.
 - i) First pole to clear factor.
 - j) Rated duration of short circuit.
 - k) Rated auxiliary D.C. supply voltage of closing and opening devices.
 - l) Rated pressure of compressed air gas for operation and interruption.
 - m) Rated out of phase breaking current.
 - n) Rated supply voltage of auxiliary circuits.
 - o) Rated supply frequency of auxiliary circuits.
 - p) Number of closing & Tripping coils
 - q) Opening time & closing time
- Other information are as per IS 12729/IEC 60694.

The coils of operating devices shall have a reference mark permitting the data to be obtained from the manufacturer.

The rating plate shall be visible in position of normal service and installation. The rating plate shall be weather proof and corrosion proof.

5.27 LIMITS OF TEMPERATURE RISE

The temperature rise on any part of equipment shall not exceed the maximum temperature rise specified below under the conditions specified in test clauses. The permissible temperature rise indicated is for a maximum ambient temperature of 50°C. If the maximum ambient temperature rises, permissible values shall be reduced accordingly.

Sl. No.	Nature of the part or of the liquid	Maximum Value of	
		Temp.	Temp. rise at a max. Ambient air temp. not exceeding 50 deg. C.
1.	Contacts in air, silver-faced copper, copper alloy or aluminum alloy [see notes (i) and (ii)] Bare copper or tinned aluminum alloy.	105 75	55 25
2.	Contacts in oil: Silver-faced copper, copper alloy or aluminum alloy (see note ii) Bare copper or tinned aluminum alloy	90 80	40 30
3.	Terminals to be connected to external conductors by screws or bolts silver faced (see note iii)	105	55
4.	Metal parts acting as springs	See note iv	See note iv
5	Metal parts in contact with insulation of the following classes:		
	Class Y: (for non-impregnated materials)	90	40
	Class A: (for materials immersed in oil or impregnated)	100	50
	Class E: in air	120	70
	in oil	100	50
	Class B: in air	130	80
	in oil	100	50
	Class F: in air	155	105
	in oil	100	50
	Enamel: Oil base Synthetic, in air	120	70
Synthetic, in oil	100	50	
6	Any part of metal or of insulating material in contact with oil, except contacts	100	50
7	Oil	90	40

Notes: (i) When applying the temperature rise of 55 deg. C, care should be taken to ensure that no damage is caused to the surrounding insulating materials.

(ii) The quality of the silver facing shall be such that a layer of silver remains at the points of contact after the mechanical endurance test. Otherwise, the contacts shall be regarded as "bare".

(iii) The values of temperature and temperature rise are valid whether or not the conductor connected to the terminals is silver-faced.

(iv) The temperature shall not reach a value whether the elasticity of the material is impaired. For pure copper, this implies a temperature limit of 80° C.

5.28 TERMINAL CONNECTORS

5.28.1 The terminal connectors shall meet the following requirements:

- a) Terminal connectors shall be manufactured and tested as per IS: 5561.
- b) All castings shall be free from blow holes, surface blisters, cracks and cavities. All sharp edges and corners shall be blurred and rounded off.
- c) No part of a clamp shall be less than 10 mm thick.
- d) All ferrous parts shall be hot dip galvanized conforming to IS: 2633.
- e) For bimetallic connectors, copper alloy liner of minimum thickness of 2 mm shall be cast integral with aluminum body.
- f) Flexible connectors shall be made from tinned copper.
- g) All current carrying parts shall be designed and manufactured to have minimum contact resistance.
- h) Connectors shall be designed to be corona free in accordance with the requirements stipulated in IS: 5561.

5.29 SPECIFICATION FOR CONTROL CABINETS:

1. Control cabinets shall be of the free standing floor mounting type.
2. Control cabinet of the operating mechanism shall be made out of **Aluminum alloy sheet (minimum 3 mm thickness)**. **The operating mechanism shall be strong, rigid & not subject to rebound**. Hinged door shall be provided with padlocking arrangement. Sloping rain hood shall be provided to cover all sides. 15 mm thick neoprene or better type of gaskets shall be provided to ensure degree of protection of at least IP55 as per IS: 2147.
3. Bus bars shall be of tinned copper of adequate cross-section to carry the normal current, without exceeding the permissible temperature rise over an ambient temperature of **50°C** outside the cubicle. The buses shall be braced to withstand forces corresponding to short circuit current of 25 KA.
4. Motors rated 1 KW and above being controlled from the control cabinet would be suitable for operation on a 415 V, 3 phase 50 Hz system. Fractional KW motors would be suitable for operation on a 240 V, 1-phase, 50 Hz supply system.
5. Isolating switches (MCBs) shall be group operated units (3 poles for use on 3-phase supply systems and 2 poles for single phase supply systems) quick make quick break type, capable of breaking safely and without deterioration, the rated current of the associated circuit. Switch handle shall have provision for locking in both fully open and fully closed positions.
6. Push buttons shall be rated for not less than 6 Amps, 415 V A.C. or 2 Amps, 220 V D.C. and shall be flush mounted on the cabinet door and provided with appropriate name plates. Red, Green and Amber indicating lamps shall be flush mounted.
7. For motors up to 5 KW, contactors shall be direct-on-line, air break, single throw type and shall be suitable for making and breaking the stalled current of the associated motor which shall be assumed equal to 6.5 times the full load current of the motor at 0.2 pf. For motors above 5 KW, automatic star delta type starters shall be provided. 3 pole contactors shall be furnished for 3 phase motors and 2-pole contactors for single phase motors. Reversing contactors shall be provided with electrical interlocks between forward and reverse contactors. If possible, mechanical interlocks shall also be provided. Contactors shall be suitable for uninterrupted duty and shall be of duty category class AC4 as defined in IS: 2959. The main contacts of the contactors shall be silver plated and the insulation class for the coils shall be class E or better. The dropout voltage of the contactors shall not exceed 70% of the rated voltage.
8. Contactors shall be provided with a three element, positive acting, ambient temperature compensated, time lagged, hand reset type thermal overload relay with adjustable setting, hand

reset button shall be flush with the front door of the cabinet and suitable for resetting with starter compartment door closed.

9. Single phasing preventer relay shall be provided for 3 phase motors to provide positive protection against single phasing.

10. Mini starters shall be provided with no volt coils whenever required.

11. Purchaser's power cables will be of 1100 volts grade stranded aluminum conductor. PVC insulated, PVC sheathed single steel wire armoured and PVC jacketed. All necessary cable terminating accessories such as glands, crimp type tinned copper lugs etc. for power as well as control cables shall be included in supplier's scope of supply. Suitable brass cable glands shall be provided for cable entry.

12. Wiring for all control circuits shall be carried out with 1100 volts grade PVC insulated tinned copper stranded conductors of sizes not smaller than 2.5 sq. mm. at least 10% spare terminal blocks for control wire terminations shall be provided on each panel. The terminal blocks shall be of non-disconnecting stud type. All terminals shall be provided with ferrules indelibly marked or numbered and these identifications shall correspond to the designations on the relevant wiring diagrams. The terminals shall be rated for adequate capacity which shall not be less than 10 Amps.

13. Separate terminal blocks shall be provided for terminating circuits of various voltage classes. CT loads shall be terminated on a separate block and shall have provision for short circuiting the CT secondary terminals.

14. Control cabinet shall be provided with 240 V, 1-phase 50 Hz, 9 W LED light WITH fixture and a suitably rated 240 V, 1-phase, 5 amps, and 3 pin sockets for hand lamps.

15. Strip heaters shall be provided inside each cabinet complete with thermostat (preferably differential type) to prevent moisture condensation. Heaters shall be controlled by suitably rated double pole miniature Circuit Breakers.

16. Signal lamps provided shall be of neon screw type with series resistors, enclosed in Bakelite body. Each signal lamp shall be provided with a fuse integrally mounted in the lamp body.

17. Electric measuring instruments shall be of moving iron type. Ammeters for measuring current up to 30 Amps shall be directly connected while those for measuring above 30 Amps shall be connected through suitable CBs. Ammeters shall be provided with selector switches.

18. Items inside the cabinet made of material shall be coated with a fungus resistant varnish.

5.30 MOTORS: (UNIVERSAL MOTOR)

Motors shall be universal type suitable for operation in AC & DC supply, as per IS: 325 of sufficient size capable of satisfactory operation for the application and duty as required for the driven equipment.

6.1.1 TESTS

Type Tests

All the equipments offered shall be fully type tested as per the relevant standards (IEC-62271-100, IEC-60694/IS-12729 with latest amendments) & tests as indicated below. **The bids offering equipments not type tested will be rejected.** In case, the equipment of the type & design offered has already been type tested, the bidder shall furnish four sets of the type test reports along with the offer. **The test must have been conducted not later than five years from the date of opening of the bids.** The purchaser reserves the right to demand repetition of some or all the type & additional type tests in the presence of his representative. For this purpose, the bidder may quote unit rates for carrying out such type tests. For any change in the design/type already type tested the design/type offered against this specification, the purchaser reserves the right to demand repetition of tests without any extra cost or reject the bid without any intimation.

Type Tests:--(As per IEC-62271-100 with latest amendments)

- 1) Dielectric Test (LI Voltage, PF Voltage Withstand (Dry & Wet)& etc.)
- 2) RIV Test
- 3) Measurement of resistance of the main circuit
- 4) Temperature rise Test
- 5) Short Time withstand current & Peak withstand current Test
- 6) Tightness Test
- 7) Mechanical Operation Test, Mechanical endurance test
- 8) Short Circuit making & Breaking Test
- 9) Capacitive Current, Switching Test, Line charging current breaking Test
- 10) Test to verify degree of protection
- 11) EMC Test

ROUTINE TESTS:-

- 1) Dielectric Tests on the main Circuit, auxiliary & control circuits
- 2) Measurement of resistance of the main circuit.
- 3) Tightness Test
- 4) Design & Visual Checks
- 5) Mechanical operation Test
- 6) Operating time of the device, motor Characteristics, measurement of coil current & resistance, SF₆ gas pressure monitoring, control Circuit, anti-pumping, dimensions, nameplate details, contact travel & timing checks & contact speed in m/sec.

The following additional type tests are proposed to be conducted. The type test charges for these tests shall be quoted along with other type tests (AS indicated above) as per IEC/ IS in the relevant schedule & the same shall be indicated in the total bid price.

- 1) Corona extinction voltage Test (As per Annexure-I)
- 2) Out of phase closing test as per IEC
- 3) Line charging breaking current test
- 4) Seismic Withstand test in unpressurised condition (as per Annexure-I)

6.1.2 The prices quoted by the bidder towards conductance of type tests & additional type tests shall be taken in to consideration for bid evaluation.

6.2 TYPE, ACCEPTANCE AND ROUTINE TESTS

6.2.1 All acceptance and routine tests as stipulated in IEC-62271-100, IEC-60694/IS-12729, IS 13118 with its latest amendments & routine tests as indicated above shall be carried out by the supplier in the presence of purchaser's representative. Also type test on one unit may be carried out by the supplier in the presence of purchaser's representative if purchaser decides & if such facility will be available either in the manufacturer's laboratory or in the CPRI. Rates for these tests must be indicated in the Annexure-IV, V, of Section-III of this tender specification. If the manufacturer wants to do the above tests in free of cost, then he may indicate the rates as 'NIL'. Purchaser reserves the right to conduct type test or may not insist for this test.

6.2.2 In addition to the mechanical and electrical tests specified by IEC, the following shall also be performed.

Speed curves for each breaker shall be obtained with the help of a suitable operation analyzer to determine the breaker contact movement during opening, closing, auto-reclosing and trip free operation under normal as well as limiting operating conditions (control voltage, pressure etc.). The tests shall show the speed of contacts directly at various stages of operation, travel of contacts, opening time, closing time, shortest time between separation and meeting of contacts at break/make operation etc. This test shall also be performed at site for which the necessary operation analyzer along with necessary transducers, cables, console, etc. shall be furnished as mandatory maintenance equipment.

6.2.3 Immediately after finalization of the programme of type/acceptance/routine testing, the supplier shall give sufficient advance intimation (20 days) to the purchaser to enable him to depute his representative for witnessing the tests.

6.3 ADDITIONAL TESTS

The purchaser reserves the right for carrying out any other tests of a reasonable nature at the works of the supplier/laboratory or at any other recognized laboratory/research institute in addition to the above mentioned type, acceptance and routine tests at the cost of the purchaser to satisfy that the material complies with the intent of this specification.

7.0 INSPECTION

7.1 The inspection may be carried out by the purchaser at any stage of manufacture. The supplier shall grant free access to purchaser's representative at a reasonable time when the work is in progress. Inspection and acceptance of any equipment under this specification by the purchaser shall not relieve the supplier of his obligation of furnishing equipment in accordance with the specification and shall not prevent subsequent rejection if the equipment is found to be defective.

The supplier shall keep the purchaser informed in advance, about the manufacturing programme so that arrangement can be made for inspection. Before offering for inspection, the supplier shall furnish shop routine test certificates and calibration reports of the equipments/instruments to be used during testing. After acceptance of these calibration reports and shop routine test certificate, inspecting officer of the purchaser will be deputed for witnessing such inspections.

7.2 The purchaser reserves the right to insist for witnessing the acceptance/routine testing of the bought out items.

7.3 No material shall be dispatched from its point of manufacture unless the material has been satisfactorily inspected and tested or unless the same is waived by the purchaser in writing.

8.0 QUALITY ASSURANCE PLAN:

The bidder shall invariably furnish following information along with his offer, failing which his offer, shall be liable for rejection.

i) Statement giving list of important raw materials including but not limited to:

- (a) Contact Material
- (b) Insulation
- (c) Porcelain
- (d) Oil
- (e) Sealing material
- (f) Contactor, limit switches, etc. in control cabinet.

Names of sub-suppliers for the raw materials, list of standards according to which the raw materials are tested, list of test normally carried out on raw materials in presence of Bidder's representative, copies of test certificates.

- ii) Information and copies of test certificates as in (i) above in respect of bought out accessories.
- iii) List of areas in manufacturing process, where stage inspections are normally carried out for quality control and details of such tests and inspections.
- iv) Special features provided in the equipment to make it maintenance free.
- vi) List of testing equipment available with the Bidder for final testing of breakers vis-à-vis, the type, special, acceptance and routine tests specified in the relevant standards. These limitations shall be very clearly brought out in the relevant schedule i.e. schedule of deviations from specified test requirements.

- vii) The supplier shall, within 30 days of placement of order, submit following information to the purchaser.
 - 1) List of raw materials as well bought out accessories and the names of sub-suppliers selected from those furnished along with offer.
 - 2) Type test certificates of the raw material and bought out accessories.
 - 3) Quality assurance plan (QAP) withhold points for purchaser's inspection (if purchaser will desires).

The supplier shall submit the routine test certificates of bought out items and raw material, at the time of routine testing of the fully assembling breaker

9.0 DOCUMENTATION

9.1 All drawings shall conform to relevant International Standards Organization (ISO) Specification/ISS. All drawings shall be in ink and suitable for micro filming. All dimensions and data shall be in S.I. Units.

9.2 List of Drawings and Documents

The Bidder shall furnish four sets of relevant descriptive and illustrative published literature pamphlets and the following drawings/documents for preliminary study along with the offer.

- a) General outline drawings showing dimensions and shipping weights, quantity of insulating media, air receiver capacity etc.
- b) Sectional views showing the general constructional features of the circuit breaker including operating mechanism, arcing chambers, contacts with lifting dimensions for maintenance.
- c) Schematic diagrams of breaker offered for control supervision and reclosing.
- d) Structural drawing, design calculations and loading data for support structures.
- e) Foundation drilling plan and loading data for foundation design.
- f) Type test reports.

9.3 The supplier shall, within 2 weeks of placement of order submit four sets of final version of all the above drawings for purchaser's approval. The purchaser shall communicate his comments/approval on the drawings to the supplier within reasonable period. The supplier shall, if necessary, modify the drawings and resubmit four copies of the modified drawings for purchaser's approval within two weeks from the date of comments. After receipt of purchaser's approval, the supplier shall, within three weeks, submit 15 prints and one good quality reproducible of the approved drawings for purchaser's use.

9.4 The supplier shall also furnish fifteen copies of manuals covering erection, commissioning, operation and maintenance instructions and all relevant information and approved drawings pertaining to the main equipment as well as auxiliary devices. Marked erection drawings shall identify the component parts of the equipment as shipped to enable purchaser to carry out erection with his own personnel. Each manual shall also contain one set of all the approved drawings, type test reports as well as acceptance reports of the corresponding consignment dispatched.

9.5 The manufacturing of the equipment shall be strictly in accordance with the approved drawings and no deviation shall be permitted without the written approval of the purchaser. All manufacturing and fabrication work in connection with the equipment prior to the approval of the drawing shall be at the supplier risk.

9.6 TEST REPORTS

- i) Four copies of acceptance test reports and type test reports shall be furnished to the purchaser as per the inspection of testing. One copy will be returned, duly certified by the purchaser and only there afterwards shall the material be dispatched.
- ii) All records of routine test reports shall be maintained by the supplier at his works for periodic inspection by the purchaser.
- iii) All test reports of tests conducted during manufacture shall be maintained by the supplier. These shall be produced for verification as and when requested for by the purchaser.

10 PACKING AND FORWARDING

The equipment shall be packed in suitable crates so as to withstand handling during transit. The supplier shall be responsible for any damage to the equipment during transit, due to improper and inadequate packing and handling. The easily damageable materials shall be carefully packed and marked with the appropriate caution symbols. Wherever necessary, proper arrangement for lifting such as lifting hooks etc. shall be provided. Any material found short inside the packing cases shall be supplied by the supplier without any extra cost.

Each consignment shall be accompanied by a detailed packing list containing the following information:

- a. Name of the consignee.
- b. Details of consignment.
- c. Destination.
- d. Total weight of consignment.
- e. Sign showing upper / lower side of the crate.
- f. Handling and unpacking instructions.
- g. Bill of material indicating contents of each package and spare material.
- h. Manuals containing approved drawings & test reports

The supplier shall ensure that the packing list and bill of material are to be supplied in advance to the purchaser & to the consignees before dispatch.

11.0 SUPERVISION OF ERECTION, TESTING AND COMMISSIONING (ET&C)

The erection, testing and commissioning of the breakers shall be supervised, by trained personnel (Engineer) of the supplier who shall direct the sequence of ET&C and make the necessary adjustments to the apparatus and correct in the field any errors or omissions in order to make the equipment and material properly perform in accordance with the intent of this specification. The Engineer shall also instruct fully (up to the satisfaction) to the plant operators, in the operation and maintenance of equipment furnished. The supplier shall be responsible for any damage to the equipment, on commissioning the same, if such damage results from faulty or improper ET&C procedure. Purchaser shall provide adequate number of skilled/semi-skilled workers as well as all ordinary tools and equipment and cranes required for breaker erection, at his own expense. Apart from the above, the purchaser shall not be responsible for any other expenses incurred by the supplier and against personal injuries to the Engineer etc., shall be to supplier's account. Special tools, if required for erection and commissioning shall be arranged by the supplier at his cost and on commissioning these shall be supplied to the purchaser, free of cost, for future use.

12.0 QUANTITY AND DELIVERY RERQUIREMENTS

- i) **The scope of supply shall include a supply of 25% extra-quantity of bolts, nuts, washers, split pins, cotter pins and such other small loose items free of cost.**

SCHEDULE- A
TECHNICAL PARTICULARS AND GUARANTEES

1. Topographical and Meteorological site conditions

Location		State of ODISHA
Altitude	m	1000
Air Temperatures		
Minimum	°C	0
Maximum	°C	55
Maximum daily average	°C	32
Humidity variation	per cent	100
Pollution level to IEC 815		Heavy
Airborne contamination, if any		Highly polluted
Isoceraunic level	day/annum	70
Seismic withstand factor (all equipment)	g	0.3
Maximum wind pressure	kg/sq. m	80.84
Wind velocity - (Wind Zone to IS 875)	m/sec	50
Average annual rain fall	cm	150

1	SYSTEM DETAILS	KV	400
1.1	Rated system voltage	kV	420
1.2	Earthing of system neutral		solid
1.3	System frequency	Hz	50
2	INSULATION LEVEL (at site altitude)		
2.1	Lightning impulse voltage withstand level, positive and negative polarity	kVp	1425
2.2	Switching impulse voltage withstand level of insulation to ground, positive and negative polarity	dry kVp wet kVp	1050 1050
2.3	Power frequency withstand voltage	dry kV wet kV	520 520
2.4	Voltage below which corona shall not be visible	kV	320
2.5	Maximum radio interference voltage level measured at 1.1 times $U_s/\sqrt{3}$ at 1 MHz	μ V	<1000
2.6	Minimum creepage to earth over insulation on rated service voltage (to IEC 815)	mm/kV	25

Us is rated system voltage:

Creepage distance across interrupter chambers shall be at least 10 per cent greater than the creepage distance to earth and shall comply with the pollution conditions of IEC 815.

2. - SWITCHGEAR DETAILS

Item No	Description	Particulars
		kV 420
1	TYPE OF SWITCHGEAR	
1.1	Type of switchgear GIS or Open terminal	Open terminal
1.2	Installation Outdoor	Outdoor
2	SHORT TIME CURRENT CAPACITY	
2.1	All equipment 3 seconds	kA 50

Item No	Description		Particulars
2.2	Maintenance earthing devices, 3 seconds	kA	50
3	CIRCUIT BREAKER		
3.1	Normal current rating	A	3150
3.2	Fault rating		
3.2.1	Making current	kAp	125
3.2.2	Breaking current (symmetrical)	kA	50
3.2.3	Breaking current (asymmetrical)	% DC/ kAp	IEC 56 <50%
3.2.4	Breaking current under out of phase conditions	kA	10
3.2.5	Rated line charging current	A	600
3.2.6	Rated cable charging current	A	600
3.2.7	Rated inductive current	A	1 to 10 - 50 - 100 – 200
3.2.8	Maximum overvoltage factor on any switching duty	pu	<2.0

3.3	Operating sequence		
3.3.1	Normal		
3.3.2	Auto reclosing		
3.3.3	Delayed three phase auto reclose cycle adjustable dead time range	s	2-30
		kV	420
3.3.4	High speed single phase auto reclose cycle adjustable dead time	s	0.3-20
3.3.5	Number of closing operations under out of synchronous conditions	(2.0 pu)	2
3.4	Transient recovery voltage		
3.4.1	First phase to clear factor		1.3
3.4.2	Recovery voltage parameter for 3 phase unearthed terminal fault		IEC 56
3.4.3	Short line fault parameter		IEC 56
3.4.4	Surge impedance for short line fault test	ohms	450
3.4.5	Minimum voltage to earth when switching capacitive currents, (1.4 times rated phase to earth voltage)	kV	340
3.4.6	Voltage across circuit breaker under out of phase switching conditions	pu	2
3.5	Electro mechanical performance		
3.5.1	Maximum total break time throughout complete rating, ie trip coil initiation to final arc extinction	ms	40
3.5.2	Maximum time interval between closure of first and last phase of three phase circuit breakers	ms	2
3.5.3	Maximum time interval between closure of interrupters of one phase of the circuit breaker	ms	1
3.5.4	Maximum time interval between opening of first and last phase of three phase circuit breaker	ms	3.3
3.5.5	Maximum time interval between opening of interrupters of one phase of the circuit breaker	ms	1

Insulation level (IEC 694) for 420 KV

Item No	DESCRIPTION	KV	420
4.1	Lightning impulse withstand (1.2/50 wave) - positive and negative a. To earth, closed contacts b. Across, open contacts	kVp	1425
		kVp	-
		kVp+	1425
		kVACp	+(240)
4.2	Switching impulse withstand (250/ 2500 wave) - positive and negative c. To earth, closed contacts d. Across, open contacts	kVp	1050
		kVp+	900
		kVACp	+(345)
4.3	Power frequency withstand	Dry/wet	
	e. To earth, closed contacts	KV	520
	f. Across, open contacts	KV	610
4.4	Ancillary equipment		
4.5	Number of trip coils required	2	
4.6	Number of closing coils required	1	
4.7	Degree of protection	IP 55	

Biased tests (Impulse + ACp), required on switchgear for 300 kV and above

5. TABLE 1 - 420KV CIRCUIT BREAKERS

(A) TERMINAL FAULT REQUIREMENTS - FOUR PARAMETER TRV

Fault duty	Current kA (rms)	First test voltage U ₁ (kV)	Time co-ord t ₁ (μs)	TRV peak value U _c (kV)	Time co- ordt ₂ (μs)	Time delay t _d (μs)	Volt co- ord u' (kV)	Time co-ord t' (μs)	Rate of rise U'/t kV (kV/μs)
10% symmetrical	5	-	-	787	88	11	262	4	8.9
30% symmetrical	15	446	89	669	668	5(22)	223	50(67)	5.0
60% symmetrical	30	446	149	669	671	2(37)	223	76(111)	3.0
100% symmetrical	50	446	223	624	669	2	223	113	2.0
100% Asym.	**	446	223	624	669	2	223	113	2.0
Asynchronous	12.5	686	446	857	1338	-	-	-	-
100% closing	125	-	-	-	-	-	-	-	-

** Dependent on circuit breaker opening time

*** 100% Sym and Assym duties shall either include ITRVs of Table III of IEC 56 or the SLF duties have been performed with t_{dL} = 0

6. (B) SHORT LINE FAULT REQUIREMENTS

Source side	50	343	171	480	513	2	171	88	2.0
				U_L	t_L	t_{dL}			U_L/t_L
Line side L90	45	-	-	54.9	6.1	0.5	-	-	9
Line side L75	37.5	-	-	137.3	18.4	0.5	-	-	7.46
Line side L 60	30	-	-	219	36.5	0.5	-	-	6

7. MINIMUM FACTORS OF SAFETY FOR SWITCHGEAR FOR 420 KV

Sl no	Description	Particulars
1.1	Complete insulators based on electro-mechanical test	2.5
1.2	Insulator metal fittings based on elastic limit	2.5
1.3	Steel structures based on elastic limit of tension members and on crippling loads of compression members	2.5
1.4	Foundations for structures against overturning or uprooting under maximum simultaneous working loadings	2.5

8. CLEARANCES*

8.1 Clearances for bus-bars and connections

		420
BIL	kVpK	1425
SIL	kVpK	1050
Minimum Clearance between Live metal and Earth	m	3.4
Minimum Clearance between Live metal of Different Phases	m	3.9
Safety Working Clearance Horizontal	m	5.4
Safety Working Clearance Vertical	m	6.4
Minimum height to base of insulation	m	2.7

* Based on BS 7354: 1990

Clearances apply only to equipment not subject to impulse voltage type tests.

They apply to conditions of maximum conductor swing and sag.

Item	Description	Particulars	
9	FINISH OF EQUIPMENT		
9.1	Outdoor equipment		Outdoor
9.1.1	Porcelains		Brown
9.1.2	Structures		Hot dip galvanized
9.1.3	Cubicles and enclosures		As specified
10	LVAC EQUIPMENT		
10.1	Rated system voltage	V	415V-30, 240V-10
10.2	Rated frequency	Hz	50
10.3	Method of earthing system neutral		Solidly earthed
10.4	Type of equipment required (switch fuses, MCCBs, air circuit breakers etc.)		Air circuit breaker MCCBs
10.5	Voltage limits for correct operation of circuit breakers	% V % V	10 5
11	DC AUXILIARY SUPPLIES		
11.1	Nominal voltage of system	V	220
11.2	Voltage limits for correct operation of equipment	%	10 5
12	NOMINAL VOLTAGE OF AUXILIARY SUPPLIES		
12.1	Supply for electrical operation of circuit breakers		
12.1.1	Closing initiation	V dc	220
12.1.2	Tripping	V dc	220
12.2	Power supply for compressor equipment		415
12.3	Power supply for spring and hydraulic charging motors	V ac	240
12.4	Supply for indication and alarm circuits	V dc	220

ANNEXURE – I
(CIRCUIT BREAKERS)
CORONA, RIV AND SEISMIC TEST PROCEDURES
CORONA AND RADIO INTERFERENCE VOLTAGE (RIV) TEST:

1) **General:**

Unless otherwise stipulated, all equipment together with its associated connectors, where applicable, shall be tested for external corona both by observing the voltage level for the extinction of visible corona under falling power frequency voltage and by measurement of radio interference voltage (RIV).

2) **Test Levels:**

The test voltage levels for measurement of external RIV and for corona extinction voltage are listed under the relevant clauses of the specification.

3) **Test Methods for RIV**

3.1 RIV tests shall be made according to measuring circuit as per International Sub-Committee on Radio Interference Publication 1- 1972 second edition. The measuring circuit shall preferably be tuned to frequency of 0.5 MHz but other frequencies in the range of 0.5 MHz to 2 MHz may be used. The measuring frequency shall be recorded. The results shall be in microvolts.

3.2 Alternatively, RIV tests shall be conducted in accordance with NEMA standard publication No. 107-1964 except as otherwise noted herein.

3.3 In measurements of RIV only standard fittings of identical type supplied with the equipment and a simulation of the connections as used in the actual installation will be permitted in the vicinity within 3.5 meters of terminals.

3.4 Ambient noise shall be measured before and after each series of tests to ensure that there is no variation in ambient noise level. If variation is present, the lowest ambient noise level will form basis for the measurement. RIV levels shall be measured at increasing and decreasing voltages of 85%, 100%, 115% and 130% of the specified RIV test voltage for all equipments unless otherwise specified.

3.5 The metering instruments shall be as per CISPR recommendation or equipment device so long as it has been used by other testing authorities.

3.6 The RIV measurement may be made with a properly tuned noise meter.

4.0 **Test Methods for Visible Corona:**

4.1 The purpose of this test is to determine the corona extinction voltage of apparatus and connectors, the test shall be carried out in the same manner as RIV test described above with the exception that RIV measurements are not required during test and a search technique shall be used near the onset of extinction voltages, when the test voltage is raised and lowered to determine their precise values. The test voltage shall be raised to 130% of RIV test voltage and maintained there for five minutes. The voltage will then be decreased slowly until all visible coronas disappear. The voltage will then be raised slowly again to the same maximum voltage. The procedure shall be repeated at least 4 times with corona inception and extinction voltage recorded each time. The corona extinction voltage for purposes of determining compliance with the specification shall be the lowest of the four values at which visible corona (negative or positive polarity) disappears. Photographs with laboratory in complete darkness shall be taken under test conditions, at all voltage steps i.e., 85%, 100%, 115% and 130%. Additional photographs shall be taken at corona inception and extinction voltages. At least two photographs shall be taken in each case.

4.2 The “test to determine the visible corona extinction voltage” need not be carried out simultaneously with “test to determine RIV levels”. However, both tests shall be carried out with the same test set up and as little time duration between tests as possible. No modifications or treatment of the sample between tests will be allowed. Simultaneous RIV and visible corona extinction voltage testing may be permitted at the discretion of owner’s inspector if, the same, in his opinion, will not prejudice other tests.

B. **Seismic Withstand Test:**

The seismic withstand test on the complete equipment shall be carried out along with the supporting structures etc. The seismic level specified shall be applied at the base of the structure. The accelerometers shall be provided at the terminal pad of the equipment and any other point as agreed by the purchaser. The seismic test shall be carried out in all possible combinations of the equipment. The detailed seismic test procedure shall be furnished to the purchaser before offer for inspection.

GUARANTEED TECHNICAL PARTICULARS FOR CIRCUIT BREAKERS

SL NO.	DESCRIPTION	420 KV SF ₆ Circuit Breaker
1	(a) Maker's name and country of manufacture	
	(b) Manufacturer's type Designation	
2	Applicable technical standards	
3	(a) Rated voltage(kV)	
	(b) Rated frequency(Hz)	
4	Number of Poles	
5	Class	
6	Rated normal current	
	(a) Under site conditions(Amps)	
	(b) Rated (Amps)	
7	(a) Rated short circuit breaking current.	
	(i) Rms value of AC component of rated short circuit current (KA)	
	(ii) Percentage DC component	
	(iii) Asymmetrical Breaking Current at Highest System Voltage	
	(iv) Certificate or report no	
	(v) Oscillogram no.	
	(b) Rated short circuit making current (KA peak)	
	(i) At Higher rated voltage.	
	(ii) At Lower rated voltage	
	(C) (i) Maximum Breaking capacity Under Phase Opposition(KAP)	
	(ii) Max Pole discrepancy (rms)	
	(iii) Ma arc duration & Corresponding current under lockout pressure.	
8	First pole to clear factor	
9	Rated transient recovery voltage for terminal faults (kV peak)	
10	Rated characteristics for short line faults.	
11	Rated operating sequence	
12	Rated duration of short circuit(Sec.)	
13	Rated out of phase making & breaking current (kA)	

14	(a)Opening time (ms)	
	(i) Maximum Opening time under any condition.	
	(ii) With limiting Voltage & Pressure.	
	(b) Arcing time (ms)	
	(i) At 100% rated breaking current (ms)	
	(ii) At 50% rated breaking current (ms)	
	(iii) At 25% rated breaking current (ms)	
	(iv) At 10% rated breaking current (ms)	
	(v) Maximum arcing time at lowest fault current (ms)	
	(c) Break Time (ms)	
	(i) At 100% rated breaking current (ms)	
	(ii) At 50% rated breaking current (ms)	
	(iii) At 25% rated breaking current (ms)	
	(iv) At 10% rated breaking current (ms)	
	(v) Maximum break time at lowest fault current (ms).	
	(vi) Maximum Total Break Time under any duty condition For any	
	(d) Closing time (ms)	
	(e)Maximum Total Closing Time	
	(f)Minimum dead time for 3 phase reclosing	
	(g)Maximum Close Open Time under any condition With limiting Voltage & Pressure.	
	(h)Minimum Time Interval between each make / Break Operation.	
15	Rated line charging breaking current (kA)	
16	Rated small inductive breaking current (kA)	
17	(i)Max. Rise of temperature over ambient for current rating under sl. 6.	
	(ii)Max. rise of temperature for Main contacts over design ambient temperature of 50 °C.	
18	Interrupting capacity based on duty cycle as per sl. 11.	
	(a) AC ;component (kA)	
	(b) Percentage DC component.	
19	Latching current (kA)	
20	No. of breaks in series per pole.	
21	Length of contact travel (mm)	
22	Total length of break per pole (mm)	

23	Rate of contact travel:	
	(a) At tripping (metres/sec.)	
	(b) At closing (metres/sec.)	
24	Type of devices, if any, used to obtain uniform voltage distribution between breaks.	
25	Recovery voltage distribution between breaks in per cent of rated voltage.	
	(a) Single line to ground fault	
	(b) Interruption on short lines.	
	(c) Switching off an unloaded, transformer	
26	(i) Type of main contact.	
	(ii) Number of auxiliary contacts per pole for normal operation(NO & NC)	
	(iii) Number of auxiliary contacts per pole provided for Owner's use(NO & NC)	
	(iv) Current rating of Auxiliary contacts	
27	Type of arcing-contacts and/or arc control device	
28	Material of contacts:	
	i. Main	
	ii. Arcing	
	iii. Whether contacts are silver plated	
	iv. Thickness of silver coating mm	
	v. Contact pressure, kg/sq.mm.	
29	Insulation level of the breaker:	
	(a) 1 minute power frequency withstand voltage kV rms(Dry & Wet)	
	(i) Between live terminals & Ground	
	(ii) Between terminals with Breaker contacts open	
	(b) Switching surge withstand test Voltage kV (peak) - To earth - Across open contacts	
	(c) Lightning impulse withstand test - To earth - Across open contacts-	
	(d) Max. dynamic power frequency over voltage withstand kV (peak)	
30	i) RIV level (Max.)	
	ii) Corona inception voltage (kV rms)	
	iii) Corona extinction voltage (kv rms.)	
31	Minimum clearances	
	(a) Between phases (live parts)(mm)	
	(b) Between live parts and earth (mm)	
	(c) Total Creepage Distance	
	(i) To ground (ii) Between terminals.	
32	Whether the circuit breaker is fixed trip or trip free	

33	Method of closing	
	(a) Normal	
	(b) Emergency	
34	Type of closing mechanism	
35	(a) Normal voltage of closing	
	b) Pick up range (volts DC)	
36	(a) Power at normal voltage of closing mechanism (watts)	
	(b) Power at 85% of normal voltage of closing mechanism(watts)	
	(c) No of closing coils in operation	
37	Type of tripping mechanism-Number of Tripping Coil	
38	(A) Normal voltage of tripping coils(volts)	
	(a) Power at normal voltage for Tripping coils (watts)	
	(b) Power at 70% normal voltage for Tripping coils (watts).	
	(c) No. of tripping coils in operation	
	(d) Pick up range (V DC)	
	(B) Number of close open operation	
	(i) possible after failure of AC supply to motor	
	(ii) Time required for motor to charge the closing spring(Sec)	
	(iii) Weather indication of spring charged condition will be provided in control cabinet.	
39	Arc duration at 100% (ms)	
40	Interruption capacity:	
	a). Opening-- Arcing time no. of loops and time including resistor current duration (cycle)	
	Resistor current duration (cycle)	
	Total length of the arc (mm)	
	Max. length of the arc (mm)	
	Total interrupting time measured from instant of trip coil energisation to arc extinction of resistor current (cycles).	
	b) Closing time measured from instant of application of power to closing device up to arcing contacts touching, (cycles).	
41	Critical current (current giving the longest	
	a) Recovery voltage when circuit breaker tested at 100% rated breaking capacity (kV inst.)	
	b) Rate of rise of re-striking voltage at breaking	
	i) for 30% breaking capacity (kV/micro secs.)	
	ii) for 100% breaking capacity (kV/ micro secs.)	
	c) Maximum over-voltage factor of the CB when switching off.	
	i) Unloaded transformers	
	ii) Loaded transformer	
	iii) Open circuited lines	
42	When switching of synchronous systems:	
	(a) Max. current (kA)	
	(b) Max. contacts of 1 pole (kV)	

43	No. of openings the circuit breaker is capable of performing without inspection, replacement of contacts or other main parts.	
	(a) at 50% rated current	
	(b) at 100% rated current	
	(c) at current corresponding to 50% rated breaking capacity.	
	(d) at current corresponding to 100% rated breaking capacity.	
44(A)	a) Weight of complete circuit breaker (Kg).	
	b) Impact loading for foundation design, to include dead load plus impact value on opening at maximum interrupting ratings, in terms of equivalent static load (Kg.)	
	c) Over dimensions	
	Height (mm)	
	Width (mm)	
	Length (mm)	
	(B)- Type & Material of Gasket used to ensure gas tight joints for	
	(i) Metal to Metal Joint	
	(ii) Metal to Porcelain Joints.	
	(C) Type & Make of	
	a) Density Monitor	
	b) Pressure Gauge.	
	(D) Density Monitor Setting	
	a) Lock Out	
	b) Alarm.	
45	Porcelain:	
	a) Make	
	b) Type	
	c) Descriptive pamphlet no.	
	d) Weight (kg.)	
	e) Transport dimensions (mm)	
	f) Height above floor, required to remove porcelain (mm).	
	g) Insulation class	
	h) One minute power frequency withstand, kV (rms) (dry & wet)	
	i) Flash over voltage (kV)	
	j) Lightning impulse withstand voltage kV (peak) (dry & wet)	
	k) Switching surge withstand voltage kV (peak) (wet)	
	l) Corona discharge voltage (kV rms)	
	m) Creepage distance, total protected (mm)	
	n) Permissible safe cantilever loading on installed porcelain (Kg.m)	
46	(i) Rated pressure of SF6 gas in the circuit breaker (Kg/sq.cm)	
	(ii) Rated Pressure of SF6 in operating Chamber(kg/cm ²) at 20° C	
	(iii) Limits of Pressure of extinguishing medium	
47	Rated pressure of SF6 gas in the gas cylinders (Kg/sq.cm)	
48	(i)Quantity of SF6 gas required per single pole unit (Kg.) at rated Pressure & at 20 deg C	
	(ii) Guaranteed Maximum Leakage rate per Year.	

49	Quantity of SF ₆ gas per cylinder (Kg.)	
	Standard to which SF ₆ Gas Complies.	
	(i) Weight of empty cylinder (Kg.)	
	(ii) Weather Breakers are dispatched filled with SF ₆ Gas or filled at	
50	Quantity of absorbent required per pole (Kg.)	
51	Recommended interval for renewal of absorbent in case of outdoor circuit breakers operating in tropical conditions.	
52	Chemical composition of absorbent	
53	Quantity of absorbent covered in the scope of supply (including	
54	Limits of gas pressure for pressure operation of circuit breaker	
55	Pressure and temperature at which the temperature compensated gas pressure switch will	
	(a) give alarm (Kg/sq.cm., deg. C)	
	(b) cut off (Kg/sq. cm, °C)	
56	Name of SF ₆ supplier and country of origin.	
57	Quantity of SF ₆ gas supplied for	
	a) Actual use in breakers (Kg.)	
	b) As spare (Kg.)	
58	Chemical composition of gas:	
	a) Qty. of air by weight (ppm)	
	b) Qty. of H ₂ O by weight (ppm)	
	c) Qty. of CF ₄ by weight (ppm)	
	d) Qty. of free acid by weight (ppm)	
	e) Density	
	f) Oil Content	
	g) Resistivity	
59	Motor For Circuit Breaker	
	(a) Manufacture's name & address	
	(b) Equipment driven by motor or not.	
	(c) Motor Type	
	(d) Country of Origin	
	(e) Type of Duty	
	(f) Type of Enclosure & Method of Cooling	
	(g) Applicable Standard to which motor confirms	
	(h) Type of mounting	
	(i) Direction of rotations as viewed from non-driving end.	
	(j) Standard Continuous rating at 50deg C	
	(k) Rated Voltage	
	(l) Rated Speed at rated Voltage & Frequency(rpm).	
	(m) Full Load current at rated voltage & frequency.	
	(n) Power Factor at rated load.	
	(o) Rating of the Motor.	
	(p)Time for fully charging the closing spring	
60	Control Cabinet	
	i. Material of enclosure	
	ii. Thickness of sheet steel	
	iii. Painting for control cubicle	
	iv. Paint shade	
	v. Degree of protection	
	vi. Dimension	
	vii. Material of gasket	

APPENDIX-I
SCHEDULE OF QUANTITY AND DELIVERY
CIRCUIT BREAKER

Sl. No.	Description of materials	Quantity in nos	Delivery period required in
1.	420 KV SF ₆ Circuit Breaker	05 Nos.	Within 04 months from the date of Issue of PO
2.		03 Nos.	04 months from 01.04.2017

N.B: The detail delivery programme & quantity to be delivered will be informed at the time of placing P.O / issue of release order.

END OF TENDER SPECIFICATION