

ODISHA POWER TRANSMISSION CORPORATION LIMITED

(A Government of Odisha Undertaking)

Registered Office: Janpath, Bhubaneswar-751022

OFFICE OF THE SR. GENERAL MANAGER (CPC)

Telephone No.0674-2541801 Fax No.0674-2542964

Corrigendum -1 to e-TENDER NOTICE NO-CPC-31/2016-17

SI no	DESCRIPTION	EXISTING SCHEDULE	REVISED SCHEDULE
1	Online request of tender document at www.tenderwizard.com./OPTCL	Up to dt.18.08.16 (13.00 hrs)	Up to dt.25.08.16 (13.00 hrs)
2	Last date & time of online submission of bid document	Up to dt.19.08.16 (13.00 hrs)	Up to dt.26.08.16 (13.00 hrs)
3	Date & time of online opening of Techno-Commercial bid	Date 20.08.2016 (15.00hrs)	Date 27.08.2016 (15.00hrs)

The Technical Specification has been corrected as mentioned below

At clause no. 1.3.1.1 of the T.S (mentioned as)	At clause no. 1.3.1.1 of the T.S (revised)
DG set net output after considering duration for engine and alternator separately due to temperature rise in side the enclosure and on account of power reduction due to auxiliaries shall be 82.5 kVA, 1500RPM, 0.8 Pf, 415V, 3-Phase, 50Hz. The above rating is the minimum requirements	DG set net output after considering de-rating for engine and alternator separately due to temperature rise in side the enclosure and on account of power reduction due to auxiliaries shall be 82.5 kVA, 1500RPM, 0.8 Pf, 415V, 3- Phase, 50Hz. The above rating is the minimum requirements

GUARANTED TECHNICAL PARTICULARS	
Alternator: Clause no. 5. (mentioned as)	Alternator: Clause no. 5 (Revised as)
Recommended Cable size x Runs (AL armoured 3 ½ core): 300 mm ²	Recommended Cable size x Runs (AL armoured 3 ½ core): 150 mm ²

All other terms & conditions of the tender remain unchanged.


 Sr. General Manager (CPC)