

**CORRIGENDUM NO.-3 TO NOTICE TO VENDORS,**  
**Notice No. Sr.GM-CPC-Vendor-14/2013**

1. The last date for receipt of application for vendor's registration is hereby extended up to 4p.m. of **Dt. 15.01.2014.**
2. The following item is included in the List of Items at **Annexure-C** of the Notice to Vendors, Notice No. Sr.GM-CPC-Vendor-14/2013.

**Item No. 35- Air Conditioner:** 5 Star rating as per BEE, Window/Split type air conditioner along with the required voltage stabilizer from reputed manufacturer having manufacturing base in India with the following specification.

- i) Voltage : a) 230 V  $\pm$  15% (1 AC supply of 50 Hz)  
b) 415 V  $\pm$  15% (3 AC supply of 50 Hz)
- ii) Capacity : a) 1 ton to 3 ton  
b) >3 ton
- iii) Standard: IS: 1391-1 / 1391-2

All other Items and sub-items at annexure-C of the notice to Vendors remain unchanged.

SR. GENERAL MANAGER[CPC]