

ଓଡ଼ିଶା ବିଦ୍ୟୁତ୍ ଶକ୍ତି ସଂଚାରଣ ନିଗମ ଲି.ଠ.
ODISHA POWER TRANSMISSION CORPORATION LTD.



(A Government of Odisha Undertaking)
Regd. Office: Janpath, Bhubaneswar-751022, Odisha
OFFICE OF THE GENERAL MANAGER: ELECT
EHT (O&M) CIRCLE: CHAINPAL, AT/PO: CHAINPAL COLONY,
DIST: ANGUL (ODISHA), Pin-759104, [Email-ehm.cle.chp@optcl.co.in](mailto:email-ehm.cle.chp@optcl.co.in)
CIN: U40102OR2004SG C007553

Ltr No. 102

Date: 01.03.24

CORRIGENDUM-01
Open Tender No. 05/2023-24

Technical specification for 400 KV system against open tender No.05/2023-24 for Supply of FRP Earth discharge rod of different voltage class for the different Grid Sub-Stations under EHT (O & M) Circle, Chainpal is modified as follows.

SPECIFICATION OF 400 kV FRP Telescopic Earthing / Discharge Rod

1. Total Section:3
2. Assemble Height: 18 Ft.
3. System Suitability : 400 kV
4. Type Tested : 630 kV ERDA Vadodara
5. Make- E-safe/BEIMCO or Any Reputed make with Flexible Single core Transparent Copper Earthing conductor 35sq.mm of 15 meter length and Die Cast Aluminium Grounding "C" Clamp(1 No.)
6. Locking: Coupler type locking system with infinite locking
7. Clamping capacity for 6 no's of discharge Rod is 38mm to 116mm and rest 6 no's of discharge rod is up to 38 mm.

Yours Faithfully,


Sr.General Manager (Elect.)
EHT (O & M) Circle, Chainpal