



# ଓଡ଼ିଶା ବିଦ୍ୟୁତ୍ ଶକ୍ତି ସଂଚାରଣ ନିଗମ ଲିମିଟେଡ

## ODISHA POWER TRANSMISSION CORPORATION LIMITED

REGD OFFICE : JANAPATH , BHUBANESWAR-751022, PH- 0674- 2547185, Fax: 2540016  
OFFICE OF SR GENERAL MANAGER(S&S),GROUND FLOOR,FINANCE BUILDING, BHOINAGAR, BHUBANESWAR  
email: sto.cle.bbs@optcl.co.in

No. W1-266/2017 - 45

dt. 23.02.2023


### CORRIGENDUM No-01 TENDER NOTICE NO. SRGM(S&S)- 04 /2022-23

**Sub: Revision of description of material in "Schedule of Price" ( Annexure-IV) at Sl. No. 1,3 & 4 in the Tender Notice No. SRGM(S&S)- 04 / 2022-23.**

Sl. No- 1,3 & 4 in "Schedule of Price" (Annexure-IV) of Tender Notice No. SRGM(S&S)- 04 / 2022-23 is hereby revised as below :

Sl. No. in Schedule of price	Tender Specification No.	Existing	Revised
1.	SRGM(S&S)-04 / 2022-23	Supply of 9 Mtr. high Octagonal pole having bottom/top 150mm/100mm, 3mm thick base plate 300x300x16mm, PCD 300mm.	Supply of 9 Mtr. high <b>galvanized Octagonal pole</b> having bottom/top 150mm/100mm,3mmthick base plate 300x300x16mm,PCD 300mm.
3.		Construction of shallow foundation with M20 grade concrete for the 9 mtr highmast including foundation bolts manufactured from steel alongwith nuts, washers, anchor plate and common template with all materials and labour.	Construction of shallow foundation with M20 grade concrete for the 9 mtr highmast including <b>galvanized</b> foundation bolts, nuts, washers, anchor plate and common template with all materials and labour.
4.		Erection, Testing & commissioning of the octagonal pole along with fixation of flood light with the help of suitable tools and plants, wiring of luminaires with all wiring materials like PVC insulated PVC sheathed flexible cable of suitable copper conductor of 3 cores of 1.5 sq. mm, lugs, MCB and all labour.	Erection, Testing & commissioning of the <b>galvanized Octagonal pole</b> along with fixation of flood light with the help of suitable tools and plants, wiring of luminaires with all wiring materials like PVC insulated PVC sheathed flexible cable of suitable copper conductor of 3 cores of 1.5 sq. mm, lugs, MCB and all labour.

Other Terms & Conditions of the Tender Notice No. SRGM(S&S)- 04 / 2022-23 remain unaltered.

  
23/02/2023,  
SR. GENERAL MANAGER [S&S.]  
OPTCL, BHUBANESWAR

CC to

- CGM(IT),OPTCL for kind information & necessary action. He is requested to hoist the Corrigendum to tender notice in the OPTCL website for wide circulation.