



# ରାଜ୍ୟ ବିଦ୍ୟୁତ୍ ଭାର ପ୍ରେରଣ କେନ୍ଦ୍ର

STATE LOAD DESPATCH CENTRE

ODISHA POWER TRANSMISSION CORPORATION LIMITED

GRIDCO Colony, P.O.- Mancheswar Rly. Colony, Bhubaneswar-17, FAX-0674- 2748509

CIN: U40102OR2004SGC007553

## CORRIGENDUM – IV to TENDER NOTICE NO. SLDC-02/2023-24

### TENDER NOTICE NO. SLDC-02/2023-24

***“Design, Development, Supply, Installation, Testing & Commissioning of 0.2S Accuracy Class AC Tri Vector ABT compliant Energy Meters, AMR (CDCS-MDAS) Software (at DC & DR) along with DCU and associated hardware and Comprehensive AMC for AMR Solution & Energy meters for State Load Despatch Center, OPTCL, Odisha.”***

Following modifications are made in respect of the TENDER NOTICE NO. SLDC-02/2023-24. The bidders are requested to go through these amended clauses before submission of the bid.

The bidders who have already submitted the tender documents in the tender portal are hereby requested to resubmit the bid as per the amended clauses of this corrigendum notice. The bids submitted earlier to publication of this corrigendum shall not be considered for technical bid evaluation.

### **Part-I - SECTION IV: SCOPE OF WORK**

#### **Clause No. 1 DETAILED SCOPE OF WORK:**

h) Providing Technical support for AMR solution software so as to run the system up to specified availability requirement for six years, one year free of cost after Go-live of project and next five years under Annual technical support/ AMC contract.

### **Part-I-Section V (Technical Specifications)**

#### **Clause No. 2.11 GUARANTEE**

Equipment (Meter) and its accessories like meter reading data cable etc. supplied shall be guaranteed for a period of 60 (sixty) months from the date of installation and commissioning of any integral part of the Equipment/ Materials. Bidders shall guarantee to repair or replace the meters and its accessories like meter reading cord and meter racks (if supplied), which are found to be defective/ inoperative at the time of installation as well as during guarantee period. Replacements shall be affected within 1 (one) month from the date of intimation.

**Part-I-SECTION –VI-A: COMPREHENSIVE ANNUAL MAINTENANCE CONTRACT FOR AMR AND HARDWARE**

**Clause No. 8. System availability**

The nature and maintenance support required for systems and components are described below:

Table 25: System availability

Sl. No.	System	System Availability requirements
1	ABT Meters data at user end	100%
2	AMR Solution Software	99%

**Note:** Availability shall be calculated on the basis of cumulative running hours of individual items quarterly.

Bidder will be responsible for coordination with the OEM for all matter related to that equipment (Hardware & Software). The bidder will also be responsible for meeting the overall response times and availability requirements as specified in the specification. The maintenance of the System will be comprehensive and will comprise of the following category of works which is further elaborated for each of the different subsystems:

- i. Preventive Maintenance Activity (performance monitoring, system backup, patch management, updates, emergency response and troubleshooting)
- ii. Maintaining adequate no. of spares
- iii. Integration of new module/equipment etc.

Sd/-

**Director (SLDC)**