

# ଓଡ଼ିଶା ଶକ୍ତି ସଂଚାରଣ ନିଗମ ଲିଡ.

ODISHA POWER TRANSMISSION CORPORATION LIMITED

CIN - U40102OR2004SGC007553

(A GOVERNMENT OF ODISHA UNDER TAKING)

OFFICE OF THE GENERAL MANAGER,

EHT (O&M) CIRCLE, BHUBANESWAR

AT: GRID SUB-STATION, CHANDAKA, PO- KIIT, BBSR-751024

E-mail-ehm.cle.bbs@optcl.co.in

OPEN TENDER CALL NOTICE NO. 03/BBS/2018-19



Sealed tenders are invited from the eligible bidders for the following work:

**OTCN- 03/BBS/2018-19: Procurement of CT Console Boxes & BMKs (Bay Marshalling Kiosk) including wiring and testing for new 3<sup>rd</sup> TFR-Bay at Grid S/S, Chandpur” under EHT (O&M) Division, Khurda** Experienced Bidders fulfilling the qualifying criteria and possessing, valid I.T. Pan Card/GST registration certificates/ authorized dealership Certificate are only eligible to participate.

The detail tender specifications can be obtained from the office of the undersigned, on payment of dues (non refundable) as mentioned below during office hours on working days in shape of DD drawn in favour of **EHT (O&M) Circle, OPTCL, Bhubaneswar, Payable at Bhubaneswar** from Dt 09.05.2018 to Dt 21.05.2018. The tenders shall be received up to 3 P.M. on Dt 22.05.2018 and will be opened at 3.30P.M.on the same date in the office of the undersigned in presence of the authorized representatives of the bidders if any. EMD @ 1% of the Quoted value is to be submitted in shape of DD drawn in favour of EHT (O&M), Circle, OPTCL, Bhubaneswar, payable at Bhubaneswar.

The tender without requisite amount of EMD will be rejected.

This office will not be responsible for non-receipt / late receipt of tender document due to postal delay. All other terms and conditions of OPTCL purchase & contract regulation will also be applicable to the successful bidders while placing the work/ purchase order.

The undersigned reserves the right to reject any or all the tenders without assigning any reason thereof.

SL No	Name of the item	Cost of tender specification	Eligibility Criteria for bidders																																																																																
1	<p><b>OTCN-03/BBS/2018-19</b></p> <p><b>Procurement of CT Console Boxes &amp; BMKs (Bay Marshalling Kiosk) including wiring and testing for new 3<sup>rd</sup> TFR-Bay at Grid S/S, Chandpur” under EHT (O&amp;M) Division, Khurda</b></p> <table border="1"> <thead> <tr> <th>Sl No</th> <th>Description of Materials</th> <th>Unit</th> <th>Qty</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>132 KV &amp; 33 KV CT console Box with disconnecting type TB including wiring and testing</td> <td>Nos.</td> <td>2</td> </tr> <tr> <td>2</td> <td>132 KV &amp; 33 KV BMK with wiring and testing</td> <td>Nos.</td> <td>2</td> </tr> <tr> <td colspan="4"><b>Materials to be supplied in BMK</b></td> </tr> <tr> <td>i</td> <td>Bulb Holder with bucket</td> <td>Nos.</td> <td>2</td> </tr> <tr> <td>ii</td> <td>Door lamp (LED,12W,220V AC)</td> <td>Nos.</td> <td>2</td> </tr> <tr> <td>iii</td> <td>PB for Door Lamp (NC, Refrig Switch)</td> <td>Nos.</td> <td>2</td> </tr> <tr> <td>iv</td> <td>Space Heater(100W,230 V AC)</td> <td>Nos.</td> <td>1</td> </tr> <tr> <td>v</td> <td>HRC Fuse (6A,415 V AC,Clip ON)</td> <td>Nos.</td> <td>3</td> </tr> <tr> <td>vi</td> <td>Fuse Base (32 A, 550 V AC)</td> <td>Nos.</td> <td>3</td> </tr> <tr> <td>vii</td> <td>Clustered LED Assembly ( 240 V AC,22.5 MM RED)</td> <td>Nos.</td> <td>2</td> </tr> <tr> <td>viii</td> <td>Contactactor (3P,70A,240V AC Coil, 1 NO+1 NC)</td> <td>Nos.</td> <td>2</td> </tr> <tr> <td>ix</td> <td>Contactactor (10A, 240V AC Coil, 2 NO + 2NC)</td> <td>Nos.</td> <td>1</td> </tr> <tr> <td>x</td> <td>Disconnecting type Neutral Link (15A)</td> <td>Nos.</td> <td>2</td> </tr> <tr> <td>xi</td> <td>Terminal Block (57A)</td> <td>Nos.</td> <td>56</td> </tr> <tr> <td>xii</td> <td>Terminal Block (76A)</td> <td>Nos.</td> <td>8</td> </tr> <tr> <td>xiii</td> <td>MCB (63A, TPN,10KA, AC,C-Curve)</td> <td>Nos.</td> <td>2</td> </tr> <tr> <td>xiv</td> <td>MCB (16A, TPN, 10KA, AC, C-Curve)</td> <td>Nos.</td> <td>10</td> </tr> <tr> <td>xv</td> <td>MCB (10A, 2P, 10KA, AC, C-Curve)</td> <td>Nos.</td> <td>9</td> </tr> <tr> <td>xvi</td> <td>MCB (6A, 2P, 10KA, AC, C Curve)</td> <td>Nos.</td> <td>4</td> </tr> </tbody> </table>	Sl No	Description of Materials	Unit	Qty	1	132 KV & 33 KV CT console Box with disconnecting type TB including wiring and testing	Nos.	2	2	132 KV & 33 KV BMK with wiring and testing	Nos.	2	<b>Materials to be supplied in BMK</b>				i	Bulb Holder with bucket	Nos.	2	ii	Door lamp (LED,12W,220V AC)	Nos.	2	iii	PB for Door Lamp (NC, Refrig Switch)	Nos.	2	iv	Space Heater(100W,230 V AC)	Nos.	1	v	HRC Fuse (6A,415 V AC,Clip ON)	Nos.	3	vi	Fuse Base (32 A, 550 V AC)	Nos.	3	vii	Clustered LED Assembly ( 240 V AC,22.5 MM RED)	Nos.	2	viii	Contactactor (3P,70A,240V AC Coil, 1 NO+1 NC)	Nos.	2	ix	Contactactor (10A, 240V AC Coil, 2 NO + 2NC)	Nos.	1	x	Disconnecting type Neutral Link (15A)	Nos.	2	xi	Terminal Block (57A)	Nos.	56	xii	Terminal Block (76A)	Nos.	8	xiii	MCB (63A, TPN,10KA, AC,C-Curve)	Nos.	2	xiv	MCB (16A, TPN, 10KA, AC, C-Curve)	Nos.	10	xv	MCB (10A, 2P, 10KA, AC, C-Curve)	Nos.	9	xvi	MCB (6A, 2P, 10KA, AC, C Curve)	Nos.	4	<p><b>1. Rs 2,240/-</b> (Cost of paper <b>Rs 2,000/- + GST @ 12%</b> i.e 240/-) <b>(Non-refundable) in shape of DD only.</b></p> <p><b>2. EMD @ 1% of quoted value in shape of DD only</b></p>	<p><b>Experienced Bidders fulfilling the qualifying criteria and possessing valid I.T. Pan Card/GST registration certificate/ authorized dealership certificate.</b></p>
Sl No	Description of Materials	Unit	Qty																																																																																
1	132 KV & 33 KV CT console Box with disconnecting type TB including wiring and testing	Nos.	2																																																																																
2	132 KV & 33 KV BMK with wiring and testing	Nos.	2																																																																																
<b>Materials to be supplied in BMK</b>																																																																																			
i	Bulb Holder with bucket	Nos.	2																																																																																
ii	Door lamp (LED,12W,220V AC)	Nos.	2																																																																																
iii	PB for Door Lamp (NC, Refrig Switch)	Nos.	2																																																																																
iv	Space Heater(100W,230 V AC)	Nos.	1																																																																																
v	HRC Fuse (6A,415 V AC,Clip ON)	Nos.	3																																																																																
vi	Fuse Base (32 A, 550 V AC)	Nos.	3																																																																																
vii	Clustered LED Assembly ( 240 V AC,22.5 MM RED)	Nos.	2																																																																																
viii	Contactactor (3P,70A,240V AC Coil, 1 NO+1 NC)	Nos.	2																																																																																
ix	Contactactor (10A, 240V AC Coil, 2 NO + 2NC)	Nos.	1																																																																																
x	Disconnecting type Neutral Link (15A)	Nos.	2																																																																																
xi	Terminal Block (57A)	Nos.	56																																																																																
xii	Terminal Block (76A)	Nos.	8																																																																																
xiii	MCB (63A, TPN,10KA, AC,C-Curve)	Nos.	2																																																																																
xiv	MCB (16A, TPN, 10KA, AC, C-Curve)	Nos.	10																																																																																
xv	MCB (10A, 2P, 10KA, AC, C-Curve)	Nos.	9																																																																																
xvi	MCB (6A, 2P, 10KA, AC, C Curve)	Nos.	4																																																																																

xv	<i>Toggle Switch (PM, SPST-ON/OFF, 10A)</i>	Nos.	1		
xvi	<i>Gang Box Domestic ( 2 SW + 1 Socket)</i>	Nos.	1		
xvii	<i>Timer ((0.1 s to 10 Hr),2C/O-24V-240V-240V AC/DC)</i>	Nos.	1		
xviii	<i>Thermostat((30-85°C), 15A,250V AC, 1 NC + )</i>	Nos.	1		
xix	<i>Terminal Block (44A)</i>	Nos.	300		
xx	<i>BMK Panel powder coating.</i>	Nos.	1		

**Sd/-**  
**GENERAL MANAGER**  
**EHT (O&M), Circle, Bhubaneswar**