

ଓଡ଼ିଶା ବିଦ୍ୟୁତ ଶକ୍ତି ସଂଚାରଣ ନିଗମ ଲିଡ.



ODISHA POWER TRANSMISSION CORPORATION LIMITED

(A Government of Odisha Undertaking)

CIN: U40102OR2004SGC007553

Regd. Office: Janpath, Bhubaneswar-751022.

O/O - Deputy General Manager (Electrical)

E.H.T. (O&M) Division, Laltikra, Bolangir – 767002, Tel No-06652-250449

E.mail ID-ehtm.div.blh@optcl.co.in

TENDER CALL NOTICE NO. 16/ 2018-1

Sealed Tenders in duplicate are invited by the undersigned from Manufacturer /40MVA, 132/33Kv Power Transformer repairing firm having valid HT Contractor License, with PAN, Goods and Service Tax Registration for **“Repairing & reconditioning of 40 MVA, 132/33 KV BBL make Power Transformer at 132/33kv grid s/s, Sonepur (on-site)”** as per details in tender specification. The tender paper will be available in the office of the undersigned on payment of **Rs.4480/- (Rupees Four thousands four hundred Eighty) Only** (Non-refundable) towards cost of Tender paper in shape of cash on any working day from **Dt.15.02.2019 to Dt.01.03.2019 during office hour.**

The Tender shall be received Up to 01.30 PM of dated -02.03.2019 & will be opened at 4.00PM Hours of same day in the Office of the undersigned in the presence of the Bidders (or) their Authorized Representatives present if any. If any of the above date happens to be a holiday, the next working day will be the corresponding effective date. Two sets (Original & Duplicate copy) of Tender paper shall be issued to one Bidder. E.M.D =**Rs.9770.00** (1% of estimated cost) should be deposited in shape of Demand Draft / Cash in favour of DGM, E.H.T. (O&M) Division, Bolangir & payable at Bolangir in any Branch of nationalized bank. Self Attested photocopy of PAN, HT license, Goods and Service Tax Registration Certificate should be submitted in between above said period along with tender papers & DD/Original money receipt failing which the tender will be liable for rejection.

STARTING DATE OF SALE OF TENDER PAPER:-DT. 15.02.2019

LAST DATE SALE OF TENDER PAPER:-DT. 01.03.2019 (17.00Hrs)

LAST DATE OF SUBMISSION OF TENDER:-DT. 02.03.2019 UP TO 13.30HRS.

DATE OF OPPENING OF TENDER:-DT. 02.03.2019 AT 16.00HRS.

The tenderer should be superscribed only the **“Tender Call Notice No. & Date of Opening of the tender on the body of the Sealed Envelope”**. Bidder should not write their name or any other information on the body of the sealed envelope. Superscribing any other information on the body of the envelop, conditional tender, incomplete tender, Telegraphic / Fax / E-mail (etc.) Tenders & Tenders not accompanied with requisite amount of E.M.D. will be rejected. The authority reserves all rights to reject any, all or part of the Tender, alter/modify the requirement/ delete any part of the tender without assigning any reason thereof.

Si No	Description of works	Unit	Quantity
1	Dismantling of all accessories of 40MVA, 132/33Kv BBL make Power Transformer having Si no-3711/1 with supply of labour & T&P	no	1
2	Erection of the 40MVA transformer with assembling of all accessories after removal of sludge & replacement of gaskets with supply of labour & T&P	No	1
3	Dismantling of main tank cover & assembling after fixing of Gasket with supply of labour & T&P	Lot	1
4	Sludge removal from main tank with supply of labour & T&P	lot	1
5	Oil filtration of the 40MVA Power Transformer with supply of labour & T&P	Per Trf.	1
6	OLTC Overhauling with supply of labour & T&P	No	1
7	Supply of all Gaskets as required of any reputed brand	lot	1
8	While Replacement of Transformer Bushing ,wrapping of insulating materials in 3phase leads to bushings by insulating tape ,all labours ,T&P as per instruction of EIC	lot	1
9	Vacuum Treatment to dry out the winding of the transformer winding & Nitrogen treatment ,Due point measurement & heat treatment with supply of vacuum pump, T&P, consumables and labour as required (4/5 cycles of treatment)	Lot	1
10	Painting of the 40MVA TFR and accessories-scraping, washing and painting by applying one coat bison zone Phosphate primer of Asian/Berger make,2nd coat of primer to be applied with high build M-10 sand witch coat over the primer coat and final two coats of painting with Berger/Asian make high glossy Luxol or equivalent enamel paint of BS gray over the sand witch coat with supply of all materials, consumable, T&P as per instruction of EIC.	Sq.Mtr	545

ARneetha
13/02/2019

Deputy General Manager (Elect.)
EHT(O&M) Division, Bolangir