



ODISHA POWER TRANSMISSION CORPORATION LTD.

O/O: G.M. (ELECT.) E.H.T. (O&M) CIRCLE, BURLA,
DIST: SAMBALPUR (ODISHA) 768017

Corrigendum –I to TENDER NOTICE NO. 12/ 15-16

With reference to Tender call notice no. 12/15-16 of this office, the following amendments are made.

The specification should be: 5 KVA stabilizers

Make- V guard, Voltas, Micro tech , Capri

1. Voltage range -180 volt to 300 volt
2. Output voltage 230AC.
3. With high and low voltage trip circuit.
4. Compact and modular construction for easy handling and servicing wall hanging
5. Single variac with buck boost transformer.
6. Digital Voltmeter to read input and output voltage.
7. MCB on input circuit.
8. Suitable power supply cord with output terminal connector

All other terms and conditions remains unaltered.

Before consideration of the price, the demo regarding voltage rating testing will be done at E.H.T. (O&M) Circle , Burla.

28-08-2015

General Manager (Elect.)
E.H.T. (O&M) Circle, Burla