

ODISHA POWER TRANSMISSION CORPORATION LIMITED

OFFICE OF THE DEPUTY GENERAL MANAGER (Elect.) EHT (O&M) DIVISION, KESINGA DIST-KALAHANDI, ODISHA, PIN-766012 Email Id: ehtm.div.ksn@optcl.co.in

TENDER CALL NOTICE-01/16-17

CORRIGENDUM NO- II

With reference to this Office Tender Call Notice No-1/2016-17 the bid, submission dates and Technical Specification are changed as follows, In place of existing entries, it may be read as,

1.Last date of Submission of Tender documents (bid sheet): Dt.08-11-2016 up to 12.00PM

2.Date of opening of Tender Paper: Dt.08-11-2016 at 3.00PM All the other term & conditions are remained un-changed.

Deputy General Manager (Elect.)

SECTION - III(PART-B)

TECHNICAL SPECIFICATION OF 22W LED BASED TUBULAR BAR:

- 1. 22W LED BASED T8 TUBULAR BAR COMPLETE FITTING
- INPUT VOLTAGE:150V-270V AC,
- POWER CONSUMPTION: 22 WATT INCLUDING DRIVER.
- FIXTURE: LIGHT WITH FITTING
- SIZE: TUBE LENGTH 1200 MM / 4 FIT, TYPE T8.(APPROX)
- **DRIVER**: INBUILT LED DRIVER
- COVER: BOTH SIDE POLYCARBONATE CAP.
- LENS: POLYCARBONATE DIFFUSER LENS.
- END CAP: END CAP SHOULD IS SUITABLE FOR REPLACEMENT WITH LINEAR FLUORESCENT TUBE. TYPE T8.
- MAKE OF LED: SYSKA/BAJAJ/PHILIPS
- COLOUR-COOL WHITE 6,000 TO 6,500 K.
- LUMINAS FLUX: NOT LESS THAN 1750 LUMEN
- POWER FACTOR :>= 0.9.
- DRIVER EFFICIENCY: 85%.
- SURGE PROTECTION: MINIMUM 2KV.
- MOUNTING: CAN BE FIXED DIRECTLY INTO THE EXISTING T8 CONVENTIONAL FIXTURE.
- CONFIRMATION TO STANDARDS: LM 80 TEST REPORT TO BE ADHERED BY THE LED CHIP MANUFACTURER.

(Luminary manufacturer has to submit authorization certificate from LED chip manufacturer like SYSKA, BAJAJ and Philips Lumi leds etc. along with type test certificate of Luminary without which their tenders will not be entertained.)

MAKE OF LUMINARY: Either of BAJAJ / CROMTON / PHILLIPS/ HAVELLS /SYSKA/INDIAN REPUTED MAKE