

RESPONSE TO PRE-BID QUERIES OF TENDER TW-IT-OT/02/2015-16 IT H/W S/W

Bidder # 1

SI No	Query	Response
1	Schedule – I UPS & Batteries	
1	Single Purchase order of ₹ 1 crore from Govt/PSU	Rectified in corrigendum
2	10 KVA UPS	
	Input parameters 3 phase 415 +25%, -30% frequency range 47 to 53 Hz	
	Power Factor Unity	
	Battery Isolation from DC bus	Original Specification stands
	Inverter Overload rating	Rectified in corrigendum
	Isolation	Original Specification stands
	Mechanical Parameters Castor wheels	Rectified in corrigendum
	Indication LED display	Original Specification stands
	Protection Reverse Phase Sequence	
	Metering Digital	
	Audible Alarm	
3	6 KVA UPS	Rectified in corrigendum
	Nominal Output Voltage	
	Overload AC mode	
	Overload Battery Mode	Original Specification stands
	Output Isolation Transformer	Rectified in corrigendum
	LCD display	
	Alarm	
	RoHS	
	Warranty	Original Specification stands

RESPONSE TO PRE-BID QUERIES OF TENDER TW-IT-OT/02/2015-16 IT H/W S/W

Bidder # 2

SI No	Query	Response
1	Schedule – I UPS & Batteries	
1	Single Purchase order of ₹ 1 crore from Govt/PSU	Rectified in corrigendum
2	30 KVA UPS	
	Extra Isolation Transformer at UPS unit or Inbuilt Isolation Transformer at Output	Rectified in corrigendum
	10 KVA UPS	
	Power Factor Unity	Rectified in Corrigendum

Bidder # 3

SI No	Query	Response
1	Schedule – I UPS & Batteries	
1	Single Purchase order of ₹ 1 crore from Govt/PSU	Rectified in corrigendum
2	10 KVA UPS	
	Isolation Transformer	Replied as above
	Built In parallel Redundancy	Rectified in corrigendum
	3 phase 415 +25%, -30% frequency range 47 to 53 Hz	
	LCD & LED Display	Rectified in corrigendum
	Reverse Phase Sequence	Original Specification stands
	Inverter Overload rating	Rectified in Corrigendum

RESPONSE TO PRE-BID QUERIES OF TENDER TW-IT-OT/02/2015-16 IT H/W S/W

Bidder # 4

SI No	Query	Response
1	Schedule – I UPS & Batteries	
2	600 VA UPS	
	Modified Sine wave	Rectified in Corrigendum
	Battery saver Button Optional	Optional feature
3	6 KVA UPS	
	VAC adjustable not understood make it no load shutdown	Adjustable at user end Original specification stands
	Input voltage range 160-280 is industry standard, in low voltage the battery will not charge	Original specification stands
	CE not required	Rectified in Corrigendum
	ROHS 7 not understood	
	UPS should be rack mountable and floor mountable	Original specification stands
	RS 232 interface + SNMP card to be provided mandatory (Part code should be mention)	The UPS brochure or the card itself should bear the sl no or item code of the card used
4	Spec brochure is not available	Original specification stands
5	Toll free 10am to 6 pm and then service engineer	
6	30 KVA UPS	
	DC bus voltage 480 v maximum	Rectified in Corrigendum
	Dual input not understood	

RESPONSE TO PRE-BID QUERIES OF TENDER TW-IT-OT/02/2015-16 IT H/W S/W

Bidder # 5

SI No	Query	Response
1	Schedule – I UPS & Batteries	
2	600 VA UPS	
	Voltage 230 V	Rectified in Corrigendum
	Power factor 0.6	
	Battery saver button as default	Original Specification stands
3	6 KVA UPS	
	Tower/ Rack 3U height convertible	
	Max configurable power 6000VA/ 5400W	
	Nominal output voltage 220/230/240 Adjustable	
	Efficiency at full load to be > 93.5 %	Rectified in Corrigendum
	Built In bypass and Manual bypass	
	Overload Capacity 105% for infinity & 150% for 30sec	
	Nominal input voltage 220/230/240 Adjustable	
	Input Voltage range for main operations	Original Specification stands
	Operating Environment 0-40	Rectified in Corrigendum
	CE not required as it is made in India	
	10 KVA UPS	
	Tower/ Rack 3U height convertible	Rectified in Corrigendum
	Input voltage Facility	Original Specification stands
	Rated Power to be 0.9 KW	Minimum 0.8 pf required
	Overload Capacity to be changed	
	Internal battery Charger should be 12Amp or higher	Compatible BC required
	CE certificate not required as it is made in India	
4	30 KVA UPS	
	DC Voltage bus to be less than 480 v	Rectified in Corrigendum
	Input Power factor to be changed	
	Output Ratings to be changed	

RESPONSE TO PRE-BID QUERIES OF TENDER TW-IT-OT/02/2015-16 IT H/W S/W

	Charging Current to be changed	
	efficiency @ full Load max 93 %	
	Overload Capacity to be changed	

Bidder # 6

SI No	Query	Response
1	Schedule – 2 Desktop PC & Laptop, Ultra thin	
	Desktop PC	
	Parallel port needs to be removed as its an obsoleted technology.	Rectified in Corrigendum
	Ultrathin Laptop	Original Specification stands
	Laptop	
	500GB @ 5400RPM Self-encrypting drive	
	Stereo headphone/mic combo jack; 1-USB 2.0	
	TPM 1.2 & Hard Drive Encryption to be removed else SED drives should be asked so that all OEM should have level ground for participation and for healthy competition.	Rectified in Corrigendum
	McAfee/ Norton Internet Security with 3-yr subscription	
	Energy Star 6.0; EPEAT should be there but EPEAT Gold Points 20 and above should be removed	Original Specification stands
	Scope should fall under partners as they can do it during installation	The bidder has to do on installation or pre-installation
	Green Guard and Green Peace should be removed	Original Specification stands

RESPONSE TO PRE-BID QUERIES OF TENDER TW-IT-OT/02/2015-16 IT H/W S/W

Bidder # 7

SI No	Query	Response
1	Schedule – 2 Desktop PC & Laptop, Ultra thin	
	Desktop Virtualisation	
	Win 8.1 preloaded to Embedded Linux	Rectified in Corrigendum
	Supported OS connector Embedded Linux to Win 8.1	

Bidder # 8

SI No	Query	Response
1	All Schedule	
	Bidder's Average Annual TO instead of Minimum Annual turnover for each of FYR 2011,2011-12,2012-13	Rectified in Corrigendum
	Schedule – I UPS & Batteries	
	Queries on 600 Va, 6KVA, 10 KVA , 30 KVA UPS	Already responded in earlier queries above
	Schedule- 3 Printers & scanners	
	Multi Function Printer	
	Print Speed	Original Specification stands
	First Page out As fast as 6 sec	Min 6 secs
	Processor Speed 350 MHz	Rectified in Corrigendum
	Memory 256 mb	
	Scan resolution 9600x9600dpi	9600 dpi is software enhanced not optical So original Specification stands
	FAX memory Up to 256 pages	256 is Inclusive in the original specification

RESPONSE TO PRE-BID QUERIES OF TENDER TW-IT-OT/02/2015-16 IT H/W S/W

	FAX max number 100 numbers	100 nos is Inclusive in the original specification
	Warranty structure ??	The 3 years warranty shall cover 3 years warranty on warranty covered Parts /spares replacement, on 3 years free engineer / labour personnel service support, on 3 years free on-site service support.