



ODISHA POWER TRANSMISSION CORPORATION LIMITED

(A Government of Odisha Undertaking)

Odisha Distribution System Strengthening Project (ODSSP)

O/O Project Management Unit - 33/11kV

(Room No- 304, Finance Wing, OPTCL Hqrs., dssp@optcl.co.in)

Er. Nilamber Dash, Project Manager
Mobile- 943890 8105

EPBX- 2322
Tel/Fax-0674-2543261

OPTCL/ODSSP/Phase-II-R/ 44/2014 / 1213

Dt. 16.10.14

Ammendment-01

T.O. Tender notice no. - NIT/ ODSSP/ OPTCL/08 (Phase-II-R), Date-
12.09.2014

1. In the GCC (Supply & Erection) the word ""Feeder"" shall be read as "Substation" and the words "Agriculture & Fishery Feeder(s)" shall be read as "Substation with Associated Lines".
2. In GTP No- 41(33kV 3Core 50 sqmm Armoured Cable) Type of material for Insulation Screening shall be "**Semiconductor XLPE + Cupper Tape**" in place of "Semiconductor XLPE" and Thickness of Copper tape with 50% overlap is 0.3mm.

Nilamber Dash
16.10.14

Project Manager
Project Management Unit-33/11 kV,
OPTCL, Bhubaneswar