

ଓଡ଼ିଶା ବିଦ୍ୟୁତ ଶକ୍ତି ସଂଚାରଣ ନିଗମ ଲିଡ.

ODISHA POWER TRANSMISSION CORPORATION LIMITED

(A Government of Odisha Undertaking)

E. H. T. (O & M) CIRCLE, BALANGIR

AT/P.O. – Sadeipali, Dist- Balangir - 767065

E-mail ID:- ehtm.cle.bln@optcl.co.in

1st CORRIGENDUM TO E-TENDER CALL NOTICE No. : BLN-06/2022-23

The date & time of submission & opening of e-Tender call notice No. : **BLN-06/2022-23** is hereby extended as follows;

- 1) Last date of submission of online tender : Upto Dt. 13.12.2022 (16:30 Hrs.)
- 2) Date of opening of Techno-commercial bid : On Dt. 14.12.2022 (12:30 Hrs.)


Further, the Technical specification (Section-IV) of the tender specification is revised as details below;

- 1) **ACDB Incomer-I, II & Bus Coupler** : 1600 Amp ACB is to be replaced with 800 Amp ACB with under voltage coil operating with 230 V AC and Close/ Trip coil with 220 V DC.
- 2) Auxiliary relays in ACDB is to be replaced by numerical relays for supporting SAS.
- 3) DCDB for 220 V DC is to be provided with additional 02 sets Current & Voltage transducer whose output current will be 4-20 mA.

As the technical specification is changed, the price bid has been revised accordingly. The tenderers who have already submitted their price bid, they are requested to resubmit the price bid.

All other terms & conditions will remain un-altered.

N.B:- All subsequent addendums/corrigendum to the e-tender shall be hosted in the OPTCL's official web site <http://www.optcl.co.in> and www.tenderwizard.com/OPTCL only.


General Manager (Ele.)
EHT (O&M) Circle, Bolangir.