

ଓଡ଼ିଶା ବିଦ୍ୟୁତ ଶକ୍ତି ସଂଚାରଣ ନିଗମ ଲିଡ.

ODISHA POWER TRANSMISSION CORPORATION LTD.

O/O : G.M. (ELECT.) E.H.T. (O&M) CIRCLE, BURLA,

DIST: SAMBALPUR (ODISHA) 768017

CORRIGENDUM TO E-TENDER CALL NOTICE NO. BRL-15/2024-25

NO.- EHTM/BRL/e-TENDER/ 1247

DATE: 22.10.2024

CORRIGENDUM

With reference to the E-Tender call notice No. BRL-15/2024-25, the last date of sale, receipt and opening of tender paper is hereby extended as given below. Also the tender specification has been updated as follows.

Date of Sale of Tender Paper	:	Up to 29.10.2024 at www.tenderwizard.com/OPTCL
Last Date & time of receipt of Tender Documents	:	30.10.2024 up to 01:00 PM at EHT (O&M) Circle, Burla.
Date of Opening of Tender Paper (Technical Bid only)	:	On 30.10.2024 at 4:00 PM
Date of Opening of financial bid (Those who have qualified in technical bid only)	:	Will be intimated later those who have qualified in technical bid.


TECHNICAL SPECIFICATION

400KV Discharge Rod		
1.	Material	FRP PPULTRUDED
2.	Surface	SMOOTH AND GLOSSY
3.	Total section	3 section
4.	Stick Design	CIRCULAR DESIGN
5.	Locking	PUSH BUTTON TYPE LOCKING TYPE
6.	Assembled Length	18 FEET
7.	Insulator	TOP & BOTTOM SECTION PROVIDED WITH SAFE GUARD
8.	H.V Test	630KV (Type test) from ERDA or any accredited laboratories
9.	Standard	IEC 60060
10.	Glass content	60%
11.	Top section dia	38MM
12.	Bottom section dia	38MM
13.	Grip	RUBBER GRIP
14.	Earthing cable (PVC insulated)	ISI mark PVC insulated multi stranded 440/1100V - grade transparent copper cable. Copper-35mm ² , 15 meters.

220KV Discharge Rod		
1.	Material	FRP PPULTRUDED
2.	Surface	SMOOTH AND GLOSSY
3.	Total section	3 Section
4.	Design	PUSH BUTTON TYPE
5.	Locking	PUSH BUTTON TYPE LOCKING TYPE
6.	Assembled Length	18 FEET
7.	Insulator	TOP & BOTTOM SECTION PROVIDED WITH SAFE GUARD
8.	H.V Test	510KV (Type test) from ERDA or any accredited laboratories
9.	Standard	IEC 60060
10.	Glass content	60%
11.	Top section dia	38MM
12.	Bottom section dia	38MM
13.	Grip	RUBBER GRIP
14.	Earthing cable (PVC insulated)	ISI mark PVC insulated multi stranded 440/1100V - grade transparent copper cable. Copper-35mm ² , 15 meters

All other terms & conditions will remain constant.

N.B:- All subsequent addendums/corrigendum to the tender shall be hosted in the OPTCL's official web site <http://www.optcl.co.in>.


General Manager (Elect.)
E.H.T. (O&M) Circle, Burla