



**ODISHA POWER TRANSMISSION CORPORATION LIMITED**

# **TECHNICAL SPECIFICATION**

**FOR**

**390KV,216KV, 120KV & 30KV SURGE  
ARRESTER**

**I- 390 KV**

**II- 216KV**

**III- 120KV**

**IV- 30KV**

**TECHNICAL SPECIFICATION FOR SURGE ARRESTERS  
FOR 400 KV,220 KV, 132KV & 33KV SYSTEMS.  
CONTENTS**

CLAUSE NO	T I T L E
1.0	SCOPE
2.0	STANDARDS
3.0	GENERAL TECHNICAL REQUIREMENTS
4.0	CONSTRUCTION
5.0	TESTS
6.0	INSPECTION
7.0	QUALITY ASSURANCE PLAN
8.0	DOCUMENTATION
9.00	PACKING & FORWARDING
10.0	QUANTITY & DELIVERY REQUIREMENT

APPENDIX – I	TECHNICAL REQUIREMENTS
--------------	------------------------

ANNEXURES	
A	GUARANTEED TECHNICAL PARTICULARS
B	CHECK – LIST
C	CALIBRATION STATUS OF TESTING EQUIPMENTS/METERS
D	CHECK-LIST TOWARDS TYPE TEST REPOR

# TECHNICAL SPECIFICATION FOR SURGE ARRESTERS FOR 400KV, 220KV, 132KV & 33KV SYSTEMS

## 1.0 SCOPE :

1.1 This Specification provides for the design, manufacture, inspection and testing before despatch, packing and delivery F.O.R. (destination) of metal oxide (gapless) Surge Arresters with discharge counters, insulating base, terminal connectors and other accessories as specified here in.

Following is the list of documents constituting this Specification. :

(i)	Technical Specification (TS)	
(ii)	Technical Requirements.	Appendix-I
(iii)	Quantity and delivery schedule.	Appendix-II
(iv)	Guaranteed Technical Particulars	Annexure-A
(v)	Check-List.	Annexure-B
(vi)	Calibration Status of testing equipments and meters/Instruments.	Annexure-C
(vii)	Check-list towards Type Test Reports.	Annexure-D
Note : Annexure-A,B,C,& D are to be filled up by the Bidder.		

1.1 All the above along with amendments thereof shall be read and interpreted together. However, in case of a contradiction between the Technical Specification and any other volume, the provisions of this volume will prevail.

1.2 The Surge Arrester shall conform in all respects to high standards of engineering, design, workmanship and latest revisions of relevant standards at the time of offer and purchaser shall have the power to reject any work or materials, which in his judgement is not in full accordance therewith.

## 2.0 **STANDARDS:-**

**2.1 Except to the extent modified in the Specification, the Surge Arrester shall conform to the latest editions and amendments of the standards listed hereunder.**

Sl. No.	Standard Ref. No.	Title.
1	IEC-99-4	Specification for Surge Arresters without gap for AC System.
2	IS:2147	Degree of protection, provided by enclosures for low voltage switchgear and control.
3	IS:2629	Recommended practice for hot dip galvanization of iron and steel.
4	IS:2633	Method for testing uniformity of coating on zinc coated articles.
5	IS:3070	Specification for surge arresters for alternating current system.
6	IS:5621 & IEC-621155	Specification for large hollow porcelain for use in electrical installation.
7	IEC-60-1	High-Voltage Test technique.
8	IEC-270	Partial discharge measurements.
9	IEC-99-1	Non-linear resistor type gapped arresters for a.c. systems.
10		Indian Electricity Rules, 1956.
11.	IEC-60815	Shed profile of hollow porcelain Insulator.

2.2 Surge Arresters with the requirement of other authoritative standards, which ensure equal or better quality than the standards, mentioned above shall also be acceptable. Where the equipment offered by the supplier conforms to other standards, salient points of difference between the standards adopted and the specified standards shall be clearly brought out in the offer. 4 (Four) copies of the reference standards in English language shall be furnished along with the offer.

### 3.0 **GENERAL TECHNICAL REQUIREMENTS** :

3.1 The Surge Arrester shall confirm the technical requirements as per Appendix-I and this TS.

3.2 The energy handling capability of each rating of Arrester offered, supported by calculations, shall be furnished with the offer.

3.3 The Surge Arresters shall be fitted with pressure relief devices and arc diverting paths and shall be tested as per the requirements of IEC for minimum prospective symmetrical fault current as specified in Appendix-I.

3.4 A grading ring shall be provided if required, (for attaining all the relevant technical parameters) on each complete Surge Arrester.

3.5 **PROTECTIVE LEVELS :**

**Surge Arresters shall be capable of providing protection to sub-station equipments, designed for the withstand levels, given in the following table.**

Sl. No.	Equipment to be protected	Insulation level of 420KV Systems	Insulation level of 245KV Systems.	Insulation Level of 145KV Systems	Insulation Level of 36KV System
		L.I. Level (KVP)	L.I. Level (KVP)	L.I. Level (KVP)	L.I. Level (KVP)
1	Auto Transformers/Power Transformers.	± 1300	± 950	± 650	± 170
2	Instrument Transformers.	± 1425	± 1050	± 650	± 170
3	Reactors	± 1300	± 950	± 650	± 170
4	Circuit Breakers/Isolators.				
(i)	Phase to ground.	± 1425	± 1050	± 650	± 170
(ii)	Across open contacts.	± 1425(+240)= 1650	± 1200		

Surge arrester shall be suitable for the following duty cycles of circuit breaker at the following system voltages:

1.	420 KV Circuit Breaker.	0-0.3 sec-co-3 min-co
2.	245 KV Circuit Breaker.	0-0.3 sec-co-3 min-co
3.	145 KV Circuit Breaker	0-0.3 sec-co-3 min-co
4.	36 KV Circuit Breaker	0-0.3 sec-co-3 min-co

### 3.6 **DUTY REQUIREMENT** :

**3.6.1 Surge Arresters shall be of heavy-duty station class and gapless type without any series or shunt gaps.**

**3.6.2 Surge Arresters shall be capable of discharging over voltages occurring during switching of un-loaded transformers, lines, capacitors and reactors.**

**3.6.3 The Surge Arresters shall be capable of discharging lightning and switching surges and temporary power frequency over-voltages.**

**3.6.4 The Surge Arresters shall be capable of discharging the energy equivalent to class 3 of IEC-99-4.**

**3.7 The reference current of the arrester shall be high enough to eliminate the influence of grading and stray capacitance on the measured reference voltage. The supplier shall submit values and the supporting evidence along with calculations on above.**

**3.8 Surge Arresters shall be fully stabilized thermally to give a life expectancy of 100 years under site conditions.**

**3.9 Surge Arresters shall be able to withstand maximum wind load of 260 Kg./sq.m.**

**3.10 Surge Arresters shall be capable of withstanding effects of direct solar radiation**

**3.11 Surge arresters shall be capable of spark over on severe switching Surges and multiple strokes.**

**3.12 The Surge Arrester should be adequately designed to operate satisfactorily under temporary power frequency over-voltage as given in specific technical requirements, after discharging two shots of respective long duration surges.**

**3.13 Unless otherwise brought out separately by the Bidder in the schedule of deviations, the Surge Arresters, offered shall conform to the specification scrupulously. All deviations from the specification shall be brought out in the schedule of deviations. The discrepancies between the specification and the catalogues or literature, submitted as part of the offer shall not be considered as valid deviations unless specifically brought out in the schedule of deviations.**

### 4.0 **CONSTRUCTION** :

4.1 Non linear blocks shall be sintered metal oxide material. These shall be provided in such a way as to obtain robust construction with excellent electrical and mechanical properties even after repeated operations.

4.1.1 All the units of arresters of same rating shall be inter-changeable without adversely affecting the performance.

4.2 The Surge Arresters shall be suitable for pedestal type mounting.

4.3 All the necessary flanges, bolts, nuts, clamps etc. required for assembly of complete arrester with accessories and mounting on support structure to be supplied by the purchaser, shall be included in supplier's scope of supply.

4.4 The drilling details for mounting the Arrester on owner's support shall be supplied by the supplier.

4.5 The minimum permissible separation between the Surge Arrester and any earthed object shall be indicated by the Bidder in his offer.

4.6 Surge Arresters shall be designed to incorporate pressure relief devices and arc diverting paths to prevent shattering of the blocks or the porcelain housing, following prolonged current flow or internal flash over and providing path for flow of rated fault currents in the event of arrester failure.

4.7 Surge Arresters shall incorporate anti-contamination feature to prevent arrester failure, caused by uneven voltage gradient across the stack, resulting from contamination of the arrester porcelain.

4.8 Seals shall be provided in such a way that these are always effectively maintained even when discharging rated lightning current.

4.9 The heat treatment cycle details alongwith necessary quality checks used for individual blocks alongwith insulation layer, formed across each block are to be furnished. Metalised coating thickness for reduced resistance between adjacent discs is to be furnished alongwith the procedure for checking the same. Details of thermal stability test for current distribution of current on individual disc is to be furnished.

4.10 Each individual unit of Surge Arresters shall be hermetically sealed and fully protected against ingress of moisture. The hermetic seal shall be effective for the entire lifetime of the arrester and under the service conditions as specified. The supplier shall furnish sectional view of the arrester showing details of sealing employed.

4.11 The Surge Arresters shall be suitable for hot line washing.

**4.12 PORCELAIN HOUSING :**

4.13.1 All porcelain Housings shall be free from lamination cavities or other flaws, affecting the maximum level of mechanical and electrical strengths.

4.13.2 The porcelain shall be well vitrified and non-porous.

4.13.3 The minimum creepage distance of the arrester housing shall be as per Appendix-I.

4.13.4 The porcelain petticoat shall be preferably of self-cleaning type (Aerofoil design). The details of the porcelain housing such as height, angle of inclination, shape of petticoats, gap between the petticoats, diameter (ID and OD) etc. shall be indicated by the Bidder in his offer in the form of detailed drawing.

4.13.5 Porcelain housings shall be so co-ordinated that external flash over will not occur due to application of impulse or switching Surge voltages up to the maximum design value for arrester.

#### **4.14 GALVANISATION, NICKEL PLATING ETC. :**

4.14.1 All ferrous parts exposed to atmosphere shall be hot dip galvanised as per IS: 2629, as amended from time to time. Tinned copper/brass lugs shall be used for internal wiring of discharge counter. Screws used for electrical connections shall be either made of brass or shall be nickel-plated.

4.14.2 Ground terminal pads and nameplate brackets shall be hot dip galvanised.

4.14.3 The material shall be galvinised only after completing all shop operations

#### **4.15 ACCESSORIES AND FITTINGS :**

4.15.1 Surge Counters;

4.15.1.1 A self- contained Surge counter, suitably enclosed for outdoor use and requiring no auxiliary of battery supply for operation shall be provided for each unit. The surge counter shall be operated by the discharge current, passed by the surge arrester and shall be suitable for mounting on the support structure of the Arrester.

4.15.1.2 Surge counters shall be of the Electro-mechanical type and designed for continuous service.

4.15.1.3 The cyclometer counter shall be visible through an inspection window from ground level. The counter terminals shall be robust and adequate size and shall be so located that the incoming and outgoing connections are made with minimum possible bends.

4.15.1.4 Internal parts shall be unaffected by atmospheric conditions at site. Alternatively, a weather proof housing to IP 55 shall be provided and this shall be designed to allow the recording device to be read from ground level without exposing the internal parts to the atmosphere.

**4.15.1.5 The Surge Counter shall be connected in the main earth lead from the arrester in such a manner that the direction of the earth lead is not changed or its surge impedance materially altered. A bolted link shall be provided so that the surge counter may be short circuited and removed without taking the arrester out of service.**

4.15.1.6 All necessary accessories and earthing connection leads between the bottom of the Arrester and discharge counter shall be in the supplier's scope of supply.

4.15.2 **LEAKAGE CURRENT METERS :**

4.15.2.1. Leakage current meters (suitable milli-ammeter) shall be connected in the earthing path of the surge arresters to measure the resistor grading leakage current. Meters shall be designed for continuous service.

4.15.2.2. The ammeter shall be suitable for mounting on the support structure of the arrester. The push buttons shall be mounted such that it can be operated from the ground level.

4.15.2.3. The internal parts shall be fully weather - proof to IP 55 or better with a transparent cover to provide an unobstructed view of the ammeter..

4.15.3. Arresters shall be complete with insulating base having provision for bolting to flat surface of the structure.

4.15.4. Grading /corona rings shall be provided on each complete Arrester unit, as required, for proper voltage stress distribution.

4.15.5. The grounding terminals shall be suitable for accommodating purchaser's grounding connection to steel earth mat.

4.15.6. The Bidder has to quote unit rates of the insulating base and the surge counter separately. The purchaser reserves its option to procure insulating base and surge counter.

4.15.7. Clamp type terminal connector, suitable for 400 KV-ACSR MOOSE/AL TUBE,220KV-ACSR MOOSE Conductor 132KV & 33KV-ACSR MOOSE Conductor shall be provided having both horizontal and vertical take-off.

4.15.8. Two clamp type ground terminal connectors, suitable for G. I. Strip (50 x 6) or (50 x 8) should be provided.

4.15.9. All interconnecting hard wares such as nuts, bolts, spring washers etc. with 5% spares shall be supplied for different units

4.15.10. Pollution Shunt (Copper braid) shall be supplied along with each surge Arrester for by-passing the surface current..

4.15.11. Other standard accessories, which are specifically not mentioned, but are usually, provided with Surge Arrester of such type and rating for efficient and trouble free operation should be supplied.

4.16 **NAME PLATE :**

Each single pole Arrester shall be provided with non-corrosive legible name plate, at the base bearing thereon, voltage rating of the complete pole and the number of demountable sections with the following data, indelibly marked

- (a) ORISSA POWER TRANSMISSION CORPORATION LIMITED.
- (b) Purchase order No. & Date.
- (c) Name of device.
- (d) Manufacturer's name and trademark and identification no. Of the arrester being supplied.
- (e) Year of manufacture
- (f) Rated voltage
- (g) Rated Frequency
- (h) Maximum continuous operating voltage.
- (i) Type
- (j) Nominal discharge current.
- (k) Long duration discharge class.
- (l) Pressure relief current in KA(rms)
- (m) Energy discharge capability ( KJ/KV rating).

## 5.0 **TEST** :

### 5.1 **Type Tests:**

The surge Arrester offered should have been subjected to the following type tests in an independent Government approved test laboratory. The bidder shall furnish four sets of type test reports alongwith the offer. These tests must not have been conducted earlier than five years from the date of opening of technical bid. For any change in the design, type already type tested and the design type offered against this specification, the purchaser reserves the right to demand repetition of some or all type tests without any extra cost to OPTCL in the presence of Purchaser's representative at the cost of the supplier.

- 1 Insulation withstands tests :
  - (a) Lightning Impulse Voltage Test.
  - (b) Wet switching impulse test. (For 390KV/216KV only).
- 2 Residual voltage tests.
- 3 Long duration current impulse withstand tests.
- 4 Operating duty tests.
- 5 Pressure relief tests.
  - (a) High current test.
  - (b) Low current test.
- 6 Power frequency voltage vs. time curve.  
(Temporary over voltage test)
- 7 Contamination test. (artificial pollution test).
- 8 Seismic withstand test.
- 9 IP-55 test on surge counter.
- 10 Minimum current operation tests of the surge counter.
- 11 Maximum current withstand test of the surge counter.
- 12 Mechanical terminal load test on bushing.
- 13 Partial discharge test.

N.B. :- Even if the condition i.e. ' the dry arcing distance or the sum of the partial dry arcing distances is larger than the test voltage divided by 500 KV/m', the lightning impulse voltage test must have been conducted or is to be conducted without any financial liability to OPTCL.

Even if the type test reports are found to be valid as per this specification, the purchaser reserves the right to demand the repetition of some or all the type tests in the presence of purchaser's representative. For this purpose, the bidder shall quote unit rates for carrying out each type test. These prices, if necessary, will be taken into consideration for bid evaluation.

## 5.2 **ROUTINE TESTS** :

The following routine tests shall be conducted at the supplier's cost on each surge arrester and shall be submitted along with or before offering for inspection for purchaser's approval.

- (a) Measurement of reference voltage.
- (b) Residual voltage tests.
- (c) Measurement for partial discharge and contact noise.
- (d) Sealing test for units with sealed housings.

## 5.3 **ACCEPTANCE TESTS** :

The following tests, considered as acceptance tests, shall be conducted in the presence of purchaser's representative for which no charges will be payable by OPTCL. The acceptance tests, whenever possible shall be conducted on the complete arrester unit. The number of samples to be subjected to acceptance test shall be decided by the purchaser at the time of actual testing.

- I Temperature Cycle Test on Housing.
- II Measurement of Power Frequency Voltage at the reference current.
- III Measurement of leakage current and capacitive current at M.C.O.V.
- IV Lightning Impulse Residual Voltage Test at N.D.C., 50% of N.D.C. & 200% of N.D.C.
- V Partial Discharge Tests on complete arresters/units at 1.05 times M.C.O.V.
- VI Special Thermal stability test.
- VII Porosity test on porcelain components.
- VIII Galvanisation test on metal parts.
  
- IX The functional (operational) test on the Surge Counter by way of checking its operation at following nominal discharge currents :
  - (i) 100 Amps with 8/20 micro second wave shape.
  - (ii) 10 KA with 8/20 micro second wave shape.
  
- X Check of calibration of leakage current meters.

## 6 **INSPECTION** :

- I The purchaser shall have access at all time to the works and all other places of manufacture, where the Surge Arresters are being manufactured and the supplier shall provide all facilities for unrestricted inspection of the supplier's works, raw materials, manufacture of all the accessories and for conducting the necessary tests.
  
- II The supplier shall keep the purchaser informed in advance of the time of starting and the progress of manufacture of equipment in its various stages so that arrangements could be made for inspection.

- III No material shall be despatched from its point of manufacture unless the material has been satisfactorily inspected, tested and despatch schedule attached to this specification.
- IV The acceptance of any quantity of equipment shall in no way relieve the supplier of his responsibility for meeting all the requirements of this specification and shall not prevent subsequent rejection, if such equipments are later found to be defective.

## 7 **QUALITY ASSURANCE PLAN** :

7.1 The Bidder shall invariably furnish following informations alongwith his offer, failing which the offer shall be liable for rejection.

- (i) Statement giving list of important raw materials, names of sub-suppliers for the raw materials, list of standards according to which the raw materials are tested, list of tests, normally carried out on raw materials in presence of Bidder's representative, copies of test certificates.
- (ii) Information and copies of test certificates as in (I) above in respect of bought-out items.
- (iii) List of manufacturing facilities available.
- (iv) Level of automation, achieved and list of areas where manual processing exists.
- (v) List of areas in manufacturing process where stage inspections are normally carried out for quality control and details of such tests and inspections.
- (vi) Special features provided in the equipment to make it maintenance free
- (vii) List of testing equipments, meters available with Bidder for final testing of equipment, specified and test plant limitation, if any, vis-à-vis the type, acceptance and routine tests, specified in the relevant standards and this specification. These limitations shall be very clearly brought out in the offer.
- (viii) All the testing equipments, meters etc. should have been calibrated in a Government approved laboratory. The Bidder must submit the list of testing equipments and meters test-wise as per Annexure-C of this Technical Specification.

7.2 The suppliers, within 30 days of placement of order submit the following informations to the purchaser.

- (i) List of raw materials as well as bought out accessories and the names of the materials as well as bought-out accessories and the names of sub-suppliers, selected from those, furnished alongwith the offer.
- (ii) Type test certificates of the raw material and bought out accessories.
- (iii) Quality Assurance Plan (QAP) with hold points for the purchaser's inspection. The QAP and hold points shall be discussed between the purchaser and the supplier before the QAP is finalised.

7.3 The supplier shall submit the routine test certificates of bought out item and raw martial at the time of acceptance testing of the fully assembled equipment.

## 8.0 **DOCUMENTATION** :

8.1 All drawings shall conform to relevant Indian Standard as per relevant IS. All drawings shall be in ink and suitable for microfilming. All dimensions and data shall be in S.I. Units.

- 8.2 The supplier shall furnish four sets of following drawings/documents' along with his offer.
- (i) General outline drawings of the complete Arrester with technical parameters.

- (ii) Drawings showing clearance from grounded and other line objects and between adjacent poles of Surge Arresters, required at various heights of Surge Arresters.
- (iii) Drawings showing details of pressure relief devices.
- (iv) Detailed drawing of discharge counters along with the wiring and schematic drawing of discharge counter and meter.
- (v) Outline drawing of insulating base.
- (vi) Details of grading rings, if used.
- (vii) Mounting details of Surge Arresters.
- (viii) Details of line terminal and ground terminals.
- (ix) Volt-time characteristics of Surge Arresters.
- (x) Details of galvanization being provided on different ferrous parts.
- (xi) The detailed dimensional drawing of porcelain Housing such as ID, OD, thickness and insulator details such as height, profile of petticoats, angle of inclination and gap between successive petticoats, total creepage distance etc.
- (xii) Cross-sectional view of the Surge Arrester Units showing all components.

### 8.3 **TEST REPORTS :**

- (i) Four copies of type test reports shall be furnished to the purchaser with the tender specification. Copies of acceptance test reports and routine test reports shall be furnished to the purchaser. One copy will be returned duly certified by the purchaser and only thereafter shall the materials be despatched.
- (ii) All records of routine test reports shall be maintained by the supplier at his works for periodic inspection by the purchaser.
- (iii) All test reports of tests, conducted during manufacture shall be maintained by the supplier. These shall be produced for verification as and when requested for by the purchaser.

### 9.0 **PACKING AND FORWARDING :**

9.1 The equipment shall be packed in suitable crates so as to withstand handling during transport and outdoor storage during transit. The supplier shall be responsible for any damage to the equipment during transit, due to improper and inadequate packing. The easily damageable material shall be carefully packed and marked with the appropriate caution symbols. Wherever necessary, proper arrangement of lifting such as lifting hooks etc. shall be provided. Any material found short inside the packing cases shall be supplied by the supplier without any extra cost.

9.2 Each consignment shall be accompanied by a detailed packing list containing the following informations :

- (a) Name of the consignee :
- (b) Details of consignment :
- (c) Destination :
- (d) Total weight of consignment :
- (e) Sign showing upper/lower side of the crate :
- (f) Handling and unpacking instructions :
- (g) Bill of materials indicating contents of each package :

9.3 The supplier shall ensure that the bill of materials is approved by the purchaser before despatch.

### 10.0 **QUANTITY AND DELIVERY REQUIREMENT :**

- (i) The scope of supply shall include a supply of 2.5% extra quantity of bolts, nuts, washers, split pins, cotter pins and such other small loose items free of cost.



## APPENDIX – I.

### (TECHNICAL REQUIREMENTS)

#### TECHNICAL REQUIREMENTS FOR METAL OXIDE (GAPLESS) SURGE ARRESTERS

The Surge Arrester under this Specification shall conform to the parameters given below :-

		390KV	216KV	120KV	30KV
Sl. No.	Particulars.	Technical Parameters	Technical Parameters.	Technical Parameters	Technical Parameters
1	Nominal system voltage (phase to phase) (KV rms).	400	220	132	33
2	Highest system voltage (phase to phase) (KV rms).	420	245	145	36
3	System Frequency (HZ).	$50 \pm 5 \%$	$50 \pm 5 \%$	$50 \pm 5\%$	$50 \pm 5\%$
4	System Neutral earthing.	Effectively earthed.	Effectively earthed.	Effectively earthed	Effectively earthed
5	Installation.	Outdoor.	Outdoor.	Outdoor	Outdoor
6	Class.	Station class, 10 KA, heavy duty type.	Station class, 10 KA, heavy duty type.	Station class, 10 KA, heavy duty type.	Station class, 10 KA, heavy duty type.
7	Type of construction for 10 KA rated arrester.	Single column, single phase.	Single column, single phase.	Single column, single phase.	Single column, single phase
8	No. of phases.	Three	Three	Three	Three
9	Maximum duration of earth fault (Sec.)	3	3	3	3
10	Maximum prospective symmetrical fault current at arrester location (KA rms.)	40	40	40	40
11	Rated arrester voltage (KV rms)	390	216	120	30
12	Nominal discharge current (KAP)  Disscharge current at which insulation coordination will be done	10 KA of 8/20 micro-second Wave. And 20 KA of 8/20 microsec wave	10 KA of 8/20 micro-second Wave.	10 KA of 8/20 micro-second Wave.	10 KA of 8/20 micro-second Wave.
13	Minimum energy discharge capability (KJ/KV)	As per relevant ISS/IEC	As per relevant ISS/IEC	As per relevant ISS/IEC	As per relevant ISS/IEC

14	Maximum continuous operating voltage at 50° C(KV rms)	303	175	102	25
15	Maximum switching surge residual voltage (KVP)	780 at 1KA	496 at 1KA	272 at 1KA	72 at 500A
16	Maximum residual voltage at 8/20 micro second(KVP)				
	(i) 5 KA.		567	320	85
	(ii) 10 KA Nominal discharge current.	900 KVP	600	340	90
	(iii) 20 KA.	975 KVP	668	380	100
17	Long duration discharge class	3	3	3	2
18	High current short duration test value (KAP)(4/10 Micro-second wave).	100	100	100	100
19	Current for pressure relief test (KA-rms)	40	40	40	40
20	Minimum total creepage distance (mm).	10500	6125	3625	900
21	One minute dry and wet power frequency withstand voltage of Arrester housing (KV-rms).	630	460	275	70
22(a)	Impulse withstand voltage of arrester housing with 1.2/50 micro-second wave (KVP).	<b>+1425</b>	+ 1050	+650	+170
22(b)	Switching Impulse Voltage (Wet) (KVP)	<b>+1050</b>	700	-	-
23	Pressure relief class.	A	A	A	A
24	Corona extinction voltage (KV-rms).	320 min	216	-	-
25	RIV at 92 KV rms.	Less than 500 micro volts	Less than 500 micro volts.	Less than 500 micro volts.	Less than 500 micro volts
26	Partial discharge at 1.05 times continuous over-voltage.	Nor more than 50 PC.	Nor more than 50 PC.	Nor more than 50 PC	Nor more than 50 PC
27	Seismic acceleration.	0.3g horizontal 0.15g vertical	0.3g horizontal 0.15g vertical.	0.3g horizontal 0.15g vertical.	0.3g horizontal 0.15g vertical
28	Reference ambient temperature.	50°C	50°C	50°C	50°C
29	(a) IR at MCOV.	Less than 500 micro amperes.	Less than 500 micro amperes.	Less than 500 micro amperes.	Less than 400 micro amperes

	(b) IC at MCOV.	Less than 1500 micro amperes.	Less than 1500 micro amperes.	Less than 1500 micro amperes.	Less than 1200 micro amperes
30	a) Reference Current (mA)	1 to 5 mA	1 to 5 mA	1 to 5 mA	1 to 5 mA
	b) Reference voltage at reference current.	Greater than rated voltage.	Greater than rated voltage.	Greater than rated voltage.	Greater than rated voltage.
31	Maximum steep current Impulse RDV (KVP). at 10 KAP	1050	654	372	100
32	Maximum cantilever strength of the arresters (KGM).	1000	1000	1000	325
33	TOV(KVP).				
	(i) 0.1 sec.	580	382	170	53
	(ii) 1.0 sec.	565	366	163	51
	(iii) 10.0 sec.	550	351	156	49
	(iv) 100.0 sec.		336	149	47

## **ANNEXURE – B**

### **CHECK – LIST**

- 1 Whether calculation towards energy handling capability of the Surge Arrester furnished as per Clause No.3.2 of TS ?
- 2 Whether there is provision of Corona Grading Ring in the SA as per Clause No.3.4 and 4.15.4 of TS ? ..... If not, whether justification for non-provision of the same furnished ?
- 3 Whether calculations and supporting evidence furnished to satisfy Clause No.3.7 of TS ?
- 4 Whether the heat treatment cycle details alongwith necessary quality checks used for individual blocks furnished as per Clause 4.10 of TS ?
- 5 Whether sectional view of arrester showing details of sealing provided as per Clause No.4.11 of TS furnished ?
- 6 Whether S.A. is suitable for hot line washing as per Clause No.4.12 of TS ?
- 7 Whether porcelain petticoat is of Aero foil design ? Whether drawing of porcelain Housing as per Clause No.4.13.4 of TS furnished ?
- 8 Whether information as per Clause No.7.1 (i) to (viii) of TS

furnished ?

9 Whether drawings and documents as per Clause No.8.2 (i) to (xii) of TS furnished ?

10 Whether special measures in the manufacture of Surge Arrester for operating at ambient temperature of 50°C (against 40°C as per IEC-99-4, Clause No.4.4.1) are to be taken ?  
..... State the special measures in details .....

Signature of the Tenderer With Seal & Date

**ANNEXURE-D**  
**CHECK LIST TOWARDS TYPE TEST REPORTS.**

Name of the Type Test.	Date of Test.	Name of the Laboratory where the Test has been conducted.	Whether the Laboratory is Government Approved.	Whether the Test reports are valid as per Clause No.5.1 of T.S.	Whether the copy of Test Report in complete shape alongwith drawings etc. furnished or not ?	Whether the Type Tested Surge Arrester fulfills the technical requirements as per TS.	<b>If the type tested Surge Arrester does not fulfill the technical requirements as per this specification, whether the bidder agrees to conduct the particular type test again at their own cost without any financial liability to OPTCL in the presence of OPTCL's representative within the specified delivery period.</b>	Remarks.
1	2	3	4	5	6	7	8	9

Signature of the Tenderer with seal and date.

**CALIBRATION STATUS OF TESTING EQUIPMENTS AND INSTRUMENTS/METERS.**

Name of the test.	Meters and equipments required for the corresponding test with range accuracy make and Sl. No.	Date of Calibration.	Due date of Calibration.	Name of the Calibrating Agency	Whether Calibrating Agency is Govt. Approved.	Whether documents relating to Govt. Approval of the calibrating Agency furnished ?	Whether the meters/equipment fulfill the accuracy class as per calibration report	Whether the calibrating agency has put any limitation towards the use of the particular meter/equipment. If yes, state the limitations.	Whether green sticker or blue sticker or yellow sticker has been affixed on the body of the particular equipment/meter. State the colour of the affixed sticker.	In spite of imposed limitations, whether the particular meter/equipment can still be used? Justify its use for corresponding test(s).	Remarks
1	2	3	4	5	6	7	8	9	10	11	12

Signature of the tenderer with seal and date.